

REPORT ID: **14215.01.T05.RP6**

Adelaide Wind Power Project – Turbine T05 (AD117)
IEC 61400-11 Edition 3.0 Measurement Report


Prepared for:

Suncor Adelaide Wind General Partnership Inc.
2489 North Sheridan Way
Mississauga, ON, L5K 1A8

Prepared by:

A. Munro

Allan Munro, B.A.Sc.



Payam Ashtiani, B.A.Sc., P.Eng.

13 July 2018 – Revision #6



Revision History

Revision Number	Description	Date
1	Issued Edition 2.1 test report [May Data]	17/09/2015
2	Issued Edition 2.1 test report [May and October Data] Draft	20/10/2015
3	Issued Edition 2.1 test report [May and October Data] Final	28/10/2015
4	Issued Edition 3.0 test report [October Data]	19/09/2017
5	Updates to report to fix typographical errors in Table T10 and Table E.02, Added Appendix F - Calibration Certificates	15/06/2018
6	Updates to section 3.2.1, Added Table 9, Table B.01 and E-Audit Checklist	13/07/2018

This report in its entirety, including appendices contains 102 pages.

Statement Qualifications and Limitations

This report was prepared by Aeroustics Engineering Limited in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), "Wind turbine generator systems – Part 11: Acoustic noise measurement techniques". This report is specific only to the Wind Turbine identified in this report.

Aeroustics Engineering Limited shall not be responsible for any events or circumstances that may have occurred since the date on which the Wind Turbine was tested and/or this report was prepared, or for any inaccuracies contained in information that was provided to Aeroustics Engineering Limited. Further, Aeroustics Engineering Limited agrees that this report represents test data analysed as per the above described standard for the specific Wind Turbine described in this report, but Aeroustics Engineering Limited makes no other representations with respect to this report or any part thereof.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Aeroustics Engineering Limited accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Any use of this report is subject to this Statement of Qualifications and Limitations. Any damages arising from improper use of this report or parts thereof shall be borne by the party making such use.

This Statement of Qualifications and Limitations is attached to and forms part of this report.

Table of Contents

Revision History	2
Statement Qualifications and Limitations	2
List of Appendices	6
1 Introduction	8
2 Wind Turbine Information	8
2.1 Wind turbine equipment specific information.....	8
2.2 Wind Turbine Location.....	9
3 Measurement Details	10
3.1 Measurement Equipment.....	10
3.1.1 Acoustic Measurement Equipment.....	10
3.1.2 Meteorological Equipment.....	10
3.2 Measurement Setup	10
3.2.1 Microphone Placement.....	10
3.2.2 Double Windscreen Setup.....	11
3.3 Measurement Schedule.....	11
3.4 Meteorological Conditions.....	11
3.5 Turbine operational information	11
4 Measurement Results	12
4.1 Deviations from IEC-61400-11 Edition 3.0.....	12
4.2 Special Notes & Considerations	12
4.3 Analysis Details	12
4.3.1 Double Windscreen Adjustment	12
4.3.2 Wind Speed Correction	12
4.4 Type B uncertainties	12
4.5 Sound Pressure Level Measurements	13
4.6 Sound Power Level of Turbine.....	14
4.7 Tonality Analysis.....	14
5 Closure	15
6 References	15

List of Figures

Figure A.01 – Site plan.....	Appendix A
Figure A.02 – Site photos	Appendix A
Figure B.01 – Power Curve.....	Appendix B
Figure B.02 – Rotor RPM vs. Wind Speed.....	Appendix B
Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON & Background).....	Appendix C
Figure C.02 – Plot of measured total noise vs electrical power output.....	Appendix C
Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer.....	Appendix C
Figure C.04 - Plot of rotor RPM vs. electrical power output.....	Appendix C
Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 7 m/s.....	Appendix C
Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 7.5 m/s.....	Appendix C
Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 8 m/s.....	Appendix C
Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s.....	Appendix C
Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s.....	Appendix C
Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s.....	Appendix C
Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s.....	Appendix C
Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s.....	Appendix C
Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s.....	Appendix C
Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s.....	Appendix C
Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 7 m/s...Appendix D	
Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 7.5 m/s...Appendix D	
Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 8 m/s....Appendix D	
Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s...Appendix D	
Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s....Appendix D	
Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s...Appendix D	
Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s....Appendix D	
Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s...Appendix D	
Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s.....Appendix D	
Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s...Appendix D	

List of Tables

Table 1 - Wind Turbine Details	8
Table 2 - Operating Details.....	8
Table 3 - Rotor Details.....	9
Table 4 - Gearbox Details.....	9
Table 5 - Generator Details	9
Table 6 - Acoustic Measurement Equipment.....	10
Table 7 – Meteorological Measurement Equipment.....	10
Table 8 - Measurement Schedule Summary	11
Table 9 - Calculated nacelle anemometer (k_nac) and 10m (k_Z) wind speed k-factor.....	12
Table 10 - Summary of Type B uncertainties	13
Table 11 - Summary of Sound Pressure Level Measurements	13
Table 12 - L _{WA} , K at each integer wind speed	14
Table 13 - L _{WA} 10m, K at each integer wind speed	14
Table 14 - Tonality Assessment Summary.....	14
Table B.01 – Allowed range of power curve and required wind speeds	Appendix B
Table C.01 – Detailed apparent sound power level data at hub height.....	Appendix C
Table C.02 – Detailed apparent sound power level data at 10m height.....	Appendix C
Table C.03 – Type B measurement uncertainty summary.....	Appendix C
Table C.04 – Detailed measurement uncertainty at hub height.....	Appendix C
Table E.01 – Measurement data –Turbine ON.....	Appendix E
Table E.02 – Measurement data – Background.....	Appendix E

List of Appendices

Appendix A – Site Details

- Figure A.01 – Site plan
- Figure A.02 – Site photos

Appendix B – Turbine Information

- Figure B.01 – Power curve
- Figure B.02 – Rotor RPM vs. wind speed
- Table B.01 – Allowed range of power curve and required wind speeds

Appendix C – Apparent Sound Power Level

- Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)
- Figure C.02 – Plot of measured total noise vs electrical power output
- Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer
- Figure C.04 - Plot of rotor RPM vs. electrical power output
- Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 7 m/s
- Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 7.5 m/s
- Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 8 m/s
- Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s
- Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s
- Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s
- Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s
- Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s
- Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s
- Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s
- Table C.01 – Detailed apparent sound power level data at hub height
- Table C.02 – Detailed apparent sound power level data at 10m height
- Table C.03 – Type B measurement uncertainty summary
- Table C.04 – Detailed measurement uncertainty at hub height

Appendix D – Tonality Assessment

- Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 7 m/s
- Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 7.5 m/s
- Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 8 m/s
- Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s
- Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s
- Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s
- Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s
- Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s
- Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s
- Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s

Appendix E – Measurement Data

- Table E.01 – Measurement data –Turbine ON
- Table E.02 – Measurement data – Background

Appendix F – Calibration Certificates

Appendix G – E-Audit Checklist

1 Introduction

Aercoustics Engineering Limited (Aercoustics) was retained by Suncor Adelaide Wind LP ("Suncor Adelaide") to conduct an acoustic measurement of turbine T05 at the Suncor Adelaide Wind Farm. The purpose of the measurement was to provide verification of the maximum noise emission of the turbine. The measurement was carried out in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), "Wind turbine generator systems – Part 11: Acoustic noise measurement techniques". This report is specific only to Turbine T05.

2 Wind Turbine Information

2.1 Wind turbine equipment specific information

Wind turbine specific equipment information for turbine T05 was provided by Suncor Adelaide and is summarized in Tables 1 – 5.

Table 1 - Wind Turbine Details

Wind Turbine Details	
Manufacturer	Siemens
Model Number	SWT2.3-113
Turbine ID	2308445

Table 2 - Operating Details

Operating Details	
Vertical or Horizontal axis wind turbine	Horizontal
Upwind or downwind rotor	Upwind rotor
Hub height	99.5 m
Horizontal distance from rotor centre to tower axis	5.5 m
Diameter of rotor	113 m
Tower type (lattice or tube)	Tubular
Passive stall, active stall, or pitch controlled turbine	Pitch controlled turbine
Constant or variable speed	Variable speed
Power curve	Rev 1
Rotational speed at each integer standardised wind speed	13.0
Rated power output	2221 kW
Control software version	121.3.0.1

Table 3 - Rotor Details

Rotor Details	
Rotor control devices	Pitch control
Presence of vortex generators, stall strips, serrated trailing edges	Vortex generators and dino tails
Blade type	B55
Serial number	Blade A: 550308701 Blade B: 550313201 Blade C: 550313001
Number of blades	3

Table 4 - Gearbox Details

Gearbox Details	
Manufacturer	n/a a direct drive turbine
Model number	n/a a direct drive turbine
Serial number	n/a a direct drive turbine

Table 5 - Generator Details

Generator Details	
Manufacturer	Siemens
Model number	DD22_02
Serial number	5970749

2.2 Wind Turbine Location

Turbine T05 is located in the municipality of Adelaide Metcalfe, Ontario approximately 860m North of Egremont Drive, and 750m East of Newell Road. The area surrounding T05 is flat and consists primarily of farmland.

A general layout of the area in which the turbine is located is provided in the site plan (Figure A.01).

3 Measurement Details

3.1 Measurement Equipment

3.1.1 Acoustic Measurement Equipment

A summary of acoustic equipment utilized by Aercoustics for the measurement of turbine T05 is summarized in Table 6.

Table 6 - Acoustic Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Acoustic Data acquisition system	LMS SCADA Mobile	53103922
Microphone	B&K 4189	2625197
Pre-amplifier	B&K 2671	2614901
Acoustic calibrator	B&K 4231	2513184

Calibration of the measurement setup was carried out before and after Aercoustics set of measurements.

3.1.2 Meteorological Equipment

Wind speed for Turbine ON was derived from the power curve (as per procedures outlined in IEC 61400-11). Wind direction for turbine ON measurements was utilized from the nacelle anemometer located at hub height (100m high) from turbine T05. Data for background measurements was obtained from a 10m high anemometer, which was placed as per guidelines outlined in IEC-61400-11.

The meteorological equipment is summarized in Table 7

Table 7 – Meteorological Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Anemometer	VAISALA WXT520	G4420002
Serial to Analog Converter	NOKEVAL 7470	A159784

3.2 Measurement Setup

3.2.1 Microphone Placement

The measurement microphone was setup 156m from the base of the turbine in ‘Position 1’, (i.e. downwind of the turbine, as per IEC 61400-11) at an elevation of 0m relative to the base of T05. The slant distance (R_1) from microphone location to rotor centre includes the distance from rotor center (hub) to tower axis ($R_1 = 191.7\text{m}$). The microphone was placed in the centre of a circular, acoustically reflective board.

During the measurement period only data points for which the microphone was within 15 degrees of downwind from the turbine were used. The microphone position relative to

downwind of the turbine was monitoring via the yaw angle output provided from the turbine system (discussed further in Section 3.5). During placement of the microphone the turbine was parked and the reference yaw angle for that measurement logged.

When measurements of T05 were taken, the surrounding land was bare farm land. There were no nearby reflecting surfaces (houses, barns etc.); as such the influence from reflecting surfaces was considered to be negligible

Photos of the measurement setup are provided in Figure A.02, Appendix A.

3.2.2 Double Windscreen Setup

A double windscreen setup was not utilized.

3.3 Measurement Schedule

Table 8 provides a summary of the test date and times. Data was logged in 10 second intervals for post-processing (as per the measurement standard).

Table 8 - Measurement Schedule Summary

Date	Test Type	Start Time	Finish time
October 9, 2015	Turbine ON	1:45pm	2:22pm
	Turbine ON	2:28pm	2:32pm
	Background	2:33pm	3:02pm
	Turbine ON	3:02pm	3:42pm
	Turbine ON	3:58pm	4:36pm
October 13, 2015	Turbine ON	12:05pm	1:05pm
	Turbine ON	1:13pm	2:13pm
	Background	2:28pm	2:58pm

3.4 Meteorological Conditions

Detailed meteorological data relevant to the measurement is provided in Appendix E.

As previously mentioned, wind speed for Turbine ON was derived from T05's power curve (as per the standard), while wind direction was provided by T05's nacelle anemometer (located at hub height). Background data was obtained from an anemometer located 10m above ground level near T05.

Temperature and pressure readings during the measurement period were provided by the 10m anemometer, located near turbine T05 for the duration of Aercoustics measurements.

3.5 Turbine operational information

Output data from the turbine (Power, yaw, RPM, pitch angle, and nacelle wind speed) were obtained as analog output signals that were simultaneously acquired with the acoustic and anemometer measurement data using Aercoustics data acquisition system.

4 Measurement Results

4.1 Deviations from IEC-61400-11 Edition 3.0

No deviations.

4.2 Special Notes & Considerations

T06 was turned off for the duration of testing at T05.

4.3 Analysis Details

The following section outlines analysis of the measurement data acquired for T05. The data presented is exclusive of transient events such as vehicle traffic, wildlife, air traffic etc. The site has been assessed to have a roughness length of 0.05m, representative of farmland with some vegetation.

4.3.1 Double Windscreen Adjustment

As previously mentioned, no double wind screen was used, as such the measurement data did not require adjustment.

4.3.2 Wind Speed Correction

The wind speed for each measurement data point for Turbine ON was derived through the power curve (as per Section 8.2.1.1 of IEC-61400-11). For data points during Turbine ON that were outside the allowed range of the power curve, the wind speed was derived from the nacelle anemometer wind speed (as specified in Section 8.2.1.2 of IEC-61400-11).

Background wind speed was derived utilizing data acquired with the 10m anemometer and normalizing the wind speed (as per Section 8.2.2 of IEC-61400-11).

Table 9 - Calculated nacelle anemometer (k_{nac}) and 10m (k_Z) wind speed k-factor

k_{nac}	k_Z
0.99	1.94

4.4 Type B uncertainties

Type B uncertainties were obtained through interpretation of information provided in Annex C of IEC-61400-11, and instrument uncertainties obtained from the calibration certificate. A summary of Type B uncertainties is provided in Table 10, while detailed information (including data in 1/3 octave) is provided in Appendix C.

Table 10 - Summary of Type B uncertainties

Component	Typical (dB)	Used (dB)
Calibration	0.2	0.2
Board	0.3	0.3
Distance & direction	0.1	0.1
Air absorption	0	0
Weather conditions	0.5	0.5
Wind speed measured	0.7	0.7
Wind speed derived	0.2	0.2
Wind speed from power curve	0.2	0.2

4.5 Sound Pressure Level Measurements

Sound pressure level measurements are summarized in Table 11. Detailed 1/3 Octave band spectrum data, respective uncertainties, and analysis plots are provided in Appendix C. A copy of the measurement data used for analysis is provided in Appendix E and includes meteorological and turbine operational data.

The purpose of this measurement was to verify turbine noise emission, and testing was conducted in conformity with IEC 61400-11-Ed 3.0 Section 5, Paragraph 3. The wind speed range for documentation is related to the specific wind turbine. As a minimum, it is defined as the hub height wind speed from 0.8 to 1.3 times the wind speed at 85% of maximum power rounded to bin centres. For Turbine T05 this corresponds to a hub height wind speed of 7 m/s to 11.5 m/s.

Table 11 - Summary of Sound Pressure Level Measurements

Wind Speed (m/s)	Turbine ON		Background		Turbine ON, Background adjusted L _{eq} , (dBA)
	L _{eq} , (dBA)	# of data pts	L _{eq} , (dBA)	# of data pts	
7	51.6	18	42.0	13	51.1
7.5	52.9	52	42.3	14	52.5
8	53.8	132	42.4	30	53.5
8.5	54.0	153	43.7	23	53.6
9	54.0	179	43.5	24	53.6
9.5	53.8	100	42.6	21	53.5
10	53.4	133	42.3	17	53.0
10.5	53.5	121	42.6	23	53.1
11	53.4	111	42.8	15	53.0
11.5	53.4	108	42.7	19	53.0

4.6 Sound Power Level of Turbine

The calculated sound power level of the turbine T05 (as per IEC 61400-11) is summarized in Table 12 (hub height) and Table 13 (10m height). Detailed 1/3 Octave band spectrum data and respective uncertainties are provided in Appendix C.

Table 12 - $L_{WA,K}$ at each integer wind speed

Wind Speed (m/s)	Apparent L_{WA} , (dBA)	Uncertainty (dB)
7	101.7	0.8
7.5	103.1	0.7
8	104.1	0.8
8.5	104.2	0.8
9	104.2	0.8
9.5	104.1	0.7
10	103.7	0.7
10.5	103.8	0.8
11	103.6	0.8
11.5	103.6	0.8

Table 13 - $L_{WA,10m,K}$ at each integer wind speed

Wind Speed (m/s)	Apparent L_{WA} , (dBA)	Uncertainty (dB)
5	102.9	1.2
6	104.2	0.8
7	103.8	0.8
8	103.6	0.8
9	103.5	0.9

4.7 Tonality Analysis

The tonality analysis for Turbine T05 is summarized in Table 14, while plots of narrow band spectra at each wind speed are provided in Appendix D. The ΔL_{tn} and ΔL_a values reported represent the energy average of all data points with an identified tone that falls within the same frequency origin (as specified in Section 9.5.8 in IEC-61400-11).

The narrow band spectra provided in the plots represents an energy average of all data points in the given wind speed bin for both Turbine ON and Background. No relevant tones were measured.

Table 14 - Tonality Assessment Summary

Wind Speed (m/s)	Frequency (Hz)	Tonality, ΔL_{tn} (dB)	Tonal audibility, ΔL_a (dB)	FFT's with tones	Total # of FFT's	Presence (%)
No Reportable Tones Detected						

5 Closure

Measurements and analysis were carried on Turbine T05 of the Suncor Adelaide Wind Farm, located in the municipality of Adelaide Metcalfe as per International IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”.

Should you have any questions or comments please do not hesitate to contact the authors of this report.

6 References


1. International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”.

Appendix A Site Details






Appendix B Turbine Information



Power Curve	
Hub Wind Speed (m/s)	Power [kW]
0	0
1	0
2	0
3	65
4	169
5	347
6	615
7	989
8	1471
9	1951
10	2172
11	2217
12	2221
13	2221
14	2221
15	2221
16	2221
17	2221
18	2221
19	2221
20	2221
21	2221
22	2221
23	2221
24	2221
25	2221



14215.01.T05.RP6

Project Name

Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Scale: NTS

Drawn by: AM

Reviewed by: PA

Date: Sept 15, 2017

Revision: 1

Figure Title

Rotor RPM vs. wind speed

Figure B.02

Table B.01 Allowed range of power curve and required wind speeds

Project: Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement

Report ID: 14215.01.T05.RP6


Page 1 of 1


Created on: 7/11/2018


Power Curve & Required Wind Speeds		
Power Curve Tolerance	1%	
Min allowable range	2	m/s
Max allowable range	10	m/s
Power Output	2221	kW
85% Power	1887.85	kW
Corresponding wind speed	8.87	m/s
Minimum bin	7.0	m/s
Maximum bin	11.5	m/s

Hub Wind Speed (m/s)	Power [kW]	+ value = acceptable slope of power curve
0	0	-44.42
1	0	-44.42
2	0	20.58
3	65	59.58
4	169	133.58
5	347	223.58
6	615	329.58
7	989	437.58
8	1471	435.58
9	1951	176.58
10	2172	0.58
11	2217	-40.42
12	2221	-44.42
13	2221	-44.42
14	2221	-44.42
15	2221	-44.42
16	2221	-44.42
17	2221	-44.42
18	2221	-44.42
19	2221	-44.42
20	2221	-44.42
21	2221	-44.42
22	2221	-44.42
23	2221	-44.42
24	2221	-44.42
25	2221	

Appendix C Apparent Sound Power Level







14215.01.T05.RP6

Scale: NTS

Drawn by: AM

Reviewed by: PA

Date: Sept 15, 2017

Revision: 1


Project Name


Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0


Figure Title


Plot of rotor RPM vs. electrical power output


Figure C.04


























Table C.01 Detailed apparent sound power level data at hub height

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement

Report ID: 14215.01.T05.RP6

Page 1 of 2

Created on: 9/6/2017

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																								Overall					
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
7.0	Turbine ON (dBA)	9.0	13.4	17.5	20.9	24.8	31.5	31.1	34.3	36.9	38.6	39.6	40.5	40.7	39.6	39.2	39.9	38.8	39.0	39.0	39.0	38.9	39.3	38.6	37.5	35.0	32.3	28.8	24.8	51.6	
	Background (dBA)	2.7	5.7	9.7	10.4	12.5	17.8	19.8	21.0	24.0	25.5	26.8	28.2	29.3	28.9	29.5	29.9	30.3	30.3	29.4	29.3	29.2	30.1	30.0	32.8	28.7	26.7	24.2	20.9	42.0	
	Turbine ON - background adj (dBA)	7.9	12.6	16.7	20.5	24.5	31.3	30.8	34.0	36.6	38.4	39.4	40.3	40.4	39.2	38.7	39.5	38.1	38.4	38.5	38.5	38.4	38.7	38.0	35.6	33.9	30.9	27.0	22.5	51.1	
	Signal to noise (dB)	6.4	7.7	7.8	10.4	12.3	13.8	11.4	13.3	12.8	13.2	12.9	12.3	11.5	10.7	9.7	10.0	8.5	8.7	9.6	9.6	9.6	9.2	8.6	4.6	6.3	5.6	4.6	3.9	9.6	
	Uncertainty (dB)	1.4	1.3	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	1.0	1.4	1.3	1.5	2.0	3.1
7.5	PWL (dBA)	58.5	63.2	67.4	71.1	75.2	82.0	81.5	84.7	87.3	89.1	90.1	90.9	91.1	89.9	89.3	90.1	88.8	89.0	89.2	89.1	89.0	89.4	88.6	86.3	84.5	81.5	77.6	73.1	101.7	
	Turbine ON (dBA)	9.5	14.0	18.2	21.7	25.6	31.9	31.8	34.8	37.5	39.3	40.6	41.6	42.1	41.2	40.7	41.6	40.5	40.7	40.5	40.3	40.2	41.0	39.9	38.4	36.0	33.2	29.7	25.7	52.9	
	Background (dBA)	3.7	6.3	10.1	10.9	12.8	17.9	20.4	21.9	25.0	26.7	27.4	29.0	29.5	28.8	30.3	30.5	31.1	31.1	30.4	30.2	29.9	30.8	30.3	31.7	28.2	26.1	23.5	20.2	42.3	
	Turbine ON - background adj (dBA)	8.2	13.2	17.5	21.3	25.3	31.7	31.5	34.6	37.2	39.1	40.4	41.4	41.8	40.9	40.3	41.2	39.9	40.1	40.0	39.9	39.7	40.6	39.3	37.4	35.2	32.3	28.6	24.2	52.5	
	Signal to noise (dB)	5.8	7.7	8.1	10.8	12.7	14.0	11.4	12.9	12.5	12.6	13.1	12.6	12.4	10.5	11.0	9.3	9.6	10.1	10.1	10.3	9.6	6.7	7.8	7.1	6.2	5.4	10.5			
8.0	Uncertainty (dB)	1.4	1.2	0.9	0.8	0.7	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	1.0	1.0	1.1	1.2	2.1	0.7
	PWL (dBA)	58.9	63.8	68.2	72.0	76.0	82.4	82.1	85.2	87.9	89.7	91.0	92.0	92.5	91.6	91.0	91.9	90.6	90.8	90.7	90.5	90.4	91.3	90.0	88.0	85.9	82.9	79.2	74.8	103.1	
	Turbine ON (dBA)	10.8	15.3	19.0	22.4	26.2	31.9	32.7	35.6	38.5	40.2	41.5	42.8	42.9	41.9	41.9	42.4	41.7	41.8	41.5	41.3	41.0	41.9	40.6	38.9	36.3	33.1	29.2	25.0	53.8	
	Background (dBA)	7.6	10.0	12.3	13.2	16.9	19.8	21.2	23.0	26.2	27.2	28.7	29.7	29.4	28.6	30.0	29.9	30.9	30.8	30.3	30.5	30.2	30.7	30.4	31.4	28.5	26.5	24.0	20.7	42.4	
	Turbine ON - background adj (dBA)	7.9	13.8	18.0	21.9	25.7	31.7	32.4	35.3	38.2	40.0	41.3	42.6	42.7	41.7	41.6	42.2	41.4	41.5	41.2	40.9	40.6	41.6	40.2	38.0	35.5	32.0	27.7	23.0	53.5	
8.5	Signal to noise (dB)	3.2	5.3	6.7	9.3	9.3	12.1	11.5	12.6	12.3	13.0	12.9	13.1	13.6	13.3	11.9	12.5	10.9	11.0	11.2	10.8	10.8	11.2	10.2	7.5	7.7	6.6	5.3	4.3	11.4	
	Uncertainty (dB)	2.5	1.5	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	1.0	1.0	1.1	1.4	0.8	
	PWL (dBA)	58.5	64.4	68.6	72.5	76.3	82.3	83.0	86.0	88.9	90.6	92.0	93.2	93.4	92.3	92.2	92.8	92.0	92.1	91.8	91.6	91.3	92.2	90.9	88.7	86.1	82.7	78.3	73.6	104.1	
	Turbine ON (dBA)	12.7	16.8	19.7	22.9	26.4	32.1	33.3	35.9	38.9	40.5	41.8	43.0	43.0	41.8	41.9	42.3	41.9	42.1	41.8	41.6	41.3	42.1	41.0	39.3	36.7	33.6	29.8	25.5	54.0	
	Background (dBA)	8.7	11.4	13.6	14.8	16.2	19.9	21.7	23.5	26.4	27.5	28.7	30.2	30.1	29.7	30.8	30.6	31.6	31.6	31.4	32.0	32.0	32.5	33.4	30.7	28.9	26.3	22.6	43.7		
9.0	Turbine ON - background adj (dBA)	10.6	15.3	18.5	22.2	26.0	31.8	32.9	35.7	38.7	40.3	41.6	42.8	42.7	41.5	41.6	42.0	41.5	41.6	41.4	41.1	40.8	41.6	40.4	38.0	35.5	31.9	27.2	[22.5]	53.6	
	Signal to noise (dB)	4.1	5.4	6.1	8.1	10.2	12.2	11.5	12.4	12.5	13.0	13.1	12.8	12.9	12.1	11.1	11.8	10.3	10.4	10.4	9.6	9.3	9.5	8.5	5.9	6.0	4.8	3.5	2.9	10.3	
	Uncertainty (dB)	2.1	1.6	1.1	1.0	0.9	0.8	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	1.2	1.2	1.5	2.2	3.6	0.8	
	PWL (dBA)	61.2	65.9	69.1	72.8	76.6	82.4	83.6	86.3	89.3	91.0	92.2	93.4	93.4	92.1	92.2	92.7	92.2	92.3	92.0	91.7	91.4	92.3	91.0	88.6	86.2	82.5	77.9	[73.1]	104.2	
	Turbine ON (dBA)	12.2	16.3	19.4	22.7	26.4	31.8	33.2	36.0	39.0	40.5	41.8	43.0	42.8	41.5	42.0	42.3	42.2	42.2	41.9	41.6	41.4	42.1	40.9	38.9	36.2	32.8	28.5	24.2	54.0	
9.5	Background (dBA)	6.7	9.1	12.4	12.8	14.7	18.7	21.0	22.9	25.9	27.0	28.2	29.5	29.6	29.1	30.4	30.4	31.5	31.6	31.3	31.7	31.8	32.7	32.7	33.5	30.8	29.0	26.3	22.7	43.5	
	Turbine ON - background adj (dBA)	10.7	15.4	18.5	22.2	26.1	31.6	32.9	35.8	38.8	40.3	41.6	42.8	42.6	41.3	41.7	42.0	41.8	41.5	41.2	40.9	41.5	40.1	37.5	34.8	30.4	[25.5]	[21.2]	53.6		
	Signal to noise (dB)	5.5	7.2	7.1	9.9	11.6	13.2	12.2	13.1	13.2	13.6	13.6	13.5	13.2	12.4	11.7	11.9	10.7	10.7	10.6	9.9	9.6	9.3	8.2	5.5	5.4	3.7	2.2	1.4	10.4	
	Uncertainty (dB)	1.5	1.2	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.9	1.2	1.2	1.8	2.3	3.3	0.8
	PWL (dBA)	60.9	66.1	69.0	72.5	76.4	82.0	83.0	85.9	89.0	90.6	91.8	93.1	93.1	91.9	92.2	92.6	92.4	92.5	92.1	91.7	91.5	92.4	91.0	88.7	86.2	82.5	77.9	72.9	104.1	
10.0	Turbine ON (dBA)	15.3	19.0	21.6	23.7	26.4	31.4	32.0	34.5	37.6	38.7	40.1	41.5	41.6	40.5	41.5	41.9	42.2	42.3	42.0	41.6	41.2	41.8	40.4	38.6	36.2	33.2	29.5	25.3	53.4	
	Background (dBA)	8.3	11.2	13.4	14.1	17.2	19.0	20.3	22.1	25.6	26.7	27.6	29.0	28.7	28.3	30.4	29.7	31.4	31.2	30.6	30.7	30.3	30.6	30.0	30.7	27.8	25.7	23.2	20.0	42.3	
	Turbine ON - background adj (dBA)	14.3	18.2	20.9	23.2	25.9	31.1	31.7	34.2	37.4	38.4	39.8	41.2	41.4	40.2	41.1	41.6	41.8	42.0	41.7	41.4	40.8	41.7	40.4	38.1	35.6	31.9	27.2	22.3	53.5	
	Signal to noise (dB)	7.0	7.8	8.2	9.6	9.3	12.3	11.7	12.3	12.0	12.0	12.5	12.9	12.1	11.1	12.2	10.8	11.2	11.4	11.4	10.9	10.8	10.8	11.1	10.4	7.9	8.5	7.5	6.3	5.3	11.1
	Uncertainty (dB)	1.4	1.3	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	1.1	1.3	2.2	0.7
10.5	PWL (dBA)	65.0	68.8	71.5	73.8	76.5	81.7	82.4	84.9	88.0	89.0	90.5	91.8	92.0	90.9	91.8	92.2	92.5	92.6	92.3	91.8	91.4	92.0	90.6	88.5	86.2	83.0				

Table C.01 Detailed apparent sound power level data at hub height

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement

Report ID: 14215.01.T05.RP6

Page 2 of 2

Created on: 9/6/2017

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																								Overall					
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
11.0	Turbine ON (dBA)	15.4	19.3	21.3	23.6	26.0	30.9	31.9	33.9	36.9	38.1	39.6	41.2	41.4	40.3	41.8	42.1	42.9	43.0	42.6	42.0	41.3	41.3	39.8	37.8	35.1	31.5	27.2	22.9	53.4	
	Background (dBA)	9.9	12.2	14.7	15.3	17.0	20.0	22.4	24.4	27.8	28.9	29.7	31.1	30.4	29.8	30.4	29.8	31.5	31.5	31.2	31.3	30.6	30.7	29.8	29.6	26.7	24.3	21.5	18.4	42.8	
	Turbine ON - background adj (dBA)	14.0	18.3	20.2	22.9	25.5	30.5	31.3	33.4	36.4	37.5	39.1	40.8	41.0	39.9	41.5	41.8	42.6	42.7	42.3	41.6	40.9	40.9	39.3	37.0	34.4	30.5	25.8	21.0	53.0	
	Signal to noise (dB)	5.5	7.0	6.6	8.2	9.1	10.9	9.5	9.5	9.1	9.1	9.9	10.2	11.0	10.5	11.4	12.3	11.4	11.5	11.4	10.7	10.7	10.6	10.0	8.2	8.4	7.2	5.7	4.5	10.6	
	Uncertainty (dB)	1.6	1.4	1.1	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.9	0.9	1.0	1.1	1.4	2.5	0.8
	PWL (dBA)	64.6	69.0	70.9	73.5	76.1	81.2	82.0	84.1	87.0	88.1	89.7	91.4	91.7	90.5	92.1	92.5	93.2	93.3	92.9	92.3	91.5	91.5	89.9	87.7	85.0	81.2	76.5	71.6	103.6	
11.5	Turbine ON (dBA)	14.7	18.3	20.6	22.8	25.7	30.8	31.7	33.8	36.8	37.9	39.4	41.1	41.4	40.4	41.8	42.2	42.9	43.1	42.7	42.1	41.3	41.3	39.7	37.6	34.9	31.2	26.7	22.2	53.4	
	Background (dBA)	8.3	10.5	12.9	14.3	16.2	20.3	22.3	24.6	27.7	29.1	29.8	31.3	30.4	29.7	30.8	29.7	31.2	31.1	30.6	30.7	30.2	30.5	29.8	29.8	26.9	24.8	22.2	19.2	42.7	
	Turbine ON - background adj (dBA)	13.6	17.5	19.8	22.2	25.2	30.4	31.2	33.3	36.2	37.3	38.9	40.6	41.0	40.0	41.5	41.9	42.6	42.8	42.4	41.8	41.0	40.9	39.2	36.8	34.1	30.1	24.7	19.2	53.0	
	Signal to noise (dB)	6.4	7.8	7.7	8.6	9.5	10.5	9.4	9.2	9.0	8.8	9.6	9.8	11.0	10.7	11.0	12.4	11.8	12.0	12.1	11.4	11.2	10.8	9.9	7.8	7.9	6.4	4.5	3.0	10.7	
	Uncertainty (dB)	1.5	1.3	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.9	0.9	1.0	1.0	1.2	1.7	3.4	0.8
	PWL (dBA)	64.2	68.2	70.5	72.8	75.8	81.0	81.8	83.9	86.8	87.9	89.5	91.3	91.7	90.7	92.1	92.6	93.3	93.4	93.1	92.4	91.6	91.6	89.8	87.4	84.7	80.7	75.4	69.9	103.6	

Table C.02 Detailed apparent sound power level data at 10m height

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement

Report ID: 14215.01.T05.RP6

Page 1 of 1

Created on: 9/15/2017

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																								Overall					
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
5.0	Turbine ON (dBA)	8.9	13.5	18.0	21.5	25.5	31.9	31.6	34.6	37.3	39.1	40.4	41.5	42.0	41.2	40.7	41.5	40.3	40.5	40.3	40.1	40.0	40.9	39.7	38.3	35.9	33.2	29.8	25.7	52.7	
	Background (dBA)	5.6	8.7	11.1	12.0	13.5	18.0	20.2	21.7	24.6	26.1	27.2	28.7	29.3	28.9	29.9	30.3	30.9	31.0	30.5	30.5	30.4	31.3	31.2	32.8	29.6	27.7	25.1	21.7	42.6	
	Turbine ON - background adj (dBA)	6.2	11.8	17.0	21.0	25.2	31.7	31.3	34.4	37.0	38.9	40.2	41.2	41.8	40.9	40.3	41.2	39.8	40.0	39.8	39.6	39.4	40.4	39.0	36.9	34.7	31.7	28.0	23.5	52.3	
	Signal to noise (dB)	3.3	4.8	6.9	9.6	12.0	13.9	11.4	12.9	12.7	13.0	13.2	12.7	12.7	12.3	10.7	11.2	9.4	9.5	9.8	9.7	9.6	9.6	8.5	5.5	6.3	5.5	4.7	4.0	10.1	
	Uncertainty (dB)	2.9	2.2	1.4	1.3	1.2	1.2	1.2	1.2	1.2	1.2	1.0	1.0	1.0	1.0	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.2
6.0	PWL (dBA)	56.8	62.4	67.7	71.7	75.9	82.3	81.9	85.0	87.7	89.5	90.8	91.9	92.4	91.5	90.9	91.8	90.4	90.6	90.5	90.3	90.1	91.1	89.7	87.5	85.3	82.4	78.6	74.2	102.9	
	Turbine ON (dBA)	12.1	16.3	19.4	22.7	26.3	31.9	33.1	35.9	38.9	40.5	41.7	42.9	42.9	41.7	41.9	42.3	42.0	42.1	41.8	41.5	41.3	42.0	40.8	39.0	36.4	33.1	29.1	24.8	53.9	
	Background (dBA)	7.6	10.3	12.8	13.7	16.3	19.7	21.4	23.2	26.3	27.4	28.7	29.9	29.7	29.1	30.4	30.3	31.3	31.3	31.0	31.4	31.4	32.1	31.9	32.7	30.1	28.2	25.6	22.0	43.3	
	Turbine ON - background adj (dBA)	10.2	15.0	18.4	22.1	25.9	31.7	32.8	35.6	38.6	40.2	41.5	42.7	42.7	41.4	41.6	42.0	41.6	41.7	41.4	41.1	40.8	41.6	40.2	37.8	35.2	31.4	26.5	[21.8]	53.5	
	Signal to noise (dB)	4.5	6.0	6.6	9.0	10.0	12.3	11.7	12.7	12.6	13.1	13.1	13.2	12.6	11.5	12.0	10.7	10.7	10.8	10.1	9.8	9.9	8.9	6.3	6.3	4.9	3.5	2.7	10.7		
7.0	Uncertainty (dB)	1.7	1.4	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	1.1	1.1	1.3	3.3	0.8
	PWL (dBA)	60.9	65.6	69.0	72.7	76.5	82.3	83.4	86.3	89.3	90.9	92.2	93.4	93.3	92.1	92.3	92.7	92.2	92.3	92.0	91.7	91.4	92.2	90.9	88.5	85.9	82.0	77.2	[72.4]	104.2	
	Turbine ON (dBA)	14.6	18.3	20.8	23.1	26.2	31.3	32.2	34.8	37.8	39.0	40.4	41.8	41.9	40.8	41.7	42.1	42.4	42.5	42.1	41.7	41.2	41.8	40.5	38.6	36.1	32.9	28.9	24.7	53.5	
	Background (dBA)	7.9	10.5	12.9	13.9	15.9	19.9	21.3	23.0	26.5	27.5	28.5	29.9	29.5	28.9	30.4	29.8	31.4	31.2	30.8	31.0	30.5	30.8	30.1	30.7	27.5	25.4	23.0	19.8	42.5	
	Turbine ON - background adj (dBA)	13.5	17.6	20.0	22.6	25.7	31.0	31.8	34.5	37.4	38.7	40.1	41.5	41.7	40.5	41.4	41.8	42.1	42.2	41.8	41.3	40.9	41.5	40.0	37.8	35.4	32.0	27.7	23.0	53.2	
8.0	Signal to noise (dB)	6.7	7.9	7.8	9.2	10.3	11.4	10.9	11.9	11.3	11.5	11.9	11.9	12.4	11.9	11.4	12.3	11.0	11.3	11.4	10.7	10.7	11.0	10.4	7.9	8.6	7.5	6.0	4.9	11.0	
	Uncertainty (dB)	1.4	1.2	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	1.0	1.2	2.3	0.8	
	PWL (dBA)	64.2	68.2	70.6	73.2	76.4	81.6	82.5	85.2	88.1	89.3	90.8	92.1	92.3	91.2	92.0	92.5	92.7	92.8	92.4	91.9	91.5	92.1	90.7	88.4	86.1	82.6	78.3	73.7	103.8	
	Turbine ON (dBA)	15.0	18.7	20.8	23.1	25.8	30.8	31.8	33.7	36.7	37.9	39.3	41.0	41.3	40.3	41.8	42.1	42.9	43.1	42.8	42.1	41.4	41.3	39.7	37.7	35.0	31.4	27.0	22.7	53.3	
	Background (dBA)	8.8	11.0	13.4	14.6	16.7	20.2	22.6	24.4	27.7	28.9	29.7	31.2	30.4	29.7	30.8	29.8	31.3	31.3	30.9	31.1	30.5	30.8	30.1	30.0	27.1	24.9	22.2	19.1	42.8	
9.0	Turbine ON - background adj (dBA)	13.8	17.9	20.0	22.4	25.2	30.4	31.2	33.2	36.1	37.3	38.7	40.5	40.9	39.9	41.4	41.9	42.6	42.8	42.5	41.8	41.0	40.9	39.2	36.8	34.2	30.2	25.3	20.2	52.9	
	Signal to noise (dB)	6.2	7.7	7.5	8.5	9.1	10.5	9.2	9.3	9.0	8.9	9.5	9.8	10.9	10.6	11.0	12.4	11.6	11.8	11.9	11.1	10.9	10.5	9.6	7.7	7.9	6.4	4.8	3.6	10.5	
	Uncertainty (dB)	1.4	1.2	1.0	0.9	0.9	0.8	0.9	0.9	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	1.0	1.1	1.4	2.8	0.8
	PWL (dBA)	64.4	68.5	70.6	73.1	75.9	81.0	81.9	83.8	86.8	87.9	89.4	91.1	91.6	90.5	92.1	92.5	93.3	93.4	93.1	92.4	91.6	91.6	89.9	87.5	84.8	80.9	75.9	70.8	103.6	
	Turbine ON (dBA)	15.0	19.0	21.2	23.1	25.8	30.8	31.8	33.2	36.1	37.1	38.4	40.1	40.9	40.1	41.6	42.2	43.0	43.3	43.1	42.5	41.6	41.4	39.7	37.5	34.7	31.1	26.7	22.3	53.3	
9.0	Background (dBA)	8.9	11.3	14.1	15.2	16.9	20.4	22.5	24.6	27.9	28.9	30.1	31.4	30.7	30.0	31.4	30.2	31.9	31.7	31.1	31.4	31.0	31.3	30.8	30.5	28.2	26.1	23.4	20.2	43.3	
	Turbine ON - background adj (dBA)	13.7	18.1	20.3	22.3	25.2	30.4	31.3	32.6	35.3	36.4	37.7	39.5	40.5	39.7	41.2	41.9	42.7	43.0	42.8	42.1	41.2	41.0	39.1	36.6	33.7	29.4	23.9	[19.3]	52.8	
	Signal to noise (dB)	6.1	7.7	7.1	7.8	8.9	10.4	9.3	8.6	8.1	8.2	8.3	8.7	10.3	10.2	10.2	12.0	11.1	11.6	12.0	11.0	10.6	10.1	8.9	7.0	6.6	4.9	3.2	2.1	10.0	
	Uncertainty (dB)	1.8	1.5	1.3	1.2	1.1	1.0	1.1	1.1	1.1	1.0	0.9	0.9	0.8	0.9	0.9	0.8	0.9	0.9	0.9	0.9	1.0	1.1	1.2	1.3	1.6	2.5	4.0	0.9		
	PWL (dBA)	64.4	68.8	70.9	72.9	75.8	81.0	81.9	83.2	86.0	87.1	88.3	90.1	91.1	90.4	91.9	92.6	93.3	93.7	93.5	92.7	91.8	91.6	89.8	87.2	84.3	80.0	74.5	[69.9]	103.5	

Overall Equipment Uncertainties		
	Typical values	Used values
Calibration	0.2 dB	0.2 dB
Board	0.3 dB	0.3 dB
Distance	0.1 dB	0.1 dB
Air absorption	0 dB	0 dB
Weather	0.5 dB	0.5 dB

1/3 Octave Band Uncertainties		
Frequency (Hz)	Microphone Uncertainty	Overall (including overall equipment Uncertainties)
20	0.8 dB	1 dB
25	0.8 dB	1 dB
31.5	0.5 dB	0.8 dB
40	0.5 dB	0.8 dB
50	0.5 dB	0.8 dB
63	0.5 dB	0.8 dB
80	0.5 dB	0.8 dB
100	0.5 dB	0.8 dB
125	0.5 dB	0.8 dB
160	0.5 dB	0.8 dB
200	0.3 dB	0.7 dB
250	0.3 dB	0.7 dB
315	0.3 dB	0.7 dB
400	0.3 dB	0.7 dB
500	0.3 dB	0.7 dB
630	0.3 dB	0.7 dB
800	0.3 dB	0.7 dB
1000	0.3 dB	0.7 dB
1250	0.3 dB	0.7 dB
1600	0.3 dB	0.7 dB
2000	0.3 dB	0.7 dB
2500	0.5 dB	0.8 dB
3150	0.5 dB	0.8 dB
4000	0.5 dB	0.8 dB
5000	0.5 dB	0.8 dB
6300	0.5 dB	0.8 dB
8000	0.5 dB	0.8 dB
10000	1.3 dB	1.4 dB

Table C.04 Detailed measurement uncertainty at hub height

Project: Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement

Report ID: 14215.01.T05.RP6

Page 1 of 2

Created on: 9/6/2017

Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																								Overall					
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
7.0	Turbine ON	7.02	18	Average (dBA)	9.1	13.5	17.6	21.0	24.9	31.7	31.2	34.4	36.9	38.7	39.7	40.6	40.8	39.7	39.3	40.0	38.9	39.1	39.2	39.1	39.0	39.5	38.8	37.7	35.3	32.6	29.2	25.2	51.7	
				Uncertainty A (dB)	0.4	0.3	0.3	0.3	0.2	0.2	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.4	0.6	0.8	1.0	1.0	1.0	
	Background	7.08	13	Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4		
				Combined Uncertainty (dB)	1.1	1.1	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	1.0	1.1	1.3	1.8		
7.5	Turbine ON	7.53	52	Average (dBA)	9.6	14.1	18.3	21.8	25.7	31.9	31.9	34.9	37.6	39.4	40.7	41.8	42.3	41.4	41.0	41.8	40.7	40.9	40.7	40.5	40.4	41.3	40.0	38.6	36.1	33.3	29.8	25.7	53.1	
				Uncertainty A (dB)	0.3	0.3	0.2	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.4	0.6	0.6			
	Background	7.47	14	Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4			
				Combined Uncertainty (dB)	1.1	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	1.0	1.1	1.6	1.8		
8.0	Turbine ON	7.99	132	Average (dBA)	10.7	15.2	19.0	22.4	26.2	31.9	32.7	35.6	38.5	40.2	41.5	42.8	42.9	41.9	41.9	42.4	42.4	41.7	41.8	41.5	41.3	41.0	41.9	40.6	38.9	36.2	33.1	29.2	25.0	53.8
				Uncertainty A (dB)	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.4	0.5	0.5	
	Background	7.96	30	Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4			
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.9			
8.5	Turbine ON	8.51	153	Average (dBA)	12.8	16.8	19.7	22.9	26.4	32.1	33.3	35.9	38.9	40.5	41.8	43.0	43.0	41.8	41.9	42.3	42.0	42.1	41.8	41.6	41.3	42.2	41.0	39.3	36.8	33.6	29.8	25.5	54.0	
				Uncertainty A (dB)	0.3	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.5	0.5		
	Background	8.51	23	Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4			
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.9			
9.0	Turbine ON	8.99	179	Average (dBA)	12.2	16.2	19.4	22.7	26.4	31.8	33.2	36.0	39.1	40.5	41.8	43.0	42.8	42.1	41.5	42.0	42.3	42.2	41.9	41.7	41.4	42.1	40.9	38.9	36.3	32.8	28.5	24.2	54.0	
				Uncertainty A (dB)	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.4	0.5	0.5			
	Background	9.05	24	Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.9			
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.9			
9.5	Turbine ON	9.48	100	Average (dBA)	12.4	16.6	19.4	22.6	26.2	31.8	32.8	35.6	38.7	40.3	41.5	42.8	42.7	41.6	41.9	42.3	42.1	42.2	41.8	41.5	41.2	42.1	40.8	38.8	36.2	32.7	28.5	24.1	53.9	
				Uncertainty A (dB)	0.3	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.5	0.6				
	Background	9.50	21	Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.4			
				Combined Uncertainty (dB)	1.1	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	1.7			

Table C.03 Detailed measurement uncertainty at hub height

Project: Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement

Report ID: 14215.01.T05.RP6


Page 2 of 2

Created on: 9/6/2017

Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																								Overall				
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	
10.0	Turbine ON	9.97	133	Average (dBA)	15.4	19.0	21.7	23.7	26.5	31.4	32.0	34.5	37.7	38.7	40.1	41.5	41.6	40.5	41.4	41.8	42.2	42.3	41.9	41.5	41.2	41.8	40.4	38.7	36.3	33.3	29.6	25.5	53.4
				Uncertainty A (dB)	0.4	0.4	0.3	0.3	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.4	0.6	0.7	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	1.4		
	Background	10.01	17	Combined Uncertainty (dB)	1.1	1.1	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	1.0	1.6
10.5	Turbine ON	10.46	121	Average (dBA)	14.8	18.4	20.4	22.7	25.7	30.8	31.9	34.5	37.0	38.3	39.9	41.3	41.7	40.6	41.9	42.3	42.9	43.0	42.5	41.9	41.3	41.7	40.2	38.2	35.6	32.3	28.2	24.0	53.5
				Uncertainty A (dB)	0.4	0.3	0.3	0.2	0.1	0.1	0.1	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.4	0.6	0.7	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	1.4		
	Background	10.46	23	Combined Uncertainty (dB)	1.1	1.1	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	1.0	1.6
11.0	Turbine ON	10.99	111	Average (dBA)	15.4	19.3	21.3	23.6	26.1	30.9	31.9	33.9	36.9	38.1	39.5	41.2	41.4	40.3	41.8	42.1	42.9	43.0	42.6	42.0	41.3	41.3	39.7	37.7	35.1	31.4	27.1	22.9	53.4
				Uncertainty A (dB)	0.4	0.3	0.3	0.3	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.5	0.6		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	1.4		
	Background	11.02	15	Combined Uncertainty (dB)	1.1	1.1	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	1.7		
11.5	Turbine ON	11.46	108	Average (dBA)	14.7	18.3	20.6	22.8	25.7	30.8	31.7	33.8	36.8	37.9	39.4	41.1	41.4	40.4	41.8	42.2	42.9	43.1	42.7	42.1	41.3	41.3	39.7	37.6	34.9	31.2	26.6	22.2	53.4
				Uncertainty A (dB)	0.4	0.3	0.3	0.2	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.5	0.6		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	1.4		
	Background	11.52	19	Combined Uncertainty (dB)	1.1	1.1	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	1.5	

Appendix D

Tonality Assessment



14215.01.T05.RP6

Project Name

Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Scale: NTS

Drawn by: AM

Reviewed by: PA


Date: Sept 15, 2017

Revision: 1

Figure Title

Plot of narrow band spectra – Turbine ON vs. Background at 7 m/s

Figure D.01



14215.01.T05.RP6

Scale: NTS
Drawn by: AM
Reviewed by: PA
Date: Sept 15, 2017
Revision: 1


Project Name

Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Figure Title

Plot of narrow band spectra – Turbine ON vs. Background at 7.5 m/s

Figure D.02



14215.01.T05.RP6

Project Name

Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Scale: NTS

Drawn by: AM

Reviewed by: PA


Date: Sept 15, 2017

Revision: 1

Figure Title

Plot of narrow band spectra – Turbine ON vs. Background at 8 m/s

Figure D.03



14215.01.T05.RP6

Project Name

Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Scale: NTS

Drawn by: AM

Reviewed by: PA


Date: Sept 15, 2017

Revision: 1

Figure Title

Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s

Figure D.04



14215.01.T05.RP6

Scale: NTS
Drawn by: AM
Reviewed by: PA
Date: Sept 15, 2017
Revision: 1


Project Name


Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Figure Title

Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s

Figure D.05





14215.01.T05.RP6

Scale: NTS
Drawn by: AM
Reviewed by: PA
Date: Sept 15, 2017
Revision: 1


Project Name

Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Figure Title

Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s

Figure D.07



14215.01.T05.RP6

Project Name

Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Scale: NTS

Drawn by: AM

Reviewed by: PA


Date: Sept 15, 2017

Revision: 1

Figure Title

Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s

Figure D.08




14215.01.T05.RP6

Project Name
Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Figure Title
Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s

Scale: NTS
Drawn by: AM
Reviewed by: PA
Date: Sept 15, 2017
Revision: 1

Figure D.09



14215.01.T05.RP6

Scale: NTS
Drawn by: AM
Reviewed by: PA
Date: Sept 15, 2017
Revision: 1

Project Name

Suncor Adelaide Wind Power Project - Turbine T05 - IEC61400-11 Edition 3.0

Figure Title

Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s

Figure D.10

Appendix E Measurement Data

Table E.01 Measurement data - Turbine ON

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
Report ID: 14215.01.T05.RP6

Page 1 of 9

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	L _{Aeq}	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
1		1578	346.0	2.0	4.8	13.0	9.5	3.0	11.8	98.5	-	
2	8.8	54.6	1857	346.0	356.0	4.8	13.1	9.0	3.8	11.8	98.5	-
3		2246	346.0	354.7	4.8	13.6	9.8	5.6	11.8	98.5	-	
4		2236	346.0	354.6	4.8	13.4	9.1	5.5	11.8	98.5	-	
5	10.6	53.7	2202	346.0	354.6	4.8	12.8	10.8	6.3	11.8	98.5	-
6		2238	346.0	354.6	4.8	12.9	9.2	3.3	11.8	98.5	-	
7	11.7	53.6	2259	346.0	354.6	4.8	13.6	9.8	4.5	11.8	98.5	-
8		2257	346.0	354.6	4.8	13.2	10.2	4.8	11.8	98.5	-	
9	10.2	53.1	2181	346.0	354.6	4.8	12.8	11.2	4.8	11.8	98.5	-
10	10.1	52.9	2177	346.0	354.6	4.8	12.7	10.9	4.1	11.7	98.5	-
11	11.1	53.2	2202	346.0	354.6	4.8	12.8	11.3	5.4	11.7	98.5	-
12	13.6	53.8	2256	346.0	354.6	4.8	13.7	13.8	4.4	11.7	98.5	-
13	11.6	54.8	2256	346.0	356.1	4.8	13.4	11.8	5.8	11.7	98.5	-
14		2241	346.0	354.6	4.8	12.9	10.9	7.6	11.7	98.5	-	
15		2222	346.0	354.6	0.1	1.8	13.0	12.6	7.3	11.7	98.5	-
16		2237	346.0	354.6	0.1	1.8	13.1	12.4	4.3	11.7	98.5	-
17		2258	346.0	0.1	4.8	13.2	13.3	5.2	11.7	98.5	-	
18		2251	346.0	0.1	4.8	13.2	11.4	5.5	11.7	98.5	-	
19		2270	346.0	0.1	4.8	13.2	12.5	6.8	11.7	98.5	-	
20		2180	346.0	0.1	4.8	12.8	12.4	7.8	11.7	98.5	-	
21		2168	346.0	0.1	4.8	12.8	12.5	7.8	11.7	98.5	-	
22	11.5	52.7	2242	346.0	359.0	4.8	13.1	13.1	4.1	11.6	98.5	-
23	11.7	52.6	2219	346.0	359.0	4.8	12.9	11.9	6.8	11.6	98.5	-
24	10.7	52.6	2271	346.0	359.0	4.8	13.1	10.9	4.4	11.6	98.5	-
25	12.1	52.3	2236	346.0	359.0	4.8	13.0	12.3	5.5	11.6	98.5	-
26	9.9	51.9	2153	346.0	354.6	4.8	12.5	12.1	3.3	11.6	98.5	-
27	9.8	52.1	2124	346.0	352.7	4.8	12.5	11.0	3.6	11.6	98.5	-
28	11.6	53.0	2252	346.0	352.7	4.8	13.3	11.8	3.1	11.6	98.5	-
29	12.1	53.7	2228	346.0	352.7	4.8	13.7	12.3	5.6	11.6	98.5	-
30	10.0	53.2	2268	346.0	352.7	4.8	13.3	10.9	5.5	11.6	98.5	-
31	11.0	53.0	2240	346.0	352.7	4.8	13.0	11.2	3.0	11.6	98.5	-
32	11.2	52.2	2190	346.0	352.7	4.8	12.7	11.3	4.5	11.6	98.5	-
33	10.6	52.9	2222	346.0	352.7	4.8	13.0	10.8	5.6	11.6	98.5	-
34	12.6	53.1	2221	346.0	352.7	4.8	13.3	12.7	5.4	11.6	98.5	-
35	11.4	52.7	2267	346.0	352.7	4.8	13.0	11.6	5.2	11.6	98.5	-
36	11.7	52.4	2205	346.0	352.7	4.8	12.7	11.8	3.9	11.6	98.5	-
37	10.3	52.5	2217	346.0	352.7	4.8	12.7	10.5	3.6	11.6	98.5	-
38	11.5	52.2	2218	346.0	352.7	4.8	12.9	11.7	2.9	11.6	98.5	-
39		2231	346.0	352.7	4.8	13.1	9.8	6.6	11.6	98.5	-	
40	9.8	51.8	2136	346.0	352.7	4.8	12.5	10.7	7.4	11.6	98.5	-
41	12.2	53.3	2249	346.0	352.7	4.8	13.2	12.4	4.1	11.6	98.5	-
42	11.6	53.9	2247	346.0	352.7	4.8	13.8	11.8	5.5	11.6	98.5	-
43	12.7	53.5	2287	346.0	352.7	4.8	13.4	12.9	5.9	11.6	98.5	-
44	12.2	53.4	2202	346.0	352.7	4.8	13.1	12.4	6.7	11.6	98.5	-
45	10.1	52.7	2179	346.0	352.7	4.8	12.7	11.8	6.4	11.6	98.5	-
46	11.2	51.9	2198	346.0	352.7	4.8	12.8	11.3	7.2	11.6	98.5	-
47	11.2	52.4	2251	346.0	352.7	4.8	13.0	11.3	5.4	11.6	98.5	-
48	11.2	53.2	2246	346.0	354.1	4.8	13.1	11.3	5.4	11.6	98.5	-
49	11.5	52.6	2195	346.0	354.1	4.8	12.6	11.7	5.4	11.6	98.5	-
50	11.8	52.6	2212	346.0	354.1	4.8	13.0	12.0	5.1	11.6	98.5	-
51	11.4	52.6	2241	346.0	354.1	4.8	13.2	11.6	5.1	11.6	98.5	-
52	11.7	52.5	2212	346.0	354.1	4.8	12.9	11.9	5.6	11.6	98.5	-
53	11.7	52.7	2227	346.0	354.1	4.8	12.9	11.8	4.9	11.6	98.5	-
54		2237	346.0	354.1	4.8	12.9	10.2	4.7	11.6	98.5	-	
55	9.9	52.4	2154	346.0	354.1	4.8	12.4	10.1	3.9	11.6	98.5	-
56	11.9	52.4	2256	346.0	354.1	4.8	13.2	12.0	5.0	11.6	98.5	-
57	11.0	53.4	2229	346.0	354.1	4.8	13.6	11.2	6.4	11.6	98.5	-
58	12.3	53.4	2227	346.0	354.1	4.8	13.6	12.4	7.0	11.6	98.5	-
59	13.3	53.5	2267	346.0	354.1	4.8	13.5	12.5	5.3	11.6	98.5	-
60	11.9	53.0	2271	346.0	354.1	4.8	13.1	12.0	2.3	11.6	98.5	-
61	13.1	53.6	2244	346.0	354.1	4.8	13.3	13.3	6.5	11.6	98.5	-
62	12.9	53.4	2225	346.0	354.1	4.8	13.1	9.7	11.6	98.5	-	
63	12.2	52.8	2192	346.0	354.1	4.8	12.8	12.4	8.4	11.6	98.5	-
64	9.9	53.7	2139	346.0	354.1	4.8	12.4	10.4	6.8	11.6	98.5	-
65	12.2	52.8	2244	346.0	354.1	4.8	13.1	12.3	4.4	11.6	98.5	-
66	11.6	53.0	2215	346.0	354.1	4.8	12.7	11.8	4.9	11.6	98.5	-
67		2200	346.0	354.1	4.8	13.6	10.3	5.7	11.6	98.5	-	
68	10.1	54.1	2174	346.0	359.1	4.8	12.5	11.3	8.3	11.6	98.5	-
69	9.9	53.1	2142	346.0	359.0	4.8	12.5	9.9	5.8	11.6	98.5	-
70	9.5	53.1	2054	346.0	356.3	4.8	12.8	8.9	5.5	11.6	98.5	-
71	13.1	53.6	2228	346.0	354.5	4.8	13.7	13.3	4.4	11.6	98.5	-
72	12.0	53.6	2259	346.0	354.5	4.8	13.4	12.2	6.6	11.6	98.5	-
73	10.9	52.8	2225	346.0	357.4	4.8	13.0	11.1	4.5	11.6	98.5	-
74		2164	346.0	357.4	4.8	12.5	10.6	5.4	11.6	98.5	-	
75		2198	346.0	357.4	4.8	12.8	9.5	7.0	11.6	98.5	-	
76		2177	346.0	357.4	4.8	12.7	9.3	5.9	11.6	98.5	-	
77		1961	346.0	357.4	4.8	12.9	9.3	4.2	11.6	98.5	-	
78		1926	346.0	357.4	4.8	12.9	10.9	3.6	11.6	98.5	-	
79		1825	346.0	357.4	4.8	12.9	12.2	4.2	11.6	98.5	-	
80		1709	346.0	357.4	4.8	12.9	8.6	8.6	11.6	98.5	-	
81		1640	346.0	357.4	4.8	12.5	6.5	3.4	11.6	98.5	-	
82	8.2	53.7	1659	346.0	357.7	4.8	13.0	8.0	5.4	11.6	98.5	-
83	7.8	53.2	1375	346.0	357.7	4.8	12.8	9.1	5.5	11.6	98.5	-
84	9.6	53.8	2083	346.0	357.7	4.8	13.2	9.6	5.6	11.6	98.5	-
85	9.9	54.1	2143	346.0	357.7	4.8	13.1	9.6	7.2	11.6	98.5	-
86	9.0	54.6	1947	346.0	357.7	4.8	13.0	10.5	5.3	11.6	98.5	-
87		2240	346.0	357.7	4.8	13.0	9.6	5.0	11.6	98.5	-	
88		2240	346.0	357.7	4.8	13.9	10.1	7.0	11.5	98.5	-	

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	L _{Aeq}	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
89	10.5	53.5	2224	346.0	346.0	4.8	13.5	10.7	6.8	11.5	98.5	-
90	11.3	52.9	2278	346.0	346.0	4.8	12.9	11.5	5.7	11.5	98.5	-
91	12.3	53.4										

Table E.01 Measurement data - Turbine ON

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
 Report ID: 14215.01.T05.RP6

Page 2 of 9

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)	
177	9.4	54.0	2034	346.0	349.2	4.8	13.1	10.1	2.9	11.1	98.5	-	
178	9.0	53.9	1931	346.0	349.2	4.8	12.9	10.0	2.8	11.1	98.5	-	
179	8.9	53.8	1909	346.0	349.2	4.8	13.0	9.2	3.3	11.1	98.5	-	
180	8.9	53.7	1886	346.0	349.2	4.8	13.0	10.0	4.7	11.1	98.5	-	
181	8.7	53.7	1804	346.0	349.2	4.8	13.0	9.2	3.8	11.1	98.5	-	
182	9.3	53.6	2007	346.0	349.2	4.8	13.1	8.8	3.3	11.1	98.5	-	
183	8.9	53.7	1926	346.0	349.2	4.8	13.0	9.4	1.1	11.1	98.5	-	
184	9.4	53.7	20444	346.0	349.2	4.8	13.1	6.6	2.6	11.1	98.5	-	
185	9.5	54.1	2061	346.0	349.2	4.8	13.0	11.4	4.6	11.1	98.5	-	
186	10.0	54.1	2167	346.0	349.2	4.8	13.0	10.9	2.3	11.1	98.5	-	
187	9.3	53.6	2024	346.0	349.2	4.8	13.0	9.5	3.8	11.1	98.5	-	
188	9.2	53.9	1995	346.0	349.2	4.8	13.0	9.0	5.2	11.1	98.5	-	
189	9.0	53.7	1936	346.0	349.2	4.8	13.0	10.2	4.7	11.1	98.5	-	
190	5.6	53.6	1862	346.0	349.2	4.8	12.9	7.7	3.4	11.1	98.5	-	
191	8.1	53.5	1963	346.0	349.2	4.8	13.0	8.4	5.1	11.1	98.5	-	
192	8.5	53.8	1700	346.0	349.2	4.8	12.9	8.8	5.7	11.1	98.5	-	
193	8.0	53.0	1480	346.0	349.2	4.8	12.9	9.4	3.4	11.1	98.5	-	
194	7.9	53.4	1416	346.0	353.6	4.8	12.9	7.1	3.8	11.1	98.5	-	
195	7.7	53.2	1326	346.0	353.9	4.8	12.6	7.5	5.2	11.1	98.5	-	
196	7.5	52.4	1230	346.0	353.9	4.8	12.3	6.7	5.7	11.1	98.5	-	
197	8.6	52.7	1741	346.0	353.9	4.8	13.2	9.0	4.9	11.1	98.5	-	
198	8.7	53.3	1804	346.0	353.9	4.8	13.0	9.5	4.4	11.1	98.5	-	
199	8.4	53.6	1644	346.0	361.5	4.8	13.0	7.6	2.3	11.1	98.5	-	
200	8.4	53.7	1685	346.0	361.5	4.8	12.9	8.2	4.2	11.1	98.5	-	
201	7.8	53.0	1376	346.0	361.5	4.8	12.8	6.3	4.8	11.1	98.5	-	
202	7.6	52.8	1256	346.0	361.5	4.8	12.3	6.3	3.0	11.1	98.5	-	
203	7.1	51.7	1055	346.0	361.5	4.8	11.6	6.7	5.3	11.1	98.5	-	
204	6.9	50.5	935	346.0	361.5	4.8	11.1	4.1	3.2	11.1	98.5	-	
205	6.5	49.6	810	346.0	361.5	4.8	10.6	5.5	2.7	11.1	98.5	-	
206	5.6	48.5	738	346.0	361.5	4.8	10.0	4.8	3.4	11.1	98.5	-	
207	6.6	49.2	828	346.0	347.8	4.8	10.7	6.6	2.7	11.1	98.5	-	
208	6.9	49.9	969	346.0	347.8	4.8	11.3	6.9	4.0	11.0	98.5	-	
209	7.7	51.7	1306	346.0	348.8	4.8	12.6	8.7	4.2	11.0	98.5	-	
210	8.2	53.8	1563	346.0	350.3	4.8	13.0	9.0	4.3	11.0	98.5	-	
211	8.2	53.7	1583	346.0	360.2	4.8	13.0	5.6	3.5	11.0	98.5	-	
212	7.8	53.6	1391	346.0	360.2	4.8	12.8	7.0	3.2	11.0	98.5	-	
213	5.4	52.7	1170	346.0	361.1	4.8	12.0	4.4	3.2	11.1	98.5	-	
214	7.7	53.3	1309	346.0	345.2	4.8	12.6	8.9	2.5	11.1	98.5	-	
215	8.7	54.0	1800	346.0	345.3	4.8	13.1	7.1	4.0	11.1	98.5	-	
216	8.5	54.1	1705	346.0	350.2	4.8	12.9	9.0	3.6	11.1	98.5	-	
217	8.4	53.5	1643	346.0	351.6	4.8	13.0	6.7	3.3	11.1	98.5	-	
218	8.5	53.7	1702	346.0	351.6	4.8	13.0	7.6	4.0	11.1	98.5	-	
219	8.3	54.0	1639	346.0	351.6	4.8	13.0	7.6	3.9	11.1	98.5	-	
220	8.4	54.2	1652	346.0	361.5	4.8	13.1	6.0	2.4	11.1	98.5	-	
221	8.9	54.3	1887	346.0	361.5	4.8	13.1	6.7	3.4	11.1	98.5	-	
222	7.8	54.1	1381	346.0	361.5	4.8	12.8	6.5	2.2	11.1	98.5	-	
223	7.8	53.6	1367	346.0	361.5	4.8	12.7	6.7	3.0	11.1	98.5	-	
224	7.4	52.6	1182	346.0	361.5	4.8	12.0	7.3	4.5	11.1	98.5	-	
225	7.0	51.2	999	346.0	361.5	4.8	11.4	5.2	4.0	11.1	98.5	-	
226	7.2	51.1	1084	346.0	361.5	4.8	11.7	8.2	3.9	11.1	98.5	-	
227	7.5	51.9	1234	346.0	363.5	4.8	12.5	5.4	3.8	11.1	98.5	-	
228	7.8	52.9	1309	346.0	364.2	4.8	12.8	8.2	2.6	11.1	98.5	-	
229	7.9	53.5	1439	346.0	360.0	4.8	13.0	8.1	2.4	11.1	98.5	-	
230	7.8	53.5	1563	346.0	365.7	4.8	12.7	5.8	3.3	11.1	98.5	-	
231	7.9	53.2	1403	346.0	365.7	4.8	12.9	9.4	1.8	11.1	98.5	-	
232	8.0	53.5	1491	346.0	365.8	4.8	13.0	8.2	2.2	11.1	98.5	-	
233	7.7	53.5	1303	346.0	362.0	4.8	12.4	7.7	3.2	11.2	98.5	-	
234	4.4	51.0	1440	346.0	364.8	4.8	12.0	5.2	3.5	11.2	98.5	-	
235	7.6	51.2	1267	346.0	365.9	4.8	12.4	5.2	3.3	11.4	98.5	-	
236	9.2	52.9	2001	346.0	365.9	4.8	12.2	7.4	2.8	11.4	98.5	-	
237	8.9	53.8	1906	346.0	349.7	4.0	13.0	9.3	3.0	11.4	98.5	-	
238	8.0	54.3	1473	346.0	349.4	4.0	12.9	8.5	6.5	11.4	98.5	-	
239	7.7	54.6	1322	346.0	349.4	4.0	12.6	6.1	3.2	11.4	98.5	-	
240	7.8	55.0	1382	346.0	349.4	4.0	12.8	5.5	5.5	11.4	98.5	-	
241	8.4	54.1	1654	346.0	349.4	4.0	13.1	9.1	4.3	11.4	98.5	-	
242	8.5	54.3	1710	346.0	349.4	4.0	13.0	6.8	7.0	11.4	98.5	-	
243	9.8	54.5	1653	346.0	364.0	4.0	13.0	6.2	5.2	11.4	98.5	-	
244	9.4	54.0	2048	346.0	349.4	4.0	13.1	11.2	3.5	11.4	98.5	-	
245	9.9	53.9	2150	346.0	349.4	4.0	13.0	9.2	3.7	11.4	98.5	-	
246	10.6	54.5	2249	346.0	349.4	4.0	13.1	10.8	7.2	11.4	98.5	-	
247	9.0	54.3	1934	346.0	349.4	4.0	12.9	10.6	7.4	11.4	98.5	-	
248	9.7	54.5	2099	346.0	349.4	4.0	13.0	8.1	4.5	11.4	98.5	-	
249	9.1	54.3	1970	346.0	349.4	4.0	12.9	8.8	4.5	11.4	98.5	-	
250	9.8	54.5	2103	346.0	349.4	4.0	13.0	8.7	4.3	11.4	98.5	-	
251	9.6	54.6	2087	346.0	349.4	4.0	13.1	8.6	3.2	11.5	98.5	-	
252	9.2	53.7	1985	346.0	349.4	4.0	13.0	10.6	2.9	11.5	98.5	-	
253	9.0	53.8	1928	346.0	349.4	4.0	12.9	8.1	5.5	11.5	98.5	-	
254	9.4	54.0	2035	346.0	349.4	4.0	13.0	6.8	6.0	11.5	98.5	-	
255	8.8	53.7	1867	346.0	349.4	4.0	12.9	9.9	4.0	11.5	98.5	-	
256	8.8	53.9	1845	346.0	349.4	4.0	12.9	8.3	3.7	11.5	98.5	-	
257	7.9	53.3	1410	346.0	362.8	4.0	12.8	9.5	1.9	11.5	98.5	-	
258	7.7	53.3	1311	346.0	363.0	4.0	12.6	7.3	4.6	11.5	98.5	-	
259	11.2	54.0	1026	346.0	364.0	4.0	12.7	11.8	5.8	4.7	11.5	98.5	-
260	10.5	53.5	1035	346.0	364.0	4.0	12.5	7.5	4.5	11.5	98.5	-	
261	12.9	54.0	1329	346.0	364.0	4.0	12.7	9.1	5.8	11.5	98.5	-	
262	8.3	53.9	1599	346.0	364.8	4.0	13.0	6.7	5.9	11.5	98.5	-	
263	7.9	54.2	1434	346.0	362.1	4.0	12.9	9.5	4.9	11.6	98.5	-	
264	8.7	54.3	1820	346.0	362.1	4.0	13.1	9.6	4.1	11.6	98.5	-	

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
265	8.5	54.2	1722									

Table E.01 Measurement data - Turbine ON

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
Report ID: 14215.01.T05.RP6

Page 3 of 9

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	L _{Aeq}	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
353	2241	346.0	347.8	40.0	13.6	10.2	4.2	11.5	98.6	-	-	-
354	11.9	54.6	2256	346.0	347.8	40.0	13.3	12.1	3.0	11.5	98.6	-
355	12.9	54.2	2234	346.0	347.8	40.0	13.5	13.1	4.5	11.5	98.6	-
356	11.9	54.0	2206	346.0	347.9	40.0	13.1	12.0	1.3	11.5	98.6	-
357	12.1	54.1	2231	346.0	350.1	40.0	13.0	12.2	6.6	11.5	98.6	-
358	11.3	53.2	2236	346.0	350.0	40.0	12.9	11.5	5.6	11.5	98.6	-
359	12.2	53.5	2300	346.0	350.1	40.0	12.9	12.3	5.3	11.5	98.6	-
360	10.0	54.5	2162	346.0	350.1	40.0	12.8	10.8	8.0	11.5	98.6	-
361	9.9	52.5	2150	346.0	351.2	40.0	12.5	12.0	6.2	11.5	98.6	-
362	10.1	53.1	2175	346.0	354.3	40.0	12.8	12.2	6.3	11.5	98.6	-
363	9.9	53.4	2143	346.0	354.3	40.0	12.5	9.1	5.7	11.5	98.6	-
364	10.0	54.1	2165	346.0	354.3	40.0	12.6	10.2	4.8	11.5	98.6	-
365	12.7	54.4	2230	346.0	354.3	40.0	13.8	12.9	7.7	11.5	98.5	-
366	11.7	53.9	2284	346.0	354.2	40.0	13.8	13.8	6.3	11.5	98.5	-
367	12.6	54.5	2249	346.0	354.2	40.0	13.2	12.8	6.4	11.5	98.5	-
368	12.1	53.8	2196	346.0	354.2	40.0	12.8	12.3	6.5	11.5	98.5	-
369	9.8	52.8	2120	346.0	354.3	40.0	12.3	10.5	7.9	11.5	98.5	-
370	10.8	53.5	2196	346.0	354.3	40.0	12.8	10.9	6.3	11.5	98.5	-
371	10.8	53.8	2243	346.0	354.3	40.0	13.0	11.0	5.0	11.5	98.6	-
372	10.3	54.8	2270	346.0	354.3	40.0	13.3	10.4	7.5	11.5	98.6	-
373	2257	346.0	354.3	40.0	13.4	9.4	11.5	9.9	-	-	-	-
374	10.6	55.2	2165	346.0	354.3	40.0	12.7	9.7	4.8	11.5	98.6	-
375	9.9	53.2	2154	346.0	354.3	40.0	12.6	10.4	4.5	11.5	98.6	-
376	9.5	54.2	2053	346.0	354.3	40.0	12.8	10.5	5.2	11.5	98.6	-
377	9.4	54.9	2041	346.0	354.3	40.0	13.0	9.4	5.9	11.5	98.6	-
378	10.3	56.0	2268	346.0	349.7	40.0	13.2	10.4	6.5	11.5	98.6	-
379	10.7	54.5	2247	346.0	349.7	40.0	13.1	10.9	5.5	11.5	98.6	-
380	9.2	54.6	1994	346.0	349.7	40.0	12.8	8.7	4.1	11.5	98.6	-
381	8.8	54.7	1843	346.0	349.7	40.0	12.9	9.9	3.9	11.5	98.6	-
382	8.6	54.2	1759	346.0	349.7	40.0	13.0	9.5	5.8	11.5	98.6	-
383	8.7	54.4	1787	346.0	349.7	40.0	13.0	8.6	5.1	11.5	98.6	-
384	8.1	54.2	1530	346.0	349.7	40.0	12.9	10.0	4.9	11.5	98.6	-
385	8.0	54.5	1458	346.0	349.7	40.0	13.0	5.9	4.5	11.5	98.6	-
386	7.9	54.5	1403	346.0	353.3	40.0	12.9	7.3	3.9	11.5	98.6	-
387	7.9	54.0	1430	346.0	353.3	40.0	12.9	7.8	3.9	11.5	98.6	-
388	8.2	53.9	1572	346.0	352.6	40.0	13.0	6.5	4.6	11.5	98.6	-
389	8.0	53.9	1485	346.0	352.6	40.0	13.0	5.5	3.1	11.5	98.6	-
390	8.0	53.8	1473	346.0	352.0	40.0	13.0	7.3	4.2	11.6	98.6	-
391	7.8	53.9	1365	346.0	352.0	40.0	12.7	8.4	4.2	11.6	98.6	-
392	7.6	53.6	1259	346.0	352.0	40.0	12.4	10.5	2.9	11.6	98.6	-
393	7.9	53.5	1424	346.0	352.0	40.0	12.9	6.8	4.0	11.6	98.5	-
394	8.9	54.5	1887	346.0	352.0	40.0	13.2	10.5	3.4	11.6	98.5	-
395	8.8	54.4	1877	346.0	352.0	40.0	13.1	8.2	3.2	11.6	98.5	-
396	10.0	54.8	2168	346.0	353.0	40.0	13.1	13.3	8.3	11.6	98.5	-
397	11.1	55.4	2251	346.0	347.1	40.0	13.7	9.5	3.9	11.6	98.5	-
398	10.5	54.6	2265	346.0	347.1	40.0	12.9	10.7	2.4	11.6	98.5	-
399	10.2	54.0	2179	346.0	347.0	40.0	12.7	9.6	3.3	11.6	98.5	-
400	10.0	53.9	2174	346.0	347.0	40.0	12.7	10.3	4.8	11.6	98.5	-
401	8.9	53.3	1891	346.0	353.4	40.0	12.6	10.3	4.0	11.6	98.5	-
402	9.0	54.8	1957	346.0	358.4	40.0	12.9	9.3	4.4	11.6	98.5	-
403	8.8	54.2	1931	346.0	358.4	40.0	12.8	7.6	5.1	11.6	98.5	-
404	7.8	54.4	1351	346.0	363.7	40.0	12.7	5.5	6.4	11.6	98.5	-
405	7.8	54.8	1362	346.0	353.4	40.0	12.7	6.3	3.2	11.6	98.5	-
406	7.5	55.2	1243	346.0	352.4	40.0	12.4	5.2	3.0	11.6	98.5	-
407	8.9	55.2	1907	346.0	346.9	40.0	13.2	8.1	2.6	11.6	98.5	-
408	9.7	54.9	2097	346.0	346.8	40.0	13.2	9.2	3.4	11.6	98.5	-
409	10.6	54.8	2261	346.0	346.8	40.0	13.3	10.8	4.1	11.6	98.5	-
410	10.7	54.7	2282	346.0	346.8	40.0	13.3	10.8	5.4	11.6	98.5	-
411	11.3	54.4	2267	346.0	346.8	40.0	13.0	10.5	4.2	11.6	98.5	-
412	11.3	54.4	2206	346.0	349.3	40.0	12.9	9.3	5.1	11.6	98.5	-
413	11.5	56.0	2192	346.0	349.9	40.0	12.8	11.7	4.9	11.6	98.5	-
414	9.9	54.7	2153	346.0	349.9	40.0	12.9	10.6	5.1	11.6	98.5	-
415	9.5	54.5	2056	346.0	349.9	40.0	13.0	12.2	2.8	11.6	98.5	-
416	9.4	54.4	2038	346.0	350.0	40.0	12.9	8.4	2.8	11.6	98.5	-
417	9.6	54.7	2091	346.0	349.9	40.0	13.1	7.9	2.7	11.6	98.5	-
418	2254	346.0	349.9	40.0	13.0	9.9	4.6	9.6	9.6	11.6	98.5	-
419	10.3	54.6	2029	346.0	349.5	40.0	12.2	4.2	4.0	11.6	98.5	-
420	11.6	54.7	2216	346.0	348.6	40.0	13.3	11.7	6.0	11.5	98.5	-
421	11.6	54.2	2260	346.0	348.6	40.0	13.3	11.8	4.1	11.5	98.6	-
422	11.3	54.8	2225	346.0	348.6	40.0	12.8	11.4	3.4	11.5	98.6	-
423	9.9	54.8	2147	346.0	348.5	40.0	12.5	10.8	4.0	11.5	98.6	-
424	10.4	54.1	2227	346.0	348.5	40.0	12.9	10.6	3.2	11.5	98.6	-
425	10.4	54.0	2210	346.0	348.6	40.0	12.9	10.5	2.9	11.5	98.6	-
426	9.8	54.0	2121	346.0	348.6	40.0	13.0	10.2	5.6	11.5	98.6	-
427	9.3	55.0	2022	346.0	348.6	40.0	13.0	10.5	4.8	11.5	98.6	-
428	8.9	54.5	1886	346.0	348.5	40.0	13.0	7.3	3.2	11.5	98.6	-
429	9.4	54.6	2030	346.0	348.6	40.0	13.1	10.8	3.3	11.5	98.6	-
430	9.0	54.5	1939	346.0	348.6	40.0	13.1	9.1	3.6	11.5	98.6	-
431	9.9	54.5	2140	346.0	348.6	40.0	13.1	9.5	4.5	11.5	98.6	-
432	9.7	54.4	2099	346.0	348.6	40.0	13.0	7.9	2.8	11.5	98.6	-
433	9.0	54.5	1930	346.0	348.6	40.0	12.9	5.0	2.6	11.5	98.6	-
434	9.6	54.4	1753	346.0	348.5	40.0	12.9	8.9	3.5	11.5	98.6	-
435	9.4	54.1	2050	346.0	348.5	40.0	13.1	9.3	2.5	11.5	98.6	-
436	9.1	54.2	1971	346.0	348.5	40.0	13.0	10.4	2.6	11.5	98.6	-
437	8.9	54.0	1906	346.0	348.5	40.0	13.0	10.1	5.5	11.5	98.6	-
438	8.6	53.7	1740	346.0	348.5	40.0	12.9	9.9	3.9	11.5	98.6	-
439	8.6	53.6	1741	346.0	348.5	40.0	13.0	8.0	3.0	11.5	98.6	-
440	7.9	54.0	1422	346.0	348.5	40.0	12.9	8.7	3.9	11.5	98.6	-

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	L _{Aeq</}
--------------	-------------------------	-----------------------

Table E.01 Measurement data - Turbine ON

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
Report ID: 14215.01.T05.RP6

Page 4 of 9

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	L _{Aeq}	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)		
529	8.3	54.0	1604	346.0	350.8	40.0	13.0	8.8	5.1	11.3	98.6	-		
530	8.4	54.3	1648	346.0	350.8	40.0	13.0	6.2	3.9	11.3	98.6	-		
531	9.1	54.6	1979	346.0	350.8	40.0	13.2	10.8	3.2	11.3	98.6	-		
532	11.3	54.3	2260	346.0	350.8	40.0	13.4	11.4	2.2	11.3	98.6	-		
533	11.6	54.1	2245	346.0	350.8	40.0	13.0	11.7	3.2	11.3	98.6	-		
534	2199	346.0	350.8	40.0	13.1	10.3	4.2	11.3	98.6	-				
535	10.5	54.7	2241	346.0	350.8	40.0	13.0	13.6	6.9	11.3	98.6	-		
536	8.0	53.8	1467	346.0	350.8	40.0	12.7	10.0	6.3	11.3	98.6	-		
537	9.6	53.7	2090	346.0	350.8	40.0	12.8	10.5	5.7	11.3	98.6	-		
538	2267	346.0	350.8	40.0	13.0	9.5	5.5	11.3	98.6	-				
539	2231	346.0	350.8	40.0	13.2	10.3	4.9	11.3	98.6	-				
540	10.4	53.3	2200	346.0	350.8	40.0	12.7	10.6	4.4	11.3	98.6	-		
541	9.9	55.0	2146	346.0	350.8	40.0	12.5	10.9	6.6	11.3	98.6	-		
542	8.4	54.7	1653	346.0	350.8	40.0	12.8	9.7	5.4	11.3	98.6	-		
543	9.3	54.2	1406	346.0	350.8	40.0	12.8	6.8	4.9	11.3	98.6	-		
544	7.9	53.5	1419	346.0	350.8	40.0	12.8	6.6	4.4	11.3	98.6	-		
545	7.7	53.0	1317	346.0	350.8	40.0	12.6	8.2	6.8	11.3	98.6	-		
546	7.6	52.9	1258	346.0	350.8	40.0	12.4	6.6	5.1	11.3	98.6	-		
547	8.1	53.0	1504	346.0	350.8	40.0	13.1	7.2	4.4	11.3	98.6	-		
548	9.1	54.3	1982	346.0	350.8	40.0	13.1	9.1	3.6	11.3	98.6	-		
549	10.9	54.6	2249	346.0	350.8	40.0	13.4	11.1	6.5	11.3	98.6	-		
550	12.3	54.6	2241	346.0	350.8	40.0	13.5	5.4	11.3	98.6	-			
551	11.0	54.2	2276	346.0	350.8	40.0	13.2	11.2	4.9	11.3	98.6	-		
552	10.2	55.2	2180	346.0	350.8	40.0	12.7	12.1	6.2	11.3	98.6	-		
553	9.8	53.9	2129	346.0	350.8	40.0	12.3	9.3	4.6	11.3	98.6	-		
554	9.5	53.7	2054	346.0	350.8	40.0	12.7	11.4	5.2	11.3	98.6	-		
555	10.7	54.2	2237	346.0	350.8	40.0	13.0	10.9	3.8	11.3	98.6	-		
556	2242	346.0	350.8	40.0	13.1	10.2	5.0	11.3	98.6	-				
557	2235	346.0	350.8	40.0	12.8	10.2	5.4	11.3	98.6	-				
558	9.9	54.3	2147	346.0	350.8	40.0	12.9	8.6	4.4	11.3	98.6	-		
559	11.0	53.8	2211	346.0	350.8	40.0	13.1	11.1	4.9	11.3	98.6	-		
560	9.5	54.7	2056	346.0	350.8	40.0	12.9	10.5	4.9	11.3	98.6	-		
561	9.2	53.7	1992	346.0	350.8	40.0	13.0	9.6	3.9	11.3	98.6	-		
562	9.8	54.0	2120	346.0	350.8	40.0	13.0	11.3	4.3	11.3	98.6	-		
563	9.6	54.1	2075	346.0	350.8	40.0	13.0	9.1	5.6	11.3	98.6	-		
564	8.9	54.4	1879	346.0	350.8	40.0	12.9	10.4	3.4	11.3	98.6	-		
565	8.0	54.0	1869	346.0	350.8	40.0	12.9	2.2	3.2	11.3	98.6	-		
566	8.9	54.3	1888	346.0	350.1	40.0	12.9	8.4	3.9	11.3	98.6	-		
567	8.6	54.7	1751	346.0	350.1	40.0	13.0	10.1	3.6	11.3	98.6	-		
568	11.0	54.8	2238	346.0	350.1	40.0	13.7	11.2	4.3	11.3	98.6	-		
569	2281	346.0	350.1	40.0	13.4	9.9	7.0	11.3	98.6	-				
570	10.1	53.2	2178	346.0	350.1	40.0	12.6	9.9	5.7	11.3	98.6	-		
571	8.8	56.0	1843	346.0	350.0	40.0	12.5	9.5	5.1	11.3	98.6	-		
572	8.5	54.2	1772	346.0	350.0	40.0	12.8	3.3	3.3	11.3	98.6	-		
573	7.9	54.5	1440	346.0	349.9	40.0	12.8	10.0	3.0	11.3	98.7	-		
574	8.0	54.3	1452	346.0	349.9	40.0	13.0	8.5	3.2	11.3	98.6	-		
575	8.1	54.2	1513	346.0	349.9	40.0	13.1	5.9	4.1	11.3	98.6	-		
576	11.3	54.5	2259	346.0	349.5	40.0	13.3	11.5	2.0	11.3	98.6	-		
577	9.3	54.4	2017	346.0	349.5	40.0	12.9	10.6	4.4	11.3	98.6	-		
578	9.4	54.2	2045	346.0	347.3	40.0	13.0	9.8	3.3	11.3	98.6	-		
579	8.7	53.9	1802	346.0	347.3	40.0	12.9	12.5	3.1	11.3	98.6	-		
580	9.0	54.9	1849	346.0	347.4	40.0	13.0	8.3	4.5	11.3	98.6	-		
581	8.7	54.7	1790	346.0	347.4	40.0	12.9	8.4	6.1	11.3	98.6	-		
582	8.3	54.7	1616	346.0	347.4	40.0	12.9	9.2	4.4	11.3	98.6	-		
583	8.0	54.8	1485	346.0	350.9	40.0	12.9	5.5	5.0	11.3	98.6	-		
584	7.8	54.6	1354	346.0	351.0	40.0	12.7	7.1	4.8	11.3	98.6	-		
585	8.2	53.8	1570	346.0	351.0	40.0	13.1	8.3	4.0	11.3	98.6	-		
586	2205	346.0	351.0	40.0	13.1	8.3	3.3	11.3	98.6	-				
587	9.8	54.5	1445	346.0	351.0	40.0	13.0	11.6	5.0	11.3	98.6	-		
588	11.1	54.8	2262	346.0	351.0	40.0	13.2	3.2	11.3	98.6	-			
589	8.9	55.2	1883	346.0	351.0	40.0	12.8	10.8	6.1	11.3	98.7	-		
590	8.4	54.4	1674	346.0	354.2	40.0	13.0	11.1	6.0	11.3	98.7	-		
591	8.9	54.7	1916	346.0	357.3	40.0	13.0	7.2	4.3	11.3	98.6	-		
592	8.3	54.4	1607	346.0	357.3	40.0	12.9	8.8	3.9	11.3	98.6	-		
593	8.1	54.1	1503	346.0	357.3	40.0	12.9	7.7	6.1	11.3	98.7	-		
594	8.1	54.3	1518	346.0	357.3	40.0	13.0	8.8	4.8	11.3	98.7	-		
595	7.9	54.5	2252	346.0	357.3	40.0	13.1	1.1	5.2	11.3	98.6	-		
596	8.7	54.1	1797	346.0	348.8	40.0	13.2	6.5	4.6	11.3	98.7	-		
597	2230	346.0	348.9	40.0	13.6	10.2	4.8	11.3	98.7	-				
598	11.1	56.0	2261	346.0	348.9	40.0	13.6	11.2	3.7	11.3	98.7	-		
599	11.6	55.1	2274	346.0	348.9	40.0	13.2	11.8	4.5	11.3	98.6	-		
600	10.5	54.3	2190	346.0	348.9	40.0	12.8	10.7	3.0	11.3	98.7	-		
601	2248	346.0	348.9	40.0	13.1	10.2	4.2	11.3	98.7	-				
602	10.9	54.5	2162	346.0	348.6	40.0	12.6	9.6	7.0	11.3	98.6	-		
603	11.2	53.7	2255	346.0	349.3	40.0	13.0	11.4	4.9	11.3	98.7	-		
604	10.6	54.5	2243	346.0	349.6	40.0	13.5	10.7	5.1	11.3	98.7	-		
605	12.2	54.3	2281	346.0	348.6	40.0	13.1	12.3	3.1	11.3	98.7	-		
606	11.1	56.6	2219	346.0	348.6	40.0	13.0	11.3	7.4	11.3	98.6	-		
607	10.0	54.7	2162	346.0	348.6	40.0	12.6	9.6	7.0	11.3	98.6	-		
608	9.9	53.5	2146	346.0	348.8	40.0	12.5	9.0	6.0	11.3	98.7	-		
609	8.6	54.2	1755	346.0	348.6	40.0	12.9	3.2	5.2	11.2	98.7	-		
610	9.5	54.2	1703	346.0	348.6	40.0	13.0	10.1	9.1	11.2	98.7	-		
611	8.9	55.0	1905	346.0	348.6	40.0	13.1	9.6	7.2	11.2	98.6	-		
612	8.2	55.3	1586	346.0	348.6	40.0	12.9	8.2	4.1	11.2	98.7	-		
613	8.1	55.0	1507	346.0	348.6	40.0	13.0	10.4	6.2	11.2	98.7	-		
614	8.7	55.1	1804	346.0	348.7	40.0	13.1	8.6	3.7	11.2	98.7	-		
615	9.2	54.6	2000	346.0	348.7	40.0	13.1	10.0	5.7	11.2	98.7	-		
616	9.1	55.2	1966	346.0	348.6	40.0	13.0	9.1	3.3	11.2	98.7	-		

Table E.01 Measurement data - Turbine ON

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
 Report ID: 14215.01.T05.RP6

Page 5 of 9

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
705	10.7	53.2	2241	277.0	268.2	35.0	13.3	10.9	7.5	12.5	96.9	61
706	12.6	53.7	2208	277.0	268.0	35.0	13.4	12.8	7.3	12.5	96.9	61
707	13.3	53.4	2232	277.0	264.3	35.0	13.4	13.5	7.4	12.5	96.9	61
708	10.5	53.4	2255	277.0	264.3	35.0	13.2	10.6	6.8	12.5	96.9	61
709	11.1	52.9	2194	277.0	264.3	35.0	12.8	11.2	10.4	12.5	96.9	62
710	11.2	52.4	2198	277.0	267.2	35.0	12.7	11.3	10.3	12.5	96.9	62
711	10.8	52.9	2186	277.0	272.3	35.0	12.6	10.9	10.9	12.5	96.9	62
712	10.5	52.7	2225	277.0	272.3	35.0	12.9	10.7	8.7	12.5	96.9	62
713	11.4	53.2	2223	277.0	272.3	35.0	13.4	11.6	7.5	12.5	96.9	62
714	11.7	53.7	2263	277.0	272.3	35.0	13.3	11.8	9.5	12.5	96.9	62
715	12.4	53.1	2256	277.0	272.3	35.0	13.0	12.6	11.0	12.5	96.9	61
716	9.9	52.4	2155	277.0	272.3	35.0	12.6	12.2	7.3	12.5	96.9	61
717	10.2	52.4	2182	277.0	272.3	35.0	12.6	11.2	8.8	12.5	96.9	61
718	9.8	52.3	2151	277.0	272.3	35.0	12.5	6.5	5.9	12.5	96.9	61
719	9.3	52.5	2012	277.0	272.3	35.0	12.8	9.9	6.4	12.5	96.9	62
720	9.1	52.6	1977	277.0	272.3	35.0	12.9	10.2	4.7	12.5	96.9	61
721	9.5	53.2	2055	277.0	272.3	35.0	13.0	10.4	8.9	12.6	96.9	62
722	9.6	53.2	2077	277.0	275.7	35.0	13.0	10.3	7.3	12.6	96.9	62
723	8.8	53.2	1859	277.0	278.5	35.0	13.0	9.0	7.1	12.6	96.9	62
724	9.4	53.0	2035	277.0	278.6	35.0	13.1	10.2	7.1	12.6	96.9	62
725	9.2	53.5	2003	277.0	277.6	35.0	13.1	9.4	9.1	12.6	96.9	62
726	11.8	52.7	2269	277.0	276.8	35.0	13.5	10.0	7.4	12.6	96.9	62
727	10.5	53.6	2246	277.0	275.8	35.0	13.5	10.7	7.0	12.6	96.9	61
728	11.5	53.6	2273	277.0	275.8	35.0	13.4	11.7	8.2	12.6	96.9	61
729	9.9	52.9	2158	277.0	275.8	35.0	12.6	11.0	8.0	12.6	96.9	61
730	10.1	52.2	2176	277.0	274.3	35.0	12.7	8.6	8.2	12.6	96.9	61
731	9.9	53.0	2160	277.0	268.5	35.0	12.5	10.7	7.5	12.6	96.9	61
732	8.8	53.6	1835	277.0	268.5	35.0	12.9	10.5	6.3	12.6	96.9	61
733	11.9	54.2	2252	277.0	268.5	35.0	13.5	12.0	5.3	12.6	96.9	62
734	8.5	53.4	2262	277.0	270.4	35.0	13.1	11.7	7.8	12.6	96.9	61
735	8.8	53.4	2184	277.0	268.8	35.0	12.7	7.9	9.8	12.6	96.9	61
736	9.5	54.1	2056	277.0	268.8	35.0	13.0	11.9	8.9	12.6	96.9	61
737	10.4	54.0	2250	277.0	268.8	35.0	13.4	10.6	9.5	12.6	96.9	61
739	10.7	53.1	2261	277.0	268.8	35.0	13.0	10.9	6.9	12.6	96.9	62
740	10.6	52.9	2230	277.0	268.8	35.0	13.1	10.7	6.4	12.6	96.9	62
741	10.3	52.9	2215	277.0	268.8	35.0	12.8	10.5	10.0	12.6	96.9	62
742	9.6	52.7	2081	277.0	268.8	35.0	12.4	11.1	7.9	12.6	96.9	62
743	9.0	53.1	1945	277.0	268.8	35.0	13.1	10.6	8.7	12.6	96.9	62
744	9.1	53.3	1980	277.0	268.8	35.0	13.0	7.7	8.8	12.6	96.9	62
745	9.3	53.1	2008	277.0	268.8	35.0	13.0	10.6	9.2	12.6	96.9	62
746	8.9	53.2	1925	277.0	269.5	35.0	13.0	11.2	8.7	12.5	96.9	62
747	8.9	53.4	1902	277.0	275.9	35.0	13.0	11.2	7.9	12.5	96.9	62
748	8.6	53.6	1767	277.0	270.8	35.0	13.0	10.5	8.3	12.5	96.9	62
749	8.4	53.3	1682	277.0	278.9	35.0	13.0	8.3	5.8	12.6	96.9	62
750	9.0	54.0	1936	277.0	278.8	35.0	13.0	8.8	7.1	12.6	96.9	62
751	8.6	53.3	1758	277.0	277.9	35.0	12.9	9.0	9.5	12.6	96.9	62
752	8.1	53.3	1499	277.0	274.3	35.0	12.9	7.8	5.9	12.6	96.9	62
753	8.3	53.4	1624	277.0	274.2	35.0	13.1	8.3	8.1	12.6	96.9	62
754	9.1	53.7	1967	277.0	274.3	35.0	13.2	9.3	9.9	12.5	96.9	62
755	11.1	53.7	2243	277.0	274.3	35.0	13.2	9.3	9.8	12.5	96.9	62
756	12.0	52.6	2232	277.0	274.3	35.0	13.1	10.4	7.1	12.6	96.9	62
757	10.9	52.7	2217	277.0	274.3	35.0	12.8	11.1	9.1	12.6	96.9	62
758	11.1	53.3	2187	277.0	274.3	35.0	12.6	11.3	5.7	12.6	96.9	62
759	11.2	52.7	2227	277.0	274.3	35.0	12.9	10.2	10.8	12.6	96.9	62
760	10.2	53.0	2182	277.0	274.3	35.0	12.5	10.4	8.0	12.6	96.9	62
761	10.7	53.2	2247	277.0	274.3	35.0	13.5	10.0	8.2	12.6	96.9	62
762	11.1	53.7	2265	277.0	274.3	35.0	13.1	10.3	9.8	12.6	96.9	62
763	11.1	52.8	2217	277.0	274.3	35.0	12.8	10.3	10.4	12.6	96.9	62
764	12.0	52.6	2232	277.0	274.3	35.0	13.0	12.2	9.8	12.6	96.9	62
765	10.9	52.7	2217	277.0	274.3	35.0	12.8	11.1	9.1	12.6	96.9	62
766	10.6	52.4	2205	277.0	274.3	35.0	12.9	10.7	7.2	12.6	96.9	62
767	11.7	52.9	2230	277.0	274.3	35.0	12.9	11.8	7.9	12.6	96.9	62
768	12.4	52.6	2245	277.0	276.7	35.0	13.0	9.8	7.7	12.6	96.9	62
769	10.2	53.0	2182	277.0	276.7	35.0	12.5	11.6	8.1	12.6	96.9	62
770	10.7	53.2	2247	277.0	276.7	35.0	13.2	10.9	7.7	12.6	96.9	62
771	10.2	53.3	2244	277.0	276.7	35.0	12.9	10.3	6.8	12.6	96.9	62
772	8.7	52.7	1827	277.0	271.0	35.0	12.7	10.8	8.4	12.6	96.9	62
773	11.1	53.4	2254	277.0	271.0	35.0	13.1	10.1	7.3	12.6	96.9	62
774	10.4	53.7	2236	277.0	271.0	35.0	13.1	10.5	10.2	12.6	96.9	62
775	9.0	53.6	1945	277.0	271.0	35.0	12.6	9.8	7.5	12.6	96.9	62
776	8.5	53.8	1688	277.0	268.7	35.0	12.9	7.3	8.4	12.6	96.9	62
777	8.3	53.6	1626	277.0	268.7	35.0	13.0	10.5	6.5	12.5	96.9	62
778	8.1	53.5	1641	277.0	268.7	35.0	13.0	9.0	5.9	12.5	96.9	62
779	8.5	53.6	1724	277.0	268.7	35.0	13.0	8.6	9.1	12.5	96.9	62
780	8.9	54.3	1902	277.0	268.7	35.0	13.0	7.9	7.3	12.5	96.9	62
781	8.7	53.9	1826	277.0	268.7	35.0	13.1	9.3	6.3	12.5	96.9	62
782	12.0	53.9	2202	277.0	268.7	35.0	13.1	12.2	7.8	12.5	96.9	62
783	9.0	53.5	1955	277.0	268.7	35.0	12.9	9.0	5.9	12.5	96.9	62
784	9.2	53.4	1997	277.0	273.4	35.0	13.0	8.8	7.7	12.5	96.9	62
785	9.3	53.3	2022	277.0	273.4	35.0	13.0	11.0	7.9	12.5	96.9	62
786	10.4	53.3	2244	277.0	274.4	35.0	13.2	10.3	6.9	12.5	96.9	62
787	11.1	53.6	2267	277.0	274.4	35.0	13.1	11.3	7.3	12.6	96.9	62
788	11.2	53.7	2241	277.0	274.4	35.0	13.5	11.4	8.5	12.6	96.9	62
789	11.4	53.3	2229	277.0	274.4	35.0	13.1	11.6	8.4	12.6	96.9	62
790	8.4	52.7	1657	277.0	276.6	35.0	12.5	10.7	8.6	12.6	96.9	62
791	10.2	53.3	2180	277.0	283.1	35.0	13.1	10.4	7.4	12.6	96.9	62
792	9.6	53.4	2078	277.0	285.9	35.0	13.0	9.4	7.7	12.6	96.9	62

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)

Table E.01 Measurement data - Turbine ON

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
Report ID: 14215.01.T05.RP6

Page 6 of 9

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
881	11.8	53.2	2246	277.0	263.1	35.0	13.0	11.9	6.1	13.0	96.9	62
882	9.7	52.8	2102	277.0	265.4	35.0	12.3	13.2	6.0	13.0	96.9	62
883			2214	277.0	270.9	35.0	12.8	9.0	8.2	13.0	96.9	61
884	11.1	53.4	2234	277.0	270.9	35.0	13.1	11.3	6.8	13.0	96.9	61
885	10.9	53.8	2224	277.0	270.9	35.0	13.0	11.1	6.4	13.0	96.9	61
886	9.9	53.9	2159	277.0	270.9	35.0	12.8	10.9	6.1	13.0	95.9	61
887			2230	277.0	270.9	35.0	12.2	6.7	6.0	13.0	96.9	61
888			2248	277.0	270.9	35.0	12.9	7.7	7.5	13.0	96.9	61
889			1878	277.0	270.9	35.0	12.8	11.7	6.3	13.1	96.9	61
890			2258	277.0	270.9	35.0	13.5	11.7	5.2	13.1	96.9	61
891			2174	277.0	270.9	35.0	12.8	10.1	5.2	13.1	96.9	61
892	9.4	53.4	2038	277.0	270.9	35.0	12.9	10.1	7.4	13.1	96.9	61
893	11.4	54.4	2237	277.0	270.9	35.0	13.7	11.6	4.5	13.1	95.9	61
894	10.4	54.1	2266	277.0	270.9	35.0	13.2	10.6	4.9	13.1	96.9	61
895	10.3	54.1	2191	277.0	270.9	35.0	12.8	6.5	6.0	13.1	96.9	61
896	11.3	52.6	2192	277.0	270.9	35.0	12.8	11.5	6.0	13.1	96.9	61
897	11.4	53.8	2222	277.0	271.0	35.0	13.8	11.5	6.6	13.1	96.9	61
898	11.3	53.7	2247	277.0	271.0	35.0	13.3	11.4	3.8	13.1	96.9	61
899	12.0	52.9	2265	277.0	271.0	35.0	13.0	12.1	9.5	13.1	96.9	61
900	12.6	53.0	2197	277.0	271.0	35.0	12.8	12.8	10.1	13.1	96.9	61
901	11.2	52.9	2240	277.0	271.0	35.0	13.1	11.4	8.8	13.1	95.9	61
902	11.1	52.6	2221	277.0	271.0	35.0	13.1	13.3	8.4	13.1	96.9	61
903	10.0	52.7	2162	277.0	271.0	35.0	12.6	12.0	5.9	13.1	96.9	61
904			2214	277.0	271.0	35.0	12.8	10.3	7.1	13.1	96.9	61
905			2232	277.0	271.0	35.0	12.8	10.0	5.7	13.1	96.9	61
906			2227	277.0	271.0	35.0	12.8	10.2	7.7	13.1	96.9	61
907	10.6	52.7	2224	277.0	271.0	35.0	12.9	10.8	9.9	13.1	96.9	61
908	10.3	53.2	2225	277.0	271.0	35.0	13.1	10.5	5.7	13.1	96.9	61
909	10.0	52.5	2167	277.0	271.0	35.0	12.6	10.4	9.7	13.1	95.9	61
910	9.9	52.8	2146	277.0	271.0	35.0	12.8	9.6	6.8	13.1	96.9	61
911			2250	277.0	271.0	35.0	13.1	9.9	9.6	13.1	96.9	61
912	11.3	53.5	2230	277.0	270.6	35.0	13.6	11.4	8.0	13.1	96.9	61
913	11.2	53.3	2249	277.0	266.0	35.0	13.2	11.4	5.2	13.1	96.9	61
914	10.1	52.9	2176	277.0	266.0	35.0	12.7	10.8	7.2	13.1	96.9	61
915			2191	277.0	266.0	35.0	12.7	10.4	8.0	13.1	96.9	61
916	11.3	53.3	2195	277.0	266.0	35.0	12.8	11.5	7.5	13.1	95.9	61
917			2233	277.0	266.4	35.0	13.5	10.3	8.3	13.1	96.9	61
918			2256	277.0	268.7	35.0	13.3	9.1	6.4	13.1	96.9	61
919	9.9	53.0	2139	277.0	268.7	35.0	12.4	11.6	5.5	13.1	96.9	62
920			2236	277.0	268.7	35.0	13.3	9.6	8.2	13.1	96.9	62
921	12.3	53.7	2227	277.0	268.7	35.0	13.4	12.5	9.0	13.1	96.9	62
922	11.1	53.4	2203	277.0	268.7	35.0	12.7	11.3	8.4	13.1	96.9	62
923	10.5	52.8	2186	277.0	268.7	35.0	12.6	10.6	8.9	13.1	95.9	62
924	10.0	52.0	2168	277.0	268.7	35.0	12.5	12.2	8.0	13.1	96.9	62
925	10.2	53.0	2180	277.0	268.7	35.0	13.0	10.8	8.4	13.1	96.9	61
926	9.4	53.4	2048	277.0	268.7	35.0	13.0	9.3	7.5	13.1	96.9	61
927	9.2	53.7	2003	277.0	268.7	35.0	13.0	9.6	6.7	13.1	96.9	61
928	8.6	53.4	1756	277.0	265.1	35.0	12.9	8.6	8.1	13.1	96.9	61
929			1661	277.0	260.5	35.0	12.9	8.7	6.8	13.1	96.9	61
930			1388	277.0	260.4	35.0	12.9	7.3	8.2	13.1	95.9	61
931			1321	277.0	260.4	35.0	12.7	5.8	5.2	13.1	96.9	61
932	7.8	53.5	1366	277.0	260.6	35.0	12.9	9.9	4.7	13.1	96.9	61
933	8.7	54.2	1829	277.0	272.5	35.0	13.1	8.7	8.2	13.1	96.9	61
934	8.0	53.8	1475	277.0	273.8	35.0	12.9	8.9	8.2	13.1	96.9	61
935	7.8	52.9	1384	277.0	270.8	35.0	13.0	9.7	6.8	13.1	96.9	61
936	8.3	53.5	1638	277.0	270.8	35.0	13.1	8.2	6.4	13.1	96.9	61
937	8.9	54.3	1917	277.0	270.8	35.0	13.1	10.2	7.1	13.0	96.9	61
938	8.9	54.4	1651	277.0	270.8	35.0	13.1	8.2	5.8	13.0	96.9	61
939	8.8	54.2	2134	277.0	268.8	35.0	13.0	8.7	6.0	13.0	96.9	61
940	8.9	54.5	1622	277.0	267.8	35.0	12.9	7.4	6.2	13.0	96.9	61
941	8.6	54.2	1736	277.0	267.0	35.0	12.9	8.0	6.1	13.0	96.9	61
942			1701	277.0	260.4	35.0	13.0	8.7	5.6	13.0	96.9	61
943			2249	277.0	259.3	35.0	13.3	10.3	6.0	13.0	96.9	62
944			2253	277.0	259.3	35.0	13.8	9.3	7.2	13.0	96.9	62
945			2214	277.0	259.3	35.0	13.6	12.5	6.8	13.0	96.9	62
946			2254	277.0	259.3	35.0	13.3	10.8	4.9	13.0	96.9	62
947			2238	277.0	259.3	35.0	13.3	10.4	4.7	13.0	96.9	62
948	10.0	52.1	2169	277.0	264.3	35.0	12.7	12.9	6.1	13.0	96.9	62
949	11.3	52.6	2255	277.0	265.6	35.0	13.0	11.5	6.0	13.1	96.9	62
950	11.7	53.0	2210	277.0	265.6	35.0	12.9	11.9	4.8	13.1	96.9	62
951	10.9	52.7	2236	277.0	265.6	35.0	12.9	11.1	7.1	13.1	96.9	62
952	11.4	52.9	2207	277.0	265.6	35.0	12.8	11.6	6.5	13.1	96.9	62
953	10.5	52.4	2194	277.0	265.8	35.0	12.6	10.6	5.5	13.1	96.9	62
954	11.3	53.0	2236	277.0	265.6	35.0	13.2	13.5	7.0	13.2	96.9	62
955	11.5	53.3	2266	277.0	265.6	35.0	13.3	11.7	8.0	13.2	96.9	62
956	10.6	53.2	2237	277.0	265.6	35.0	13.1	10.8	7.0	13.2	96.9	62
957	11.2	53.0	2227	277.0	265.6	35.0	13.1	11.3	7.4	13.2	96.9	62
958	10.3	52.9	2205	277.0	265.6	35.0	12.8	10.4	8.5	13.2	96.9	62
959	13.3	53.0	2236	277.0	265.6	35.0	13.2	13.5	7.0	13.2	96.9	62
960	11.7	53.3	2272	277.0	265.6	35.0	13.5	11.9	7.0	13.2	95.9	62
961	11.0	53.6	2207	277.0	265.6	35.0	13.2	12.2	5.4	13.2	96.9	62
962	12.4	53.2	2224	277.0	265.6	35.0	13.1	12.5	7.2	13.2	97.0	62
963	12.9	53.2	2238	277.0	265.6	35.0	13.2	13.1	6.5	13.2	97.0	62
964	10.1	52.6	2178	277.0	265.6	35.0	12.6	11.8	5.7	13.2	97.0	62
965	12.2	52.3	2225	277.0	265.8	35.0	12.8	12.4	6.8	13.2	97.0	62
966	11.4	52.6	2251	277.0	265.7	35.0	13.0	11.5	6.8	13.2	97.0	62
967	11.2	52.6	2204	277.0	265.6	35.0	12.7	11.4	6.5	13.1	97.0	62
968	11.3	52.3	2229	277.0	265.8	35.0	13.1	11.4	7.8	13.1	97.0	62

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Reference Yaw Angle</
--------------	-------------------------	------	-----------------------

Table E.01 Measurement data - Turbine ON

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
Report ID: 14215.01.T05.RP6

Page 7 of 9

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAEQ	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
1057	11.1	52.7	2244	277.0	278.5	35.0	13.0	11.3	7.3	13.1	97.0	62
1058	10.7	52.7	2227	277.0	278.5	35.0	13.0	10.9	9.1	13.1	97.0	62
1059	11.5	52.6	2223	277.0	278.5	35.0	13.0	11.6	7.0	13.1	97.0	62
1060	10.8	53.1	2238	277.0	278.5	35.0	13.1	11.0	8.2	13.1	97.0	62
1061	10.0	52.6	2173	277.0	278.5	35.0	12.5	11.3	7.7	13.1	97.0	62
1062	11.2	53.0	2254	277.0	278.5	35.0	13.3	11.3	6.9	13.1	97.0	62
1063	10.8	53.8	2255	277.0	278.5	35.0	13.3	10.0	8.8	13.1	97.0	62
1064	11.1	52.7	2220	277.0	278.5	35.0	13.0	11.3	9.9	13.1	97.0	62
1065	-	-	2211	277.0	278.5	35.0	12.8	9.8	9.1	13.1	97.0	62
1066	10.8	51.9	2184	277.0	278.5	35.0	12.7	11.0	9.0	13.1	97.0	62
1067	-	-	2206	277.0	278.5	35.0	12.8	10.2	7.7	13.1	97.0	62
1068	-	-	2261	277.0	278.5	35.0	13.0	10.3	7.8	13.1	97.0	62
1069	-	-	2217	277.0	278.5	35.0	12.8	10.1	6.4	13.1	97.0	62
1070	-	-	2210	277.0	278.5	35.0	12.8	10.3	6.1	13.1	97.0	62
1071	-	-	2168	277.0	278.5	35.0	13.0	7	5.0	13.1	97.0	62
1072	9.3	53.1	2010	277.0	278.5	35.0	12.9	9.9	8.6	13.1	97.0	62
1073	8.9	52.9	1899	277.0	278.5	35.0	13.0	8.2	6.0	13.1	97.0	62
1074	8.8	53.4	1838	277.0	278.5	35.0	12.9	8.0	5.1	13.1	97.0	62
1075	9.1	53.6	1984	277.0	278.5	35.0	13.1	10.4	5.0	13.1	97.0	62
1076	8.8	53.4	1836	277.0	278.5	35.0	12.9	8.6	3.0	13.1	97.0	62
1077	8.8	54.5	1876	277.0	278.3	35.0	12.8	8.6	7.0	13.3	97.0	62
1078	9.4	53.6	1894	277.0	278.3	35.0	13.1	9.5	13.3	13.3	97.0	62
1079	8.8	54.0	1849	277.0	278.3	35.0	13.0	8.7	6.7	13.3	97.0	62
1080	8.4	53.8	1676	277.0	278.3	35.0	12.9	9.3	7.5	13.3	97.0	62
1081	8.2	53.6	1546	277.0	278.3	35.0	13.0	5.9	6.4	13.3	97.0	62
1082	9.6	53.5	2094	277.0	274.1	35.0	13.2	9.7	7.2	13.3	97.0	62
1083	-	-	2248	277.0	274.1	35.0	13.2	9.3	5.6	13.3	97.0	62
1084	10.6	53.2	2193	277.0	274.1	35.0	12.8	10.8	8.2	13.4	96.9	62
1085	9.0	53.2	1960	277.0	274.1	35.0	13.0	9.1	7.4	13.4	96.9	62
1086	10.3	53.4	2248	277.0	274.1	35.0	12.8	9.6	6.3	13.4	96.9	62
1087	11.9	53.9	2260	277.0	274.1	35.0	13.2	12.1	7.9	13.4	96.9	62
1088	10.7	53.7	2211	277.0	274.1	35.0	13.4	10.9	7.0	13.4	96.9	62
1089	10.4	53.2	2232	277.0	274.1	35.0	13.3	10.5	5.7	13.4	96.9	62
1090	10.4	52.8	2196	277.0	274.1	35.0	12.6	10.5	7.7	13.4	96.9	62
1091	9.8	52.1	2195	277.0	274.1	35.0	12.7	9.9	6.4	13.4	96.9	62
1092	11.4	52.4	2238	277.0	274.1	35.0	12.8	11.5	5.1	13.4	96.9	62
1093	9.0	53.0	2018	277.0	274.1	35.0	12.8	11.5	1.3	13.4	96.9	62
1094	10.6	53.4	2245	277.0	274.1	35.0	13.4	10.7	3.8	13.4	96.9	62
1095	11.1	54.1	2224	277.0	281.4	35.0	13.7	11.2	4.3	13.4	96.9	62
1096	11.6	53.2	2252	277.0	281.4	35.0	13.1	11.7	5.9	13.4	96.9	62
1097	10.3	52.5	2268	277.0	281.4	35.0	13.2	10.4	6.4	13.4	97.0	62
1098	12.2	53.0	2237	277.0	277.4	35.0	13.5	12.3	6.3	13.4	97.0	62
1099	12.7	53.1	2245	277.0	274.4	35.0	13.2	12.9	4.4	13.4	97.0	62
1100	13.0	53.6	2100	277.0	274.4	35.0	12.8	12.4	4.8	13.4	97.0	62
1101	13.0	52.6	2263	277.0	274.4	35.0	12.8	13.2	8.3	13.4	97.0	62
1102	11.5	52.5	2201	277.0	274.4	35.0	12.8	11.7	5.8	13.5	97.0	62
1103	12.7	52.0	2202	277.0	274.4	35.0	12.7	12.9	8.3	13.5	97.0	62
1104	11.3	52.5	2205	277.0	274.4	35.0	12.8	11.5	8.6	13.5	97.0	62
1105	11.8	52.5	2240	277.0	274.4	35.0	13.0	11.9	9.3	13.5	97.0	62
1106	12.5	52.9	2223	277.0	274.4	35.0	13.3	12.7	8.0	13.5	97.0	62
1107	-	-	2244	277.0	274.4	35.0	13.4	13.0	6.1	13.5	97.0	62
1108	13.0	53.2	2239	277.0	274.4	35.0	13.0	10.2	8.9	13.5	97.0	62
1109	12.7	52.9	2266	277.0	280.6	35.0	13.1	12.9	6.1	13.6	97.0	61
1110	11.1	52.6	2216	277.0	282.4	35.0	13.0	11.3	8.6	13.6	97.0	61
1111	11.8	52.9	2243	277.0	282.3	35.0	13.0	12.0	8.0	13.6	97.0	61
1112	11.3	52.7	2185	277.0	282.4	35.0	12.8	11.5	9.9	13.6	97.0	61
1113	11.8	52.7	2245	277.0	282.4	35.0	13.0	12.0	8.4	13.6	97.0	61
1114	-	-	2250	277.0	282.4	35.0	13.1	11.1	9.1	13.5	97.0	61
1115	11.9	52.8	2265	277.0	282.4	35.0	13.1	12.1	5.9	13.5	97.0	61
1116	11.2	53.2	2226	277.0	277.8	35.0	12.9	11.3	6.9	13.6	97.0	61
1117	12.1	52.5	2218	277.0	272.5	35.0	12.9	12.3	6.9	13.5	97.0	61
1118	12.2	52.8	2214	277.0	272.5	35.0	13.2	12.4	9.5	13.5	97.0	61
1119	11.2	52.8	2244	277.0	272.5	35.0	13.1	11.3	6.8	13.5	97.0	61
1120	10.5	52.3	2221	277.0	272.5	35.0	12.8	10.6	6.2	13.5	97.0	61
1121	12.5	52.8	2258	277.0	272.5	35.0	13.2	12.7	5.4	13.5	96.9	62
1122	12.0	52.6	2255	277.0	272.5	35.0	13.0	12.2	8.6	13.5	96.9	62
1123	12.3	52.3	2235	277.0	272.5	35.0	13.1	11.4	6.6	13.5	96.9	62
1124	10.9	52.9	2210	277.0	276.3	35.0	13.0	11.1	5.7	13.5	96.9	62
1125	11.8	52.7	2242	277.0	276.3	35.0	12.9	11.9	6.4	13.5	96.9	62
1126	10.5	52.7	2246	277.0	276.3	35.0	13.0	10.6	5.4	13.5	97.0	62
1127	11.2	53.1	2258	277.0	276.3	35.0	13.1	11.4	9.5	13.5	97.0	62
1128	11.2	53.1	2240	277.0	276.3	35.0	13.0	11.4	6.6	13.5	97.0	62
1129	10.0	52.3	2167	277.0	276.3	35.0	12.7	10.7	6.0	13.5	97.0	62
1130	11.9	52.2	2165	277.0	276.3	35.0	12.7	12.0	6.0	13.5	97.0	62
1131	12.3	52.8	2233	277.0	276.3	35.0	13.2	12.4	7.1	13.5	97.0	62
1132	9.9	52.6	2157	277.0	276.1	35.0	12.6	9.2	5.2	13.6	97.0	62
1133	10.0	52.6	2169	277.0	272.3	35.0	12.6	10.5	5.5	13.6	97.0	62
1134	11.4	53.3	2262	277.0	272.3	35.0	13.6	11.5	4.2	13.6	97.0	62
1135	11.8	53.5	2235	277.0	272.3	35.0	13.3	12.0	8.7	13.6	97.0	62
1136	11.0	52.9	2223	277.0	272.3	35.0	13.2	11.2	6.1	13.6	97.0	62
1137	11.3	52.4	2100	277.0	272.3	35.0	13.5	12.5	6.5	13.6	97.0	62
1138	9.9	52.2	2160	277.0	272.3	35.0	12.5	12.5	9.2	13.6	96.9	61
1139	8.7	52.1	1789	277.0	273.3	35.0	12.6	10.9	8.2	13.6	96.9	61
1140	8.8	53.4	1876	277.0	279.7	35.0	13.0	10.7	6.9	13.6	96.9	61
1141	8.6	53.7	1765	277.0	279.9	35.0	13.0	8.9	3.3	13.6	96.9	61
1142	9.5	53.8	2070	277.0	279.9	35.0	13.2	9.1	5.6	13.6	96.9	61
1143	10.8	53.7	2228	277.0	279.9	35.0	13.1	11.0	6.3	13.6	96.9	61
1144	11.0	53.3	2239	277.0	279.9	35.0	13.7	11.2	5.6	13.6	97.0	61

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAEQ	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed

Table E.01 Measurement data - Turbine ON

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
 Report ID: 14215.01.T05.RP6

Page 8 of 9

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)	
1233	10.9	53.4	2243	277.0	264.5	35.0	13.5	11.0	7.7	13.6	97.0	61	
1234	10.9	53.3	2246	277.0	264.5	35.0	12.9	11.0	6.5	13.6	97.0	62	
1235	12.6	53.3	2190	277.0	264.4	35.0	12.7	12.8	7.1	13.6	97.0	62	
1236	10.1	53.0	2178	277.0	265.2	35.0	12.6	11.3	5.4	13.6	97.0	62	
1237	10.9	53.3	2210	277.0	270.8	35.0	13.1	13.1	11.1	4.3	13.6	97.0	62
1238	11.6	53.8	2246	277.0	270.8	35.0	13.6	11.8	4.8	13.6	97.0	61	
1239	12.6	53.6	2257	277.0	270.8	35.0	13.4	12.9	5.3	13.6	97.0	61	
1240	12.2	53.3	2264	277.0	270.8	35.0	13.1	12.3	7.9	13.6	97.0	62	
1241	9.8	52.0	2133	277.0	270.8	35.0	12.5	11.1	10.3	13.6	96.9	62	
1242	11.2	52.6	2212	277.0	270.8	35.0	12.9	11.3	9.4	13.6	96.9	62	
1243	11.2	52.7	2186	277.0	270.8	35.0	12.8	11.3	8.8	13.6	96.9	62	
1244	10.5	52.6	2225	277.0	268.6	35.0	13.0	10.7	9.0	13.6	96.9	62	
1245	10.4	53.2	2237	277.0	264.0	35.0	13.2	10.6	6.7	13.6	96.9	61	
1246	11.3	53.7	2261	277.0	264.0	35.0	13.1	10.4	5.6	13.6	96.9	61	
1247	9.8	52.6	2206	277.0	264.0	35.0	12.8	8.5	6.2	13.5	96.9	61	
1248	9.9	52.8	2155	277.0	264.0	35.0	12.5	10.9	4.8	13.6	96.9	61	
1249	8.9	53.3	1916	277.0	264.0	35.0	12.9	10.6	5.1	13.6	96.9	61	
1250	9.8	53.7	2133	277.0	268.5	35.0	13.0	12.0	11.2	13.6	96.9	61	
1251	10.9	53.4	2232	277.0	275.1	35.0	13.2	11.1	9.4	13.6	96.9	61	
1252	10.5	53.2	2224	277.0	275.8	35.0	12.8	10.6	7.2	13.7	96.9	61	
1253	8.3	52.6	1597	277.0	275.8	35.0	12.8	7.7	7.7	13.7	96.9	61	
1254	9.2	54.8	1692	277.0	268.8	35.0	13.1	11.0	6.8	13.7	96.9	61	
1255	9.3	53.6	2019	277.0	275.8	35.0	13.0	11.2	5.4	13.7	96.9	61	
1256	9.3	53.5	2026	277.0	275.9	35.0	13.0	8.2	6.8	13.7	96.9	61	
1257	9.4	53.5	2048	277.0	275.7	35.0	13.0	7.3	4.5	13.7	96.9	61	
1258	8.8	53.8	1835	277.0	270.0	35.0	13.0	10.2	7.3	13.7	96.9	61	
1259	10.8	54.3	2264	277.0	270.0	35.0	13.6	10.9	5.8	13.7	96.9	61	
1260	12.2	53.8	2238	277.0	270.0	35.0	13.2	9.6	4.8	13.7	96.9	61	
1261	10.1	53.2	2178	277.0	270.0	35.0	12.8	10.3	5.4	13.7	96.9	61	
1262	9.8	52.6	2249	277.0	270.0	35.0	12.0	9.4	6.5	13.7	96.9	61	
1263	9.2	53.6	2251	277.0	265.1	35.0	13.0	8.4	6.1	13.7	96.9	61	
1264	10.5	52.9	2271	277.0	265.2	35.0	13.2	10.6	5.7	13.8	96.9	61	
1265	10.6	53.4	2231	277.0	265.2	35.0	13.2	10.7	8.0	13.8	96.9	61	
1266	9.2	53.8	2228	277.0	265.2	35.0	12.9	10.1	6.4	13.8	96.9	61	
1267	21.96	52.7	2270	277.0	265.0	35.0	12.8	10.4	7.4	13.8	97.0	61	
1268	9.3	52.7	2017	277.0	265.0	35.0	12.5	10.9	5.5	13.8	97.0	61	
1269	9.3	53.9	2013	277.0	265.0	35.0	13.0	9.6	8.6	13.8	97.0	61	
1270	8.5	53.5	1706	277.0	264.9	35.0	12.9	9.0	0.5	13.8	97.0	61	
1271	10.0	53.9	2166	277.0	265.5	35.0	13.2	11.5	8.7	13.8	97.0	61	
1272	10.5	53.7	2230	277.0	265.7	35.0	13.2	10.7	8.0	13.8	97.0	61	
1273	8.6	53.2	1761	277.0	265.7	35.0	12.8	10.0	5.7	13.8	97.0	61	
1274	8.6	53.3	1771	277.0	265.6	35.0	13.0	9.5	7.1	13.8	97.0	61	
1275	9.4	53.9	2050	277.0	265.6	35.0	13.0	9.8	7.4	13.8	97.0	61	
1276	8.5	53.7	1689	277.0	265.0	35.0	13.0	9.2	6.3	13.8	97.0	61	
1277	9.2	53.6	1985	277.0	267.4	35.0	13.0	9.9	6.4	13.8	97.0	61	
1278	8.9	53.8	1906	277.0	274.0	35.0	13.0	11.5	4.7	13.8	97.0	61	
1279	8.2	53.2	1587	277.0	274.8	35.0	12.8	8.5	6.0	13.8	97.0	61	
1280	8.0	52.9	1480	277.0	274.8	35.0	13.0	10.1	4.7	13.8	97.0	61	
1281	9.6	53.5	2082	277.0	274.8	35.0	13.2	9.1	7.4	13.8	97.0	61	
1282	8.6	53.6	1778	277.0	279.0	35.0	12.9	7.9	7.0	13.8	97.0	61	
1283	8.4	53.5	1657	277.0	279.0	35.0	13.0	6.5	7.1	13.8	97.0	61	
1284	8.6	53.6	1633	277.0	272.7	35.0	13.1	8.2	7.7	13.8	97.0	61	
1285	9.9	54.0	2145	277.0	268.8	35.0	13.1	10.1	7.2	13.8	97.0	61	
1286	9.3	53.5	2025	277.0	268.8	35.0	13.0	7.4	5.3	13.8	97.0	61	
1287	8.8	53.4	1858	277.0	268.8	35.0	13.0	8.9	5.0	13.8	97.0	61	
1288	8.6	53.7	1750	277.0	268.8	35.0	13.0	9.4	6.0	13.8	97.0	61	
1289	8.5	53.5	1688	277.0	268.8	35.0	12.9	9.9	8.7	13.8	97.0	61	
1290	8.5	53.5	1692	277.0	268.8	35.0	13.0	9.5	7.4	13.8	97.0	61	
1291	8.5	53.6	1763	277.0	268.8	35.0	13.0	9.7	6.2	13.8	97.0	61	
1292	8.5	53.6	1713	277.0	268.8	35.0	13.0	11.1	6.2	13.8	97.0	61	
1293	10.5	54.3	2227	277.0	268.8	35.0	13.5	10.6	5.9	13.8	97.0	61	
1294	10.9	54.5	2267	277.0	268.8	35.0	13.5	11.1	5.3	13.8	97.0	61	
1295	11.8	53.8	2246	277.0	268.8	35.0	13.1	12.0	8.6	13.8	97.0	61	
1296	10.0	52.5	2168	277.0	268.8	35.0	12.7	10.0	8.0	13.8	97.0	61	
1297	10.0	52.4	2173	277.0	268.8	35.0	12.6	10.4	6.6	13.8	97.0	61	
1298	11.2	53.3	2209	277.0	268.8	35.0	12.9	11.4	7.6	13.8	97.0	61	
1299	10.8	53.6	2237	277.0	270.2	35.0	13.0	9.9	5.7	13.8	97.0	61	
1300	8.2	52.6	2229	277.0	272.2	35.0	12.8	10.0	5.1	13.8	97.0	61	
1301	8.5	54.7	1700	277.0	272.2	35.0	12.7	9.5	6.2	13.8	97.0	61	
1302	8.8	53.8	1856	277.0	272.2	35.0	13.0	10.0	7.2	13.8	97.0	61	
1303	10.7	53.5	2221	277.0	272.2	35.0	13.1	10.9	6.9	13.8	97.0	61	
1304	8.7	52.9	1811	277.0	268.3	35.0	12.5	12.0	8.3	13.8	97.0	61	
1310	9.9	53.5	2149	277.0	268.3	35.0	13.1	7.3	9.1	13.8	97.0	61	
1311	8.9	53.5	1903	277.0	268.3	35.0	12.9	12.4	7.8	13.8	97.0	61	
1312	8.7	53.7	1820	277.0	268.3	35.0	12.9	9.7	7.9	13.7	97.0	61	
1313	9.8	53.4	2134	277.0	268.3	35.0	12.1	8.5	7.4	13.8	97.0	61	
1305	10.0	53.9	1653	277.0	268.3	35.0	12.8	9.8	6.0	13.7	97.0	61	
1314	10.1	53.6	2175	277.0	269.5	35.0	13.1	10.4	8.9	13.7	97.0	61	
1315	10.6	53.9	2188	277.0	268.3	35.0	13.0	7.7	13.7	97.0	61		
1316	11.7	53.7	2254	277.0	268.3	35.0	13.3	11.9	7.3	13.7	97.0	61	
1317	9.1	53.2	1977	277.0	268.3	35.0	12.8	9.5	8.0	13.7	97.0	61	
1318	8.9	52.8	1910	277.0	268.3	35.0	12.9	10.3	7.8	13.7	97.0	61	
1319	9.3	53.5	2018	277.0	268.3	35.0	13.0	10.7	6.4	13.7	97.0	61	
1320	11.6	54.3	2242	277.0	268.3	35.0	13.3	11.7	6.4	13.7	97.0	61	

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Reference Yaw Angle	Yaw Angle	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
1321	8.5	53.6	2189	277.0	268.3	35.0	12.9	8.9	6.8	13.7	97

Table E.01 Measurement data - Turbine ON

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
Report ID: 14215.01.T05.RP6

Page 9 of 9
Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording.

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording.

Table E.02 Measurement data - Background

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
Report ID: 14215.01.T05.RP6

Page 1 of 4

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
1		0.4	6.2	11	98.7	62	
2		0.4	6.2	11	98.7	62	
3		0.5	5.7	11	98.7	62	
4		0.5	6.5	11	98.7	62	
5		0.5	4.7	11	98.7	62	
6		0.4	5.9	11	98.7	62	
7		0.3	5.7	11	98.7	62	
8		0.3	6.2	11	98.7	62	
9		0.3	4.8	11	98.7	62	
10		0.3	5.3	11	98.7	62	
11		0.4	5.9	11	98.7	62	
12		0.4	5.9	11	98.7	62	
13		0.2	4.8	11	98.7	62	
14		0.2	6.8	11	98.7	62	
15		0.3	7.3	11	98.7	62	
16		0.3	5.7	11	98.7	62	
17		0.3	4.1	11	98.7	62	
18		0.3	4.8	12	98.7	61	
19		0.4	6.0	12	98.7	61	
20		0.2	5.1	12	98.7	61	
21		0.3	3.3	12	98.7	61	
22		0.3	4.5	12	98.7	61	
23		0.1	5.0	12	98.7	61	
24		0.3	2.7	12	98.7	61	
25		0.4	5.6	12	98.7	61	
26		0.2	4.8	12	98.7	61	
27		0.3	3.5	12	98.7	61	
28		0.4	4.2	12	98.7	61	
29		0.4	4.8	12	98.7	61	
30		0.2	2.7	12	98.7	61	
31		0.1	5.1	12	98.7	61	
32		0.2	4.5	12	98.7	61	
33		0.2	5.3	12	98.7	61	
34		0.2	4.7	12	98.7	61	
35		0.3	5.0	12	98.7	61	
36		0.4	4.8	12	98.7	61	
37		0.4	6.5	12	98.7	61	
38		0.3	5.7	12	98.7	61	
39		0.4	5.4	12	98.7	61	
40		0.4	5.4	12	98.7	61	
41		0.3	4.8	12	98.7	61	
42		0.3	5.6	12	98.7	59	
43		0.2	6.0	12	98.7	59	
44		0.3	5.0	12	98.7	59	
45		0.3	3.5	12	98.7	59	
46		0.3	5.8	12	98.7	59	
47		0.3	5.1	12	98.7	59	
48		0.3	7.0	12	98.7	60	
49		0.3	6.2	12	98.7	60	
50		0.3	5.3	12	98.7	60	
51		0.3	5.0	12	98.7	60	
52		0.4	5.3	12	98.7	60	
53		0.3	4.2	12	98.7	60	
54		0.3	3.6	12	98.7	60	
55		0.3	3.2	12	98.7	60	
56		0.3	5.0	12	98.7	60	
57		0.3	5.5	12	98.7	60	
58		0.3	2.6	12	98.7	60	
59		0.2	3.0	12	98.7	60	
60		0.2	3.6	12	98.7	61	
61		0.2	3.8	12	98.7	61	
62		0.4	3.5	12	98.7	61	
63		0.5	3.2	12	98.7	61	
64		0.2	6.8	12	98.7	61	
65		0.1	6.2	12	98.7	61	
66		0.3	5.9	12	98.7	59	
67		0.4	6.2	12	98.7	59	
68		0.4	5.7	12	98.7	59	
69		0.3	8.3	12	98.7	59	
70		0.2	6.5	12	98.7	59	
71		0.2	5.9	12	98.7	59	
72		0.3	5.4	12	98.7	58	
73		0.2	5.7	12	98.7	58	
74		0.3	3.8	12	98.7	58	
75		0.4	4.2	12	98.7	58	
76		0.4	5.7	12	98.7	58	
77		0.1	2.1	12	98.7	58	
78		0.2	3.0	12	98.7	61	
79		0.2	5.4	12	98.7	61	
80		0.3	6.9	12	98.7	61	
81		0.3	5.0	12	98.7	61	
82		0.3	5.4	12	98.7	61	
83		0.4	5.7	12	98.7	61	

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
84		0.3	5.0	12	98.7	59	
85		0.3	5.0	12	98.7	59	
86		0.2	2.9	12	98.7	59	
87		0.2	5.0	12	98.7	59	
88		0.3	4.2	12	98.7	59	
89		0.2	3.6	12	98.7	59	
90		0.2	3.5	12	98.7	59	
91		0.3	3.9	12	98.7	59	
92		0.4	5.4	12	98.7	59	
93		0.2	5.1	12	98.7	59	
94		0.2	4.1	12	98.7	59	
95		0.3	4.8	12	98.7	59	
96		0.4	5.4	12	98.7	59	
97		0.4	3.8	12	98.7	59	
98		0.4	4.5	12	98.7	59	
99		0.4	5.0	12	98.7	59	
100		0.3	6.0	12	98.7	59	
101		0.3	5.9	12	98.7	59	
102		0.3	5.7	12	98.7	59	
103		0.3	4.5	12	98.7	59	
104		0.6	4.8	12	98.7	59	
105		0.5	5.3	12	98.7	59	
106		0.6	3.0	12	98.7	59	
107		0.5	5.0	12	98.7	59	
108		0.3	5.9	12	98.7	59	
109		0.4	7.0	12	98.7	59	
110		0.3	6.0	12	98.7	59	
111		0.3	6.5	12	98.7	59	
112		0.3	4.1	12	98.7	59	
113		0.4	3.2	12	98.7	59	
114		0.2	5.9	12	98.7	59	
115		0.2	6.9	12	98.7	59	
116		0.1	6.6	12	98.7	59	
117		0.2	5.0	12	98.7	59	
118		0.2	5.0	12	98.7	59	
119		0.2	6.0	12	98.7	59	
120		0.2	4.8	12	98.7	58	
121		0.3	5.1	12	98.7	58	
122		0.4	5.7	12	98.7	58	
123		0.5	4.7	12	98.7	58	
124		0.4	2.7	12	98.7	58	
125		0.4	4.7	12	98.7	58	
126		0.4	2.7	12	98.7	58	
127		0.4	4.2	12	98.7	58	
128		0.3	6.5	12	98.7	58	
129		0.3	5.9	12	98.7	58	
130		0.3	5.4	12	98.7	58	
131		0.3	5.4	12	98.7	58	
132		0.4	6.5	12	98.7	58	
133		0.3	6.6	12	98.7	58	
134		0.3	5.7	12	98.7	58	
135		0.3	5.9	12	98.7	58	
136		0.4	5.0	12	98.7	58	
137		0.5	4.2	12	98.7	58	
138		0.4	4.5	12	98.7	59	
139		0.4	5.1	12	98.7	59	
140		0.3	4.8	12	98.7	59	
141		0.4	4.8	12	98.7	59	
142		0.5	5.0	12	98.7	59	
143		0.4	4.2	12	98.7	59	
144		0.4	3.2	12	98.7	59	
145		0.3	3.6	12	98.7	59	
146		0.2	4.1	12	98.7	59	
147		0.3	4.5	12	98.7	59	
148		0.2	4.5	12	98.7	59	
149		0.2	4.5	12	98.7	59	
150		0.3	3.6	12	98.7	59	
151		0.3	4.1	12	98.7	59	
152		0.4	4.4	12	98.7	59	
153		0.3	4.5	12	98.7	59	
154		0.3	3.9	12	98.7	59	
155		0.3	5.7	12	98.7	59	
156		0.3	4.8	12	98.7	58	
157		0.3	5.4	12	98.7	58	
158		0.3	5.4	12	98.7	58	
159		0.3	7.1	12	98.7	58	
160		0.4	6.2	12	98.7	58	
161		0.3	5.0	12	98.7	58	
162		0.3	3.2	12	98.6	58	
163		0.3	3.2	12	98.6	58	
164		0.2	2.6	12	98.6	58	
165		0.2	4.5	12	98.6	58	
166		0.3	5.6	12	98.6	58	
167		0.3	5.6	12	98.6	58	
168		0.3	5.3	12	98.6	58	
169		0.3	4.5	12	98.6	58	
170		0.3	4.8	12	98.6	58	
171		0.3	5.0	12	98.6	58	
172		0.3	5.4	12	98.6	58	
173		0.2	5.6	12	98.6	58	
174		0.2	1.7	12	98.6	58	
175		0.2	1.2	12	98.6	58	
176		0.5	3.0	12	98.6	58	
177		0.3	4.4	12	98		

Table E.02 Measurement data - Background

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
Report ID: 14215.01.T05.RP6

Page 2 of 4

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
250	0.6	9.8	11	99.1	32		
251	0.7	10.7	11	99.1	32		
252	0.7	6.0	11	99.1	32		
253	0.9	10.1	11	99.1	32		
254	0.5	7.0	11	99.1	32		
255	0.8	11.5	11	99.1	34		
256	0.7	11.0	11	99.1	34		
257	0.7	9.2	11	99.1	34		
258	0.7	9.5	11	99.1	34		
259	0.8	7.6	11	99.1	34		
260	0.5	12.7	11	99.1	34		
261	0.7	11.8	11	99.0	34		
262	0.7	11.6	11	99.0	34		
263	0.6	10.7	11	99.0	34		
264	0.6	9.6	11	99.0	34		
265	0.6	10.1	11	99.0	34		
266	0.6	10.2	11	99.0	34		
267	0.8	11.9	11	99.1	33		
268	0.7	12.0	11	99.1	33		
269	0.7	12.3	11	99.1	33		
270	0.6	12.9	11	99.1	33		
271	1.0	9.1	11	99.1	33		
272	0.9	11.6	11	99.1	33		
273	0.5	10.1	11	99.1	32		
274	0.7	10.7	11	99.1	32		
275	0.7	14.0	11	99.1	32		
276	0.8	10.3	11	99.1	32		
277	0.8	7.4	11	99.1	32		
278	0.7	11.7	11	99.1	32		
279	0.5	11.3	11	99.1	32		
280	0.6	13.3	11	99.1	32		
281	0.6	10.4	11	99.1	32		
282	1.0	9.2	11	99.1	32		
283	0.5	10.3	11	99.1	32		
284	0.7	7.1	11	99.1	32		
285	0.5	7.9	11	99.1	33		
286	0.4	8.6	11	99.1	33		
287	0.7	9.5	11	99.1	33		
288	0.8	9.8	11	99.1	33		
289	0.8	8.9	11	99.1	33		
290	0.9	10.7	11	99.1	33		
291	0.8	11.7	11	99.0	28		
292	0.8	10.3	11	99.0	28		
293	0.7	9.2	11	99.0	28		
294	0.7	7.4	11	99.0	28		
295	0.5	11.0	11	99.0	28		
296	0.6	12.7	11	99.0	28		
297	0.9	11.7	11	99.1	31		
298	0.9	12.4	11	99.1	31		
299	0.7	10.2	11	99.1	31		
300	0.6	6.2	11	99.1	31		
301	0.8	12.1	11	99.1	31		
302	0.3	8.7	11	99.1	31		
303	0.5	9.4	11	99.1	32		
304	0.5	10.6	11	99.1	32		
305	0.6	6.6	11	99.1	32		
306	0.5	12.8	11	99.1	32		
307	0.7	8.7	11	99.1	32		
308	0.9	8.3	11	99.1	32		
309	0.7	7.6	11	99.1	32		
310	0.7	9.5	11	99.1	32		
311	0.9	9.7	11	99.1	32		
312	0.9	9.7	11	99.1	32		
313	0.6	10.0	11	99.1	32		
314	0.8	6.9	11	99.1	32		
315	0.8	9.8	11	99.1	29		
316	0.5	6.7	11	99.1	29		
317	0.6	10.7	11	99.1	29		
318	0.8	10.2	11	99.1	29		
319	0.9	8.9	11	99.1	29		
320	0.9	11.0	11	99.1	29		
321	0.7	8.7	11	99.1	30		
322	0.8	7.4	11	99.1	30		
323	0.9	7.2	11	99.1	30		
324	1.0	10.3	11	99.1	30		
325	0.9	10.5	11	99.1	30		
326	1.0	9.8	11	99.1	30		
327	0.9	9.1	11	99.1	30		
328	0.8	12.7	11	99.1	30		
329	0.9	10.9	11	99.1	30		
330	0.9	6.6	11	99.1	30		
331	0.9	12.6	11	99.1	30		
332	0.8	11.7	11	99.1	30		

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
333			0.8	11.5	11	99.1	30
334			1	13.6	11	99.1	30
335			1.0	8.7	11	99.1	30
336			0.9	13.3	11	99.1	30
337			1.0	12.9	11	99.1	30
338			0.7	10.4	11	99.1	30
339			0.7	12.7	11	99.1	28
340			0.8	10.9	11	99.1	28
341			0.8	8.9	11	99.1	28
342			0.8	12.4	11	99.1	28
343			0.9	10.6	11	99.1	28
344			0.9	9.2	11	99.1	28
345			0.9	13.4	11	99.1	28
346			0.8	9.5	11	99.1	28
347			0.9	10.2	11	99.1	28
348			0.7	7.8	11	99.1	28
349			0.7	6.9	11	99.1	28
350			0.7	8.3	11	99.1	28
351			0.8	9.4	11	99.1	29
352			0.9	13.2	11	99.1	29
353			1.0	11.7	11	99.1	29
354			1.0	13.7	11	99.1	29
355			0.7	11.5	11	99.1	29
356			0.7	9.3	11	99.1	29
357			0.7	13.2	11	99.1	27
358			0.9	8.2	11	99.1	27
359			0.8	9.4	11	99.1	27
360			0.8	5.6	11	99.1	27
361			0.8	4.2	11	99.1	27
362			0.8	9.0	11	99.1	27
363			0.6	8.9	11	99.1	28
364			1.0	11.3	11	99.1	28
365			0.8	10.9	11	99.1	28
366			0.6	11.3	11	99.1	28
367			0.5	10.9	11	99.1	28
368			0.6	9.8	11	99.1	28
369			0.7	6.3	11	99.1	28
370			0.6	6.8	11	99.1	28
371			0.7	7.8	11	99.1	28
372			0.7	7.3	11	99.1	28
373			0.5	7.6	11	99.1	28
374			0.7	8.9	11	99.1	28
375			0.5	13.1	11	99.1	29
376			0.8	13.4	11	99.1	29
377			0.9	10.6	11	99.1	29
378			1.1	9.2	11	99.1	29
379			1.2	11.5	11	99.1	29
380			1.0	12.5	11	99.1	29
381			1.0	13.3	11	99.1	28
382			1.0	8.8	11	99.1	28
383			1.0	10.7	11	99.1	28
384			1.0	11.3	11	99.1	28
385			1.0	8.9	11	99.1	28
386			1.1	8.0	11	99.1	28
387			0.9	9.8	11	99.1	28
388			1.0	11.2	11	99.1	28
389			0.9	10.6	11	99.1	28
390			0.4	11.5	11	99.1	28
391			0.5	13.2	11	99.1	28
392			0.4	11.6	11	99.1	28
393			0.7	10.3	11	99.1	28
394			0.6	9.9	11	99.1	28
395			0.9	8.5	11	99.1	28
396			0.7	7.9	11	99.1	28
397			0.7	9.8	11	99.1	28
398			0.9	10.6	11	99.1	28
399			0.8	7.0	11	99.1	30
400			0.9	9.6	11	99.1	30
401			0.8	8.1	11	99.1	30
402			0.7	8.9	11	99.1	30
403			0.8	8.7	11	99.1	30
404			1.1	6.5	11	99.1	30
405			1.2	10.4	11	99.1	30
406			1.1	10.2	11	99.1	30
407			0.5	11.0	11	99.1	30
408			0.5	10.9	11	99.1	30
409			1.0	10.7	11	99.1	30
410			0.9	8.8	11	99.1	30
411			0.6	7.7	10	99.3	27
412			0.6	8.4	10	99.3	27
413			0.7	8.9	10	99.3	27
414			0.6	8.9	10	99.3	27
415			0.5	7.4	10	99.3	27

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
4							

Table E.02 Measurement data - Background

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
Report ID: 14215.01.T05.RP6

Page 3 of 4

Created on: 6/15/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
499		0.7	5.8	10	99.3	27	
500		0.7	7.1	10	99.3	29	
501		0.7	7.2	10	99.3	28	
502		0.5	6.9	10	99.3	28	
503		0.5	6.3	10	99.3	28	
504		0.3	6.0	10	99.3	28	
505		0.3	8.5	10	99.3	28	
506		0.4	10.4	11	99.3	28	
507		0.6	12.2	11	99.3	28	
508		0.6	9.1	11	99.3	28	
509		0.7	11.3	11	99.3	28	
510		0.7	9.7	11	99.3	28	
511		0.6	8.7	11	99.3	28	
512		0.6	8.4	11	99.3	29	
513		0.8	10.1	11	99.3	29	
514		0.9	10.9	11	99.3	29	
515		0.6	10.1	11	99.3	29	
516		0.6	7.6	11	99.3	29	
517		0.8	8.7	11	99.3	29	
518		0.9	9.8	11	99.3	29	
519		0.7	8.4	11	99.3	29	
520		0.6	10.4	11	99.3	29	
521		0.6	11.6	11	99.3	29	
522		0.6	10.4	11	99.3	29	
523		0.5	8.4	11	99.3	29	
524		0.7	9.1	10	99.3	28	
525		0.6	10.4	10	99.3	28	
526		0.8	8.4	10	99.3	28	
527		0.8	9.5	10	99.3	28	
528		0.7	9.2	10	99.3	28	
529		0.6	9.7	10	99.3	28	
530		0.5	8.3	10	99.3	29	
531		0.5	7.4	10	99.3	29	
532		0.5	7.2	10	99.3	29	
533		0.6	7.1	10	99.3	29	
534		0.6	6.0	10	99.3	29	
535		0.8	6.6	10	99.3	29	
536		0.7	5.3	10	99.3	30	
537		0.9	11.4	10	99.3	30	
538		0.5	10.6	10	99.3	30	
539		0.6	9.4	10	99.3	30	
540		0.6	9.8	10	99.3	30	
541		0.3	10.6	10	99.3	30	
542		0.5	11.1	11	99.3	29	
543		0.7	9.8	11	99.3	29	
544		0.3	9.2	11	99.3	29	
545		1.0	10.8	11	99.3	29	
546		0.9	7.5	11	99.3	29	
547		1.0	7.9	11	99.3	29	
548		0.9	7.6	10	99.3	29	
549		0.9	6.9	10	99.3	29	
550		0.8	9.4	10	99.3	29	
551		0.7	9.1	10	99.3	29	
552		0.7	7.5	10	99.3	29	
553		0.7	8.6	10	99.3	29	
554		0.7	8.2	10	99.3	29	
555		0.5	10.7	10	99.3	29	
556		0.8	10.1	10	99.3	29	
557		1.0	7.3	10	99.3	29	
558		0.7	8.4	10	99.3	29	
559		0.5	7.9	10	99.3	29	
560		0.5	8.8	10	99.3	30	
561		0.8	13.6	10	99.3	30	
562		0.7	11.0	10	99.3	30	
563		0.7	8.4	10	99.3	30	
564		0.8	8.6	10	99.3	30	
565		0.7	9.1	10	99.3	30	
566		0.7	6.9	11	99.3	30	
567		0.7	7.5	11	99.3	30	
568		0.6	8.5	11	99.3	30	
569		0.7	8.4	11	99.3	30	
570		0.6	8.0	11	99.3	30	
571		0.4	9.5	11	99.3	30	
572		0.5	8.1	11	99.3	30	
573		0.5	6.5	11	99.3	30	
574		0.6	7.9	11	99.3	30	
575		0.5	5.8	11	99.3	30	
576		0.5	5.4	11	99.3	30	
577		0.5	7.9	11	99.3	30	
578		0.4	6.9	11	99.3	30	
579		0.8	4.5	11	99.3	30	
580		0.6	7.3	11	99.3	30	
581		0.6	9.5	11	99.3	30	

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
582		0.7	8.8	11	99.3	30	
583		0	7.5	11	99.3	29	
584		0.7	9.4	11	99.3	29	
585		0.6	9.1	11	99.3	29	
586		0.8	11.2	11	99.3	29	
588		0.6	3.9	11	99.3	29	
589		0.6	8.2	11	99.3	29	
590		0.4	9.6	11	99.3	30	
591		0.5	8.6	11	99.3	30	
592		0.4	8.6	11	99.3	30	
593		0.4	10.4	11	99.3	30	
594		0.5	8.6	11	99.3	30	
595		0.5	10.2	11	99.3	30	
596		0.6	8.1	11	99.3	30	
597		0.7	6.6	11	99.3	30	
598		0.9	8.5	11	99.3	30	
599		0.8	9.9	11	99.3	30	
600		0.8	10.6	11	99.3	30	
601		0.7	8.7	11	99.3	30	
602		0.7	10.8	11	99.3	30	
603		0.6	10.9	11	99.3	30	
604		0.9	10.3	11	99.3	30	
605		1.0	7.6	11	99.3	30	
606		0.9	7.4	11	99.3	30	
607		0.7	10.1	11	99.3	30	
608		0.9	9.4	11	99.3	30	
609		0.5	8.9	11	99.3	30	
610		0.5	6.5	11	99.3	30	
611		0.6	9.5	11	99.3	30	
612		0.5	7.3	11	99.3	30	
613		0.6	8.1	11	99.3	30	
614		0.8	9.1	11	99.3	30	
615		0.5	8.1	11	99.3	30	
616		0.6	6.9	11	99.3	30	
617		0.7	6.0	11	99.3	30	
618		0.5	6.8	11	99.3	30	
619		0.5	6.0	11	99.3	30	
620		0.6	6.3	10	99.3	31	
621		0.9	6.7	10	99.3	31	
622		0.8	6.0	10	99.3	31	
623		0.7	6.0	10	99.3	31	
624		0.6	9.4	10	99.3	31	
625		0.6	10.9	11	99.3	31	
626		0.5	9.0	11	99.3	30	
627		0.6	9.5	11	99.3	30	
628		0.6	8.3	11	99.3	30	
629		0.6	5.4	11	99.3	30	
630		0.6	5.3	11	99.3	30	
631		0.7	11.9	38.9	0.1	6.1	11
632		0.6	7.6	38.1	0.2	3.9	11
633		0.6	10.0	39.5	0.2	5.1	11
634		0.6	10.2	39.4	0.1	5.3	11
635		0.5	7.0	39.9	0.2	4.7	11
636		0.6	10.0	40.3	0.3	5.5	11
637		0.6	41.8	0.3	4.9	11	
638		0.6	33.8	0.3	5.8	11	
639		0.4	38.7	0.4	3.8	11	
640		0.7	38.7	0.4	3.8	11	
641		1.1	38.9	0.1	6.1	11	
642		0.6	38.1	0.2	3.9	11	
643		0.6	39.5	0.2	5.1	11	
644		1.0	39.4	0.1	5.3	11	
645		0.2	39.9	0.2	4.7	11	
646		12.1	43.6	0.3	6.2	11	
647		9.5	41.8	0.3	4.9	11	
648		7.0	38.8	0.3	3.6	11	
649		9.2	38.4	0.4	4.7	11	
650		8.1	38.8	0.3	4.2	11	
651		7.2	38.3	0.3	3.7	11	
652		3.9	39.8	0.3	2.0	11	
653		4.3	39.8	0.3	2.2	11	
654		3.9	40.8	0.3	2.0	11	
655		3.7	40.9	0.3	1.9	11	
656		6.6	43.7	0.2	3.4	11	
657		5.7	40.8	0.2	2.9	11	
658		8.0	41.9	0.3	4.1	11	
659		5.4	42.2	0.3	2.8	11	
660		10.9	40.7	0.2	5.6	11	
661		8.6	41.1	0.3	4.4	11	
662		11.4	41.0	0.4	5.9	11	
663		7.2	39.7	0.3	3.7	11	
664		9.2	40.6	0.2	4.7	11	

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
664		0.7	8.8	11	99.3	30	

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m

Table E.02 Measurement data - Background

Project: Suncor Adelaide Wind Power Project - Turbine T05 - IEC 61400-11 Measurement
 Report ID: 14215.01.T05.RP6

Page 4 of 4

Created on: 6/15/2018

*****Blank data denotes values that were omitted in the analysis due to an extraneous event during recording**

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
748	9.2	41.6	0.4	5.3	11	98.5	-
749	11.3	42.8	0.4	5.3	11	98.3	-
750	12.8	43.1	0.4	6.6	11	98.5	-
751	6.7	43.0	0.5	3.4	11	98.5	-
752	9.7	42.8	0.5	5.0	11	98.5	-
753	8.2	41.9	0.3	4.2	11	98.5	-
754	10.0	39.7	0.3	5.1	11	98.5	-
755	11.7	42.6	0.2	6.0	11	98.5	-
756	8.2	41.6	0.2	4.2	11	98.5	-
757	8.2	43.2	0.2	4.2	11	98.5	-
758					2.3	98.5	-
759					11	98.5	-
760					9.5	98.5	-
761					5.3	98.5	-
762					4.0	98.5	-
763					5.0	98.5	-
764	7.1	41.2	0.5	3.6	11	98.5	-
765	7.2	43.6	0.4	3.7	11	98.5	-
766	7.3	44.3	0.4	3.8	11	98.5	-
767	13.0	44.7	0.3	6.7	11	98.5	-
768	13.6	42.8	0.2	7.0	11	98.5	-
769	14.7	46.0	0.3	7.6	11	98.5	-
770	10.7	42.0	0.4	5.5	11	98.5	-
771	10.4	44.2	0.4	5.2	11	98.5	-
772	8.0	44.4	0.2	4.1	11	98.5	-
773	10.2	44.0	0.2	5.2	11	98.5	-
774	10.3	44.9	0.3	5.3	11	98.5	-
775	8.3	44.5	0.3	4.3	11	98.5	-
776	7.8	43.4	0.3	4.0	11	98.5	-
777	8.1	41.5	0.3	4.2	11	98.5	-
778	6.6	40.7	0.4	3.4	11	98.5	-
779	3.8	39.9	0.3	2.0	11	98.5	-
780	4.3	41.4	0.5	2.2	11	98.5	-
781	12.2	41.8	0.5	5.3	11	98.5	-
782	6.7	44.2	0.4	3.5	11	98.5	-
783	9.1	47.4	0.5	4.7	11	98.5	-
784	6.4	46.2	0.4	3.3	11	98.5	-
785	7.9	43.1	0.2	4.1	11	98.5	-
786	7.6	45.1	0.3	3.9	11	98.5	-
787	8.8	46.3	0.6	4.5	11	98.5	-
788	8.7	45.3	0.4	4.5	11	98.5	-
789	6.2	44.4	0.4	3.2	11	98.5	-
790	4.9	43.5	0.4	2.5	11	98.5	-
791	5.5	44.0	0.5	2.8	11	98.5	-
792	7.6	42.3	0.9	3.9	11	98.5	-
793	5.6	42.0	0.9	4.1	11	98.5	-
794	6.6	41.9	1.4	3.4	11	98.5	-
795	15.9	46.1	1.7	8.2	11	98.5	-
796	14.2	49.5	2.7	7.3	11	98.5	-
797	9.1	45.5	3.6	4.7	11	98.5	-
798	8.8	47.8	4.2	4.5	11	98.5	-
799	4.8	2.2			11	98.5	-
800		5.7	5.7		11	98.5	-
801		7.1	5.9		11	98.5	-
802		8.3	7.2		11	98.5	-
803		8.7	6.5		11	98.5	-
804		8.6	4.3		11	98.5	-
805		8.6	5.9		11	98.5	-
806		9.4	7.7		11	98.5	-
807	14.3	43.9	0.6	7.4	14	97.0	63
808	9.3	43.4	0.4	4.8	14	97.0	63
809	16.5	43.2	0.5	8.5	14	97.0	62
810	13.4	43.8	0.3	6.9	14	97.0	62
811	8.2	43.9	0.4	4.2	14	97.0	62
812	9.9	42.2	0.4	5.1	14	97.0	62
813	9.9	41.8	0.3	5.1	14	97.0	62
814	12.1	42.0	0.2	5.2	14	97.0	62
815	14.2	42.8	0.4	7.3	14	97.0	62
816	11.7	43.5	0.3	6.0	14	97.0	62
817	12.1	42.1	0.5	6.2	14	97.0	62
818	12.5	44.0	0.3	6.4	14	97.0	62
819	13.1	42.3	0.3	6.8	14	97.0	62
820	11.7	42.1	0.7	6.0	14	97.0	62
821	10.1	42.7	0.7	5.2	14	97.0	62
822	12.9	42.7	0.6	6.7	14	97.0	62
823	9.9	41.6	0.7	5.1	14	97.0	62
824	12.6	42.5	0.5	6.5	14	97.0	62
825	13.0	42.3	0.4	6.7	14	97.0	62
826	10.3	42.8	0.4	5.3	14	97.0	62
827	9.1	41.4	0.5	4.7	14	97.0	62
828	7.8	40.2	0.4	4.0	14	97.0	62
829	8.0	42.9	0.4	4.1	14	97.0	62
830	11.4	42.6	0.7	5.9	14	97.0	62

*****Blank data denotes values that were omitted in the analysis due to an extraneous event during recording**

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
831	9.5	41.9	0.6	4.9	14	97.0	62
832	14.1	41.4	0.5	7.3	14	97.0	62
833	14.9	41.9	0.4	7.7	14	97.0	62
834	15.0	41.6	0.5	7.8	14	97.0	62
835	15.3	41.5	0.6	7.9	14	97.0	62
836	10.9	41.4	0.6	5.6	14	97.0	62
837	8.7	42.3	0.6	4.5	14	97.0	62
838	10.3	42.5	0.6	5.3	14	97.0	62
839	8.5	43.1	0.5	4.4	14	97.0	63
840	10.5	44.5	0.5	5.4	14	97.0	63
841	8.7	41.4	0.5	4.5	14	97.0	63
842	9.5	43.0	0.5	4.5	14	97.0	63
843	10.9	42.2	0.4	5.6	14	97.0	63
844	12.4	42.2	0.4	6.4	14	97.0	63
845	9.1	41.9	0.5	4.7	14	97.0	62
846	9.8	43.5	0.3	5.1	14	97.0	62
847	13.2	42.9	0.4	6.8	14	97.0	62
848	14.9	43.4	0.6	7.7	14	97.0	62
849	13.0	43.3	0.4	6.7	14	97.0	62
850	9.3	43.0	0.5	4.8	14	97.0	62
851	10.6	42.9	0.5	5.5	14	97.0	62
852	13.3	42.1	0.5	6.9	14	97.0	62
853	9.3	42.7	0.6	4.7	14	97.0	62
854	14.0	42.2	0.5	7.2	14	97.0	62
855	14.0	42.6	0.5	7.2	14	97.0	62
856	12.1	42.2	0.5	6.2	14	97.0	62
857	14.1	42.3	0.5	7.3	14	97.0	62
858	11.4	42.8	0.4	5.9	14	97.0	62
859	7.6	42.9	0.7	3.9	14	97.0	62
860	9.5	42.2	0.5	4.9	14	97.0	62
861	15.0	42.5	0.5	7.7	14	97.0	62
862	12.4	42.0	0.6	6.4	14	97.0	62
863	10.3	41.1	0.6	5.3	14	97.0	62
864	9.8	41.4	0.5	5.1	14	97.0	62
865	7.8	41.2	0.4	4.0	14	97.0	62
866	10.9	42.2	0.6	5.6	14	97.0	62
867	9.3	41.9	0.6	4.8	14	97.0	62
868	13.8	42.4	0.6	7.1	14	97.0	62
869	13.8	42.1	0.5	7.1	14	97.0	62
870	14.4	41.4	0.6	7.4	14	97.0	62
871	14.0	41.5	0.6	7.2	14	97.0	62
872	13.6	41.8	0.6	7.0	14	97.0	62
873	13.9	42.1	0.5	7.2	14	97.0	62
874	12.5	42.5	0.6	6.4	14	97.0	62
875	10.7	41.5	0.6	5.5	14	97.0	62
876	13.0	42.2	0.5	6.2	14	97.0	62
877	11.7	42.1	0.5	6.0	14	97.0	62
878	7.8	42.9	0.5	4.0	14	97.0	62
879	11.3	43.6	0.6	5.8	14	97.0	62
880	9.3	42.2	0.5	4.8	14	97.0	62
881	12.5	41.7	0.5	6.4	14	97.0	63
882	12.6	43.1	0.5	6.5	14	97.0	63
883	14.4	43.7	0.4	7.4	14	97.0	63
884	11.7	42.9	0.5	6.0	14	97.0	62
885	12.6	41.4	0.4	6.5	14	97.0	62
886	12.1	42.7	0.5	6.2	14	97.0	62
887	11.8	42.6	0.4	6.1	14	97.0	62
888	13.8	44.1	0.5	7.1	14	97.0	62
889	11.6	42.9	0.6	6.0	14	97.0	63
890	16.2	43.2	0.4	8.3	14	97.0	63
891	15.1	44.5	0.5	7.8	14	97.0	63
892	13.4	43.2	0.6	6.9	14	97.0	63
893	12.6	42.3	0.6	6.5	14	97.0	63
894	12.6	42.3	0.6	6.5	14	97.0	63
895	12.1	43.6	0.5	6.2	14	97.0	63
896	12.4	43.0	0.8	6.4	14	97.0	63
897	13.9	42.2	0.5	7.2	14	97.0	63
898	10.7	43.6	0.5	4.4	14	97.0	63
899							
900							
901	8.5	43.4	0.5	4.3	14	97.0	63
902							
903	12.6	42.3	0.6	6.5	14	97.0	

Appendix F

Calibration Certificates

Certificate number: **1-947579110**

Calibration report

- 'As Found data' -

Product type: LMS SCADAS

Calibration Suite: **Calibration Software**
Calibration Suite Version: **2.0**

Customer:

Company name : Aercoustics Engineering
Division / department : Aercoustics Engineering
Location (city / country) : Toronto Canada
Contact person : Mr. Rob Jozwiak

System:

System type(s) : SCR05
Serial number(s) : 53103922

Calibration conditions:

Location (factory, office or on-site) : Factory
Date : 04-June-2014
Ambient temperature : 22.7°C
Previous calibration date : Mar-2014

Calibration results (refer to page 2 for details):

Calibration successful : YES
Within published specification : YES
Within test specification : YES

Report approved by:

Name : Mr. A v Aalst



West Caldwell Calibration Laboratories Inc.

Certificate of Calibration

for

MICROPHONE UNIT

Manufactured by: BRUEL & KJAER
Model No: 4189-A-021
Serial No: 2622170
Calibration Recall No: 24274

Submitted By:

Customer:

Company: AERCOUSTICS ENGINEERING
Address:

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. 4189-A-021 BRUE

Upon receipt for Calibration, the instrument was found to be:

Within (X) see attached Report of Calibration.

the tolerance of the indicated specification.

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by:

Calibration Date: 16-Jun-14

FC

Certificate No: 24274 - 3

Felix Christopher (QA Mgr.)
ISO/IEC 17025:2005

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

West Caldwell
Calibration
Laboratories, Inc.
uncompromised calibration
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

for

Brüel & Kjær Microphone Unit Model No.: 4189-A-021
Mic. Model: 4189
Preampl. Model No.: 2671

Serial No.: 2622170
Serial No.: 2625197
Serial No.: 2614901
I. D. No.: XXXX

Company : Aercoustics Engineering

Calibration results:	Before data:	After data:
Combined Sensitivity @ 250 Hz and pressure of 99.622 kPa	Before & after data same: ...✓...	
(Sensitivity with microphone and preamplifier.)	Ambient Temperature: 21 °C	
-26.67 dB re.1V/Pascal	Ambient Humidity: 51.8 % RH	
46.39 mV/Pascal	Ambient Pressure: 99.62 kPa	
0.67 Ko (- dB re 50 mV/Pascal)	Calibration Date: 16-Jun-2014	
Sensitivity: Pass	Re-calibration Due: 16-Jun-2015	
Freq. Response: Pass	Report Number: 24274 -3	
All tests: Pass	Control Number: 24274	
Combined Sensitivity @ 1000 Hz	-26.74 dB re.1V/Pascal or 46.03 mV/Pascal	


The above listed instrument meets or exceeds the tested manufacturer's specifications.

This Calibration is traceable through NIST test numbers: 683/281764-12

The expanded uncertainty of calibration: 0.18dB at 95% confidence level with a coverage factor of k=2.

The lower curve is the pressure response recorded with electrostatic actuator.

Frequency Response



The above listed instrument was checked using calibration procedure documented in West Caldwell Calibration Laboratories Inc. procedure : **Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4189A021B&K**

Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures

intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008 ISO 17025

Measurements performed by:

Felix Christopher

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4189A021B&K

West Caldwell Calibration Laboratories Inc.

1575 State Route 96, Victor NY 14564

Tel. (585) 586-3900 FAX (585) 586-4327

Calibration Data Record

for

Brüel & Kjær Microphone Unit Model No.: 4189-A-021

Serial No.: 2622170

I. D. No.: XXXX

Company : Aercoustics Engineering

Frequency Response (Reference = 0 dB @ 250Hz)

Frequency [Hz]	Actuator [dB]	Random (dB)	Free Field (dB)	Frequency [Hz]	Actuator [dB]	Random (dB)	Free Field (dB)
19.95	-0.70	-0.70	-0.70	631.0	-0.03	-0.03	0.00
25.12	-0.47	-0.47	-0.47	794.3	-0.04	-0.04	0.02
31.62	-0.28	-0.28	-0.28	1000.0	-0.07	-0.09	0.03
39.81	-0.15	-0.15	-0.15	1258.9	-0.11	-0.15	0.03
50.12	-0.05	-0.05	-0.05	1584.9	-0.19	-0.24	0.03
63.10	0.00	0.00	0.00	1995.3	-0.30	-0.30	0.03
79.43	0.01	0.01	0.01	2511.9	-0.47	-0.44	0.00
100.00	0.01	0.01	0.01	3162.3	-0.73	-0.70	-0.02
125.89	0.00	0.00	0.00	3981.1	-1.13	-1.04	-0.07
158.49	0.01	0.01	0.01	5011.9	-1.69	-1.55	-0.12
199.53	0.02	0.02	0.02	6309.6	-2.45	-2.13	-0.17
251.19	0.00	0.00	0.00	7943.3	-3.44	-2.69	-0.06
316.23	0.02	0.02	0.02	10000.0	-4.87	-3.34	0.25
398.11	-0.01	-0.01	0.00	12589.3	-6.46	-3.95	0.73
501.19	-0.01	-0.01	0.01	15848.9	-7.24	-4.66	1.35
				19952.6	-8.88	-6.40	1.17

Frequency Response: Expanded Uncertainty (dB) with coverage factor K = 2

20 to 25 Hz 0.8dB, 25 to 160 Hz 0.5dB, 160 to 2kHz 0.3dB, 2k to 10kHz 0.5dB, 10k to 20kHz 1.3dB.

Instruments used for calibration:			Date of Cal.	Traceability No.	Re-cal. Due Date
Brüel & Kjær	4134	S/N 1942286	2-Oct-2013	683/281764-12	3-Oct-2014
HP	34401A	S/N 36064102	8-Oct-2013	,287708	8-Oct-2014
HP	34401A	S/N 36102471	8-Oct-2013	,287708	8-Oct-2014
HP	33120A	S/N 36043716	8-Oct-2013	,287708	8-Oct-2014
Brüel & Kjær	2636	S/N 1324082	3-Oct-2013	683/281764-12	3-Oct-2014
Brüel & Kjær	2669	S/N 1835082	3-Oct-2013	683/281764-12	3-Oct-2014
Brüel & Kjær	4228	S/N 1742061	2-Oct-2013	683/281764-12	3-Oct-2014

Cal. Date: 16-Jun-2014

Tested by: Felix Christopher

Calibrated on WCCL system type 9700

This document shall not be reproduced except in full without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4189A021B&K

West Caldwell Calibration Laboratories Inc.

Certificate of Calibration

for

ACOUSTICAL CALIBRATOR

Manufactured by: BRUEL & KJAER
Model No: 4231
Serial No: 2513184
Calibration Recall No: 25471

Submitted By:

Customer:

Company: Aeroustics Engineering, LTD.
Address:

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. 4231 BRUE

Upon receipt for Calibration, the instrument was found to be:

Within (X)

tolerance of the indicated specification. See attached Report of Calibration.

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by:

Calibration Date: 01-Jul-15

F

Certificate No: 25471 - 1

Felix Christopher (QA Mgr.)
ISO/IEC 17025:2005

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

West Caldwell
Calibration
Laboratories, Inc.
uncompromised calibration
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01



REPORT OF CALIBRATION

Brüel & Kjær Acoustical Calibrator

for
Model No.: 4231

Serial No.: 2513184

Company : Aercoustics Engineering, LTD.

I. D. No: XXXX

Calibration results:

Sound Pressure Level at 999.9 Hz and pressure of 1013 hPa (mbar)
was 114.0 dB re 20µPa

(Calibrator tested with 1/2" adaptor UC 0210)

IEC 1094-4 Type WS 2 P Microphone was used for measurement.

	114dB	94dB
Sound Pressure Level:	Pass	Pass
Frequency:	Pass	Pass
Distortion:	Pass	Pass
Stability:	Pass	Pass
All tested parameters:		Pass

Before data: After data:

Before & after data same: ...X...

Laboratory Environment:

Ambient Temperature:	22.3	°C
Ambient Humidity:	49.4	% RH
Ambient Pressure:	98.407	kPa
Calibration Date:	1-Jul-2015	
Re-calibration Due:	1-Jul-2016	
Report Number:	25471 -1	
Control Number:	25471	

The above listed instrument meets or exceeds the tested manufacturer's specifications


The IEC 942:1988 Class 1 specifications, passed.

The ANSI S1.4-1984 specifications, passed.

This Calibration is traceable through NIST test numbers: 683/284413-14

The expanded uncertainty of calibration: 0.09dB at 95% confidence level with a coverage factor of k=2.

Graph represents six samples of Sound Pressure Level measured at 5sec. interval.



The above listed instrument was checked using calibration procedure documented in West Caldwell Calibration Laboratories Inc. procedure :

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&K

Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures

intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Cal. Date: 1-Jul-2015

Measurements performed by:

Calibrated on WCCL system type 9700

Joanne Lemmon

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&K

West Caldwell Calibration Laboratories Inc.

1575 State Route 96, Victor NY 14564

Tel. (585) 586-3900 FAX (585) 586-4327

Calibration Data Record

Brüel & Kjær Acoustical Calibrator

for
Model No.: 4231

Serial No.: 2513184

Company : Aeracoustics Engineering, LTD.

All tested parameters: Pass

Measured Sound Pressure Level (Six samples measured at 5 sec. interval)

Sample	1	114.04 dB re 20μPa	94.02 dB re 20μPa
	2	114.04	94.03
	3	114.04	94.03
	4	114.04	94.03
	5	114.04	94.02
	6	114.04	94.02
Average		114.0 Spec. 114dB ± 0.2dB	94.0 Spec. 94dB ± 0.2dB

Frequency measured (Three samples at 30 sec. Interval)

Sample	1	999.95 Hz	999.95 Hz
	2	999.95	999.94
	3	999.95	999.93
Average		999.95	999.94 Spec. 1000Hz ±0.1%

The Frequency expanded uncertainty of calibration:45μHz/Hz at 95% confidence level with a coverage factor of k=2.

Distortion measured -51.3 dB -47.5 dB Spec. ≤-40dB

Instruments used for calibration:			Date of Cal.	Traceability No.	Re-cal. Due Date
Brüel & Kjær	4231	S/N 2205493	3-Oct-2014	683/284413-14	4-Oct-2015
Brüel & Kjær	4134	S/N 1942286	3-Oct-2014	683/284413-14	4-Oct-2015
Brüel & Kjær	2669	S/N 1835082	3-Oct-2014	683/284413-14	3-Oct-2015
HP	34401A	S/N 36064102	6-Oct-2014	,287708	6-Oct-2015
Brüel & Kjær	2636	S/N 1324082	6-Oct-2014	683/284413-14	6-Oct-2015
HP	33120A	S/N 36043716	6-Oct-2014	,287708	6-Oct-2015

Cal. Date: 1-Jul-2015

Tested by: Joanne Lemmon

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&K



SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.999.3309 • Fax 802.735.9106 • www.sohwind.com

CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

Certificate number: 13.US1. 09043

Date of issue: November 25, 2013

Type: Vaisala Weather Transmitter, WXT520

Serial number: G4420002

Manufacturer: VAISALA Oyj, Pl 26, FIN-00421 Helsinki, Finland

Client: Aercoustics Engineering Ltd., 50 Ronson Dr, Suite 165, Toronto, ON M9W 1B3, Canada

Anemometer received: November 19, 2013

Anemometer calibrated: November 22, 2013

Calibrated by: rps

Calibration procedure: IEC 61400-12-1:2005(E) Annex F
(at 0°)

Certificate prepared by: R. Paul Smith

Approved by: Calibration engineer, rds

Calibration equation obtained: v [m/s] = 1.0070 · m/s output + 0.00704

Standard uncertainty, slope: N/A

Standard uncertainty, offset: N/A

Covariance: N/A

Coefficient of correlation: N/A

Absolute maximum deviation: 0.062 m/s at 11.022 m/s

Barometric pressure: 1003.7 hPa

Relative humidity: 23.8%




Standard: ISO/IEC 17025

AC-1746

Succession	Direction	Temperature in		Wind velocity, v , [m/s]	Speed Signal, I_1 [A]	Uncertainty, u_c ($k=2$) [m/s]	Deviation, d , [m/s]	Direction Signal, I_2 [A]
		α [°] ¹	wind tunnel [°C]					
2	0	22.3	26.5	4.233	4.2	0.045	-0.003	0
4	0	22.3	26.5	5.059	5.0	0.038	0.017	0
6	0	22.3	26.5	5.948	5.9	0.033	0.000	0
8	0	22.3	26.5	6.977	6.9	0.029	0.022	0
10	0	22.3	26.5	8.056	8.0	0.026	-0.007	0
12	0	22.3	26.5	9.017	9.0	0.024	-0.053	0
13-last	0	22.3	26.5	10.022	9.9	0.023	0.045	0
11	0	22.3	26.5	11.022	11.0	0.022	-0.062	359
9	0	22.3	26.5	11.999	11.9	0.022	0.009	0
7	0	22.3	26.5	12.901	12.8	0.022	0.004	0
5	0	22.3	26.5	13.943	13.8	0.022	0.039	0
3	0	22.3	26.5	15.002	14.9	0.023	-0.009	0
1-first	0	22.2	26.5	15.917	15.8	0.024	0.000	0

¹Wind Direction measurements are not included in the ISO 17025 scope for SOH Wind Engineering and, therefore, not certified.





SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.999.3309 • Fax 802.735.9106 • www.sohwind.com

EQUIPMENT USED

Serial Number	Description
Njord 1	Wind tunnel, blockage factor = 1.0035
2254	Control cup anemometer
-	Mounting tube, D = 25 mm
TT001	Summit RT-AUI, wind tunnel
TP001	Summit RT-AUI, differential pressure box
DP006	Setra Model 239 pressure transducer
HY002	Dwyer Instruments RHP-2D20 humidity transmitter
BP002	Setra Model 278 barometer
PL3	Pitot tube
XB001	Computer Board. 16 bit A/D data acquisition board
9PRZRW1	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Hayes Instrument Service, Inc., TRANSCAT, Atlantic Scale, & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.





Photo of the wind tunnel setup. The cross-sectional area is 2.5 x 2.5 m.



Standard: ISO/IEC 17025

UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ($k=2$) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.DC.016-00 for further details.

Certificate number: 13.US1. 09043



SOH Wind Engineering LLC

141 Leroy Road · Williston, VT 05495 · USA

Tel 802.999.3309 · Fax 802.735.9106 · www.sohwind.com

CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

Certificate number: 13.US1. 09045

Date of issue: November 25, 2013

Type: Vaisala Weather Transmitter, WXT520

Serial number: G4420002

Manufacturer: VAISALA Oyj, Pl 26, FIN-00421 Helsinki, Finland

Client: Aercoustics Engineering Ltd., 50 Ronson Dr, Suite 165, Toronto, ON M9W 1B3, Canada

Anemometer received: November 19, 2013

Anemometer calibrated: November 22, 2013

Calibrated by: rps

Calibration procedure: IEC 61400-12-1:2005(E) Annex F
(at 90°)

Certificate prepared by: R. Paul Smith

Approved by: Calibration engineer, rds

Robert D. Hardesty

Calibration equation obtained: v [m/s] = 1.0347 · m/s output + 0.12046

Standard uncertainty, slope: N/A

Standard uncertainty, offset: N/A


Covariance: N/A

Coefficient of correlation: N/A

Absolute maximum deviation: 0.173 m/s at 12.890 m/s

Barometric pressure: 1002.5 hPa

Relative humidity: 23.9%




AC-1746

Standard: ISO/IEC 17025

Succession	Direction	Temperature in		Wind velocity, v_r	Speed Signal I_1	Uncertainty $u_c(k=2)$	Deviation d	Direction Signal, I_2
		α [°] ¹	wind tunnel [°C]	d.p. box [°C]	[m/s]	[A]	[m/s]	[A]
2	0	22.4	26.6	4.242	4.0	0.045	-0.008	91
4	0	22.4	26.6	5.061	4.8	0.038	-0.015	92
6	0	22.5	26.6	5.957	5.7	0.033	-0.049	92
8	0	22.5	26.6	6.989	6.6	0.029	0.055	92
10	0	22.5	26.6	8.030	7.7	0.026	-0.041	92
12	0	22.4	26.6	9.035	8.6	0.024	0.035	92
13-last	0	22.4	26.6	10.026	9.6	0.023	-0.006	91
11	0	22.4	26.6	11.036	10.6	0.022	-0.028	92
9	0	22.4	26.6	12.007	11.5	0.022	0.013	92
7	0	22.4	26.6	12.890	12.2	0.022	0.173	92
5	0	22.4	26.6	13.933	13.4	0.023	-0.023	92
3	0	22.4	26.6	15.026	14.5	0.023	-0.065	92
1-first	0	22.4	26.6	15.877	15.3	0.024	-0.041	92

¹Wind Direction measurements are not included in the ISO 17025 scope for SOH Wind Engineering and, therefore, not certified.





SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.999.3309 • Fax 802.735.9106 • www.sohwind.com

EQUIPMENT USED

Serial Number	Description
Njord 1	Wind tunnel, blockage factor = 1.0035
2254	Control cup anemometer
-	Mounting tube, D = 25 mm
TT001	Summit RT-AUI, wind tunnel
TP001	Summit RT-AUI, differential pressure box
DP006	Setra Model 239 pressure transducer
HY002	Dwyer Instruments RHP-2D20 humidity transmitter
BP002	Setra Model 278 barometer
PL3	Pitot tube
XB001	Computer Board. 16 bit A/D data acquisition board
9PRZRW1	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Hayes Instrument Service, Inc., TRANSCAT, Atlantic Scale, & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.




Photo of the wind tunnel setup. The cross-sectional area is 2.5 x 2.5 m.



Standard: ISO/IEC 17025

UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ($k=2$) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.DC.016-00 for further details.

Certificate number: 13.US1.09045



SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.999.3309 • Fax 802.735.9106 • www.sohwind.com

CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

Certificate number: 13.US1. 09046

Date of issue: November 25, 2013

Type: Vaisala Weather Transmitter, WXT520

Serial number: G4420002

Manufacturer: VAISALA Oyj, Pl 26, FIN-00421 Helsinki, Finland

Client: Aeroustics Engineering Ltd., 50 Ronson Dr, Suite 165, Toronto, ON M9W 1B3, Canada

Anemometer received: November 19, 2013

Anemometer calibrated: November 22, 2013

Calibrated by: rps

Calibration procedure: IEC 61400-12-1:2005(E) Annex F
(at 270°¹)

Certificate prepared by: R. Paul Smith

Approved by: Calibration engineer, rds

Calibration equation obtained: v [m/s] = 1.0229 · m/s output + 0.03701

Standard uncertainty, slope: N/A

Standard uncertainty, offset: N/A

Covariance: N/A

Coefficient of correlation: N/A

Absolute maximum deviation: 0.061 m/s at 10.021 m/s

Barometric pressure: 1002.2 hPa

Relative humidity: 24.0%




Standard: ISO/IEC 17025

AC-1746

Page 1 of 4

Succession	Direction	Temperature in		Wind velocity, v	Speed Signal I ₁	Uncertainty u_c ($k=2$)	Deviation d.	Direction Signal, I ₂
		α [°] ¹	wind tunnel [°C]	d.p. box [°C]	[m/s]	[A]	[m/s]	[A]
2	270	22.5	26.6	4.247	4.1	0.045	0.016	272
4	270	22.5	26.6	5.063	4.9	0.038	0.013	271
6	270	22.5	26.6	5.936	5.8	0.033	-0.034	272
8	270	22.5	26.6	6.974	6.8	0.029	-0.019	272
10	270	22.5	26.6	8.042	7.8	0.026	0.026	272
12	270	22.5	26.6	9.029	8.8	0.024	-0.010	271
13-last	270	22.5	26.6	10.021	9.7	0.023	0.061	272
11	270	22.5	26.6	11.038	10.8	0.022	-0.046	271
9	270	22.5	26.6	12.001	11.7	0.022	-0.004	272
7	270	22.5	26.6	12.897	12.6	0.022	-0.029	272
5	270	22.5	26.6	13.935	13.6	0.022	-0.014	272
3	270	22.5	26.6	15.007	14.6	0.023	0.035	272
1-first	270	22.4	26.6	15.899	15.5	0.024	0.006	272

¹Wind Direction measurements are not included in the ISO 17025 scope for SOH Wind Engineering and, therefore, not certified.





SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.999.3309 • Fax 802.735.9106 • www.sohwind.com

EQUIPMENT USED

Serial Number	Description
Njord 1	Wind tunnel, blockage factor = 1.0035
2254	Control cup anemometer
-	Mounting tube, D = 25 mm
TT001	Summit RT-AUI, wind tunnel
TP001	Summit RT-AUI, differential pressure box
DP006	Setra Model 239 pressure transducer
HY002	Dwyer Instruments RHP-2D20 humidity transmitter
BP002	Setra Model 278 barometer
PL3	Pitot tube
XB001	Computer Board. 16 bit A/D data acquisition board
9PRZRW1	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Hayes Instrument Service, Inc., TRANSCAT, Atlantic Scale, & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.




Photo of the wind tunnel setup. The cross-sectional area is 2.5 x 2.5 m.



AC-1746

Standard: ISO/IEC 17025

UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ($k=2$) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.DC.016-00 for further details.

Certificate number: 13.US1. 09046



SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.999.3309 • Fax 802.735.9106 • www.sohwind.com

CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

Certificate number: 13.US1. 09044

Date of issue: November 25, 2013

Type: Vaisala Weather Transmitter, WXT520

Serial number: G4420002

Manufacturer: VAISALA Oyj, Pl 26, FIN-00421 Helsinki, Finland

Client: Aeroustics Engineering Ltd., 50 Ronson Dr, Suite 165, Toronto, ON M9W 1B3, Canada

Anemometer received: November 19, 2013

Anemometer calibrated: November 22, 2013

Calibrated by: rps

Calibration procedure: IEC 61400-12-1:2005(E) Annex F
(at 180°^o)

Certificate prepared by: R. Paul Smith

Approved by: Calibration engineer, rds

Calibration equation obtained: v [m/s] = 1.0168 · m/s output + 0.08458

Standard uncertainty, slope: N/A

Standard uncertainty, offset: N/A


Covariance: N/A

Coefficient of correlation: N/A

Absolute maximum deviation: 0.083 m/s at 10.083 m/s

Barometric pressure: 1002.9 hPa




Relative humidity: 23.7%



Standard: ISO/IEC 17025

Succession	Direction	Temperature in		Wind velocity, v .	Speed Signal I ₁	Uncertainty u_c ($k=2$)	Deviation d.	Direction Signal, I ₂
		α [°] ¹	wind tunnel [°C]	d.p. box [°C]	[m/s]	[A]	[m/s]	[A]
2	180	22.3	26.5	4.240	4.1	0.045	-0.013	182
4	180	22.3	26.5	5.063	4.9	0.038	-0.004	182
6	180	22.3	26.5	5.951	5.8	0.033	-0.031	182
8	180	22.3	26.5	6.985	6.8	0.029	-0.014	182
10	180	22.3	26.5	8.044	7.8	0.026	0.029	182
12	180	22.3	26.5	9.027	8.8	0.024	-0.006	181
13-last	180	22.3	26.5	10.030	9.7	0.023	0.083	182
11	180	22.3	26.5	11.022	10.8	0.022	-0.044	182
9	180	22.3	26.5	11.995	11.7	0.022	0.014	182
7	180	22.3	26.5	12.922	12.6	0.022	0.025	182
5	180	22.3	26.5	13.937	13.6	0.022	0.024	182
3	180	22.3	26.5	15.012	14.7	0.023	-0.020	182
1-first	180	22.2	26.5	15.904	15.6	0.024	-0.043	182

¹Wind Direction measurements are not included in the ISO 17025 scope for SOH Wind Engineering and, therefore, not certified.





SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.999.3309 • Fax 802.735.9106 • www.sohwind.com

EQUIPMENT USED

Serial Number	Description
Njord 1	Wind tunnel, blockage factor = 1.0035
2254	Control cup anemometer
-	Mounting tube, D = 25 mm
TT001	Summit RT-AUI, wind tunnel
TP001	Summit RT-AUI, differential pressure box
DP006	Setra Model 239 pressure transducer
HY002	Dwyer Instruments RHP-2D20 humidity transmitter
BP002	Setra Model 278 barometer
PL3	Pitot tube
XB001	Computer Board. 16 bit A/D data acquisition board
9PRZRW1	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Hayes Instrument Service, Inc., TRANSCAT, Atlantic Scale, & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.




Photo of the wind tunnel setup. The cross-sectional area is 2.5 x 2.5 m.



AC-1746

Standard: ISO/IEC 17025

UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ($k=2$) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.DC.016-00 for further details.

Certificate number: 13.US1. 09044

CERTIFICATE OF CALIBRATION

Customer: AEROCOUSTICS ENGINEERING LTD
50 RONSON DRIVE
SUITE 165
TORONTO, ON M9W 1B3

Cert/SO Nbr: 33-8Z881-1-1
Manufacturer: Nokeval
Model Nbr: 7470

Customer Nbr: 9-322110-000
PO Nbr: C022414
Date Received: February 24, 2014

Date Completed: March 11, 2014
Due Date: March 11, 2015

Description: Serial to Analog Converter
Serial Nbr: A159784
ID Nbr: NONE
Unit Barcode: 901B0150195

Calibrated To: Manufacturer Specification
Calibration Proc: 1-AC58014-0
Item Received: In Tolerance
Item Returned: In Tolerance

Transcat Calibration Laboratories have been audited and found in compliance with ISO/IEC 17025 2005. Accredited calibrations performed within the Lab's Scope of Accreditation are indicated by the presence of the Accrediting Body's Logo and Certificate Number on this Certificate of Calibration. Any measurements on an accredited calibration not covered by that Lab's Scope are listed in the notes section of the certificate. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

Transcat calibrations, as applicable, are performed in compliance with the requirements of ISO 9001:2008, ISO TS16949, ANSI/NCSL Z540-1994, and ISO 10012-1992. When specified contractually, the requirements of 10CFR21, 10CFR50 App. B and NQA-1 are also covered.

Traceability includes no less than An unbroken chain of comparison, realization of SI units, measurement uncertainty, documentation, competence, periodic recalibration, and measurement assurance. Transcat documents the traceability of measurements to the SI units through the National Institute of Standards and Technology (NIST) or the National Research Council of Canada (NRC), or other recognized national measurement institutes (NMI's) or international standard bodies, or to measurable conditions created in our laboratory, or accepted fundamental and/or natural physical constants, ratio type of calibration, or by comparison to consensus standards. The specific path of traceability for the reported measurement results is maintained at the Transcat facility and is available there for review.

Complete records of work performed are maintained by Transcat and are available for inspection. Laboratory standards used in the performance of this calibration are shown on the Supplemental Report.

The results in this report relate only to the item calibrated or tested, and the determination of in or out of tolerance is specific to the model/serial no. referenced above based on the tolerances shown on the supplemental report; these tolerances are either the original equipment manufacturer's (OEM's) warranted specifications or the client's requested specifications.

The applied uncertainty is the uncertainty of the calibration process. The Test Uncertainty Ratio (TUR) is calculated as per NCSL International RP-9, section 8.2. All calibrations have been performed using processes having a TUR of 4:1 or better (3:1 for mass calibrations), unless otherwise noted on the Supplemental Report. Uncertainties have been estimated at a 95 percent confidence level ($k=2$). Calibration at a 4:1 TUR (or greater) provides reasonable confidence that the instrument is within the stated tolerances. For measuring instruments, in order to consider the contribution to the uncertainty from reproducibility of the unit under test (UUT), add 0.6 of the UUT's least significant digit to the reported uncertainty. For mass calibrations. Conventional mass referenced to 8.0 g/cm³.

Any number of factors can cause a unit to drift out of tolerance at any time following its calibration. Limitations on the uses of this instrument are detailed in the OEM's operating instructions.

Notes:**Calibrated At:**

4043 Carling Avenue
Ottawa, ON K2K 2A4
By: Shabeба Bucknor

Digitally Signed On March 11, 2014

Facility Responsible:

4043 Carling Avenue
Ottawa, ON K2K 2A4
613-591-8140

Digitally Signed By Keith Powell

Date: March 11, 2014

Keith Powell
Lab Manager

Revision 0

This certificate may not be reproduced except in full, without the written approval of Transcat. Additional information, if applicable may be included on separate report(s).

F0011R24 1/27/14

Certificate - Page 1 of 1

SUPPLEMENTAL REPORT FOR 33-8Z881-1-1

CALIBRATION LAB DATA AS FOUND / AS LEFT

Service Order Nbr:	33-8Z881-1-1	Mfg:	Nokeval
Description:	Serial to Analog Converter	Model:	7470
Serial:	A159784		
Customer:	AEROACOUSTICS ENGINEERING LTD		
Calibrated:	March 11, 2014	PO Nbr:	C022414
Date Due:	March 11, 2015	ID Nbr:	NONE
Service Type:	R9	Calibration Proc:	1-AC58014-0
Description	Setpoints	Accuracy	Low Limit
			High Limit
			As Found / As Left
			Q
			Uncertainty (k=2; ±)
			TUR
DC Current % Source - 4-20mA Ch #1			
4 - 20mA	0%	±(0.1% Span)	3.984
	25%	±(0.1% Span)	7.984
	50%	±(0.1% Span)	11.984
	75%	±(0.1% Span)	15.984
	100%	±(0.1% Span)	19.984
DC Current % Source - 4-20mA Ch #2			
4 - 20mA	0%	±(0.1% Span)	3.984
	25%	±(0.1% Span)	7.984
	50%	±(0.1% Span)	11.984
	75%	±(0.1% Span)	15.984

The reported uncertainty is the uncertainty of the calibration process. For measuring instruments, add 0.6 of the least significant digit to the reported uncertainty to obtain the measurement uncertainty of the unit under test at the specific test point.

Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT

Field not applicable.
Calibration Lab Data Report - Page 1 of 7

FM02IRI 1/27/14 Service Order Nbr: 33-8Z881-1-1

SUPPLEMENTAL REPORT FOR 33-8Z881-1-1

CALIBRATION LAB DATA AS FOUND / AS LEFT

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	8	Uncertainty (k=2; ±)	TUR
	100%	±(0.1% Span)	19.984	20.016	19.999 mA	1.4e-003 mA		11.4 : 1
DC Current % Source - 4-20mA Ch #3								
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	3.995 mA	1.6e-004 mA		100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	7.995 mA	2.7e-004 mA		59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	11.996 mA	1.1e-003 mA		14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.002 mA	1.3e-003 mA		12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.002 mA	1.4e-003 mA		11.4 : 1
DC Current % Source - 4-20mA Ch #4								
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	3.997 mA	1.6e-004 mA		100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	7.995 mA	2.7e-004 mA		59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	11.999 mA	1.1e-003 mA		14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	15.998 mA	1.3e-003 mA		12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.002 mA	1.4e-003 mA		11.4 : 1
DC Current % Source - 0-20mA Ch #1								
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.000 mA	9.2e-007 mA		100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	4.997 mA	1.9e-004 mA		100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	9.998 mA	3.2e-004 mA		62.5 : 1
	75%	±(0.1% Span)	14.980	15.020	14.998 mA	1.2e-003 mA		16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	19.998 mA	1.4e-003 mA		14.3 : 1

The reported uncertainty is the uncertainty of the calibration process. For measuring instruments, add 0.6 of the least significant digit to the reported uncertainty to obtain the measurement uncertainty of the unit under test at the specific test point.
Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Calibration Lab Data Report - Page 2 of 7
Field not applicable.

SUPPLEMENTAL REPORT FOR 33-8Z881-1-1

CALIBRATION LAB DATA AS FOUND / AS LEFT

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	$\frac{\delta}{\text{Span}}$	Uncertainty ($k=2; \pm$)	TUR
DC Current % Source - 0-20mA Ch #2								
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.000 mA		9.2e-007 mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	4.996 mA		1.9e-004 mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	10.000 mA		3.2e-004 mA	62.5 : 1
	75%	±(0.1% Span)	14.980	15.020	15.000 mA		1.2e-003 mA	16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	19.999 mA		1.4e-003 mA	14.3 : 1
DC Current % Source - 0-20mA Ch #3								
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.000 mA		9.2e-007 mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	4.995 mA		1.9e-004 mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	9.995 mA		3.2e-004 mA	62.5 : 1
	75%	±(0.1% Span)	14.980	15.020	14.997 mA		1.2e-003 mA	16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	20.002 mA		1.4e-003 mA	14.3 : 1
DC Current % Source - 0-20mA Ch #4								
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.000 mA		9.2e-007 mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	4.992 mA		1.9e-004 mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	9.997 mA		3.2e-004 mA	62.5 : 1
	75%	±(0.1% Span)	14.980	15.020	14.996 mA		1.2e-003 mA	16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	20.002 mA		1.4e-003 mA	14.3 : 1
DC Voltage % Source - 0-5V Ch#1								

The reported uncertainty is the uncertainty of the calibration process. For measuring instruments, add 0.6 of the least significant digit to the reported uncertainty to obtain the measurement uncertainty of the unit under test at the specific test point.

Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Field not applicable.

Calibration Lab Data Report - Page 3 of 7

FWI2IRI 1/27/14 Service Order Nbr: 33-8Z881-1-1

SUPPLEMENTAL REPORT FOR 33-8Z881-1-1

CALIBRATION LAB DATA AS FOUND / AS LEFT

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	8	Uncertainty (k=2; ±)	TUR
0 -5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0004 V	5.0e-007 V		100.0 : 1
	20%	±(0.1% Span)	0.9950	1.0050	1.0006 V	5.5e-006 V		100.0 : 1
	40%	±(0.1% Span)	1.9950	2.0050	1.9990 V	1.1e-005 V		100.0 : 1
	60%	±(0.1% Span)	2.9950	3.0050	2.9969 V	1.6e-005 V		100.0 : 1
	80%	±(0.1% Span)	3.9950	4.0050	3.9981 V	2.1e-005 V		100.0 : 1
	100%	±(0.1% Span)	4.9950	5.0050	4.9970 V	2.6e-005 V		100.0 : 1
DC Voltage % Source - 0-5V Ch#2								
0 -5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0016 V	5.0e-007 V		100.0 : 1
	20%	±(0.1% Span)	0.9950	1.0050	0.9993 V	5.5e-006 V		100.0 : 1
	40%	±(0.1% Span)	1.9950	2.0050	1.9998 V	1.1e-005 V		100.0 : 1
	60%	±(0.1% Span)	2.9950	3.0050	2.9979 V	1.6e-005 V		100.0 : 1
	80%	±(0.1% Span)	3.9950	4.0050	3.9963 V	2.1e-005 V		100.0 : 1
	100%	±(0.1% Span)	4.9950	5.0050	4.9974 V	2.6e-005 V		100.0 : 1
DC Voltage % Source - 0-5V Ch#3								
0 -5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0004 V	5.0e-007 V		100.0 : 1
	20%	±(0.1% Span)	0.9950	1.0050	0.9988 V	5.5e-006 V		100.0 : 1
	40%	±(0.1% Span)	1.9950	2.0050	1.9980 V	1.1e-005 V		100.0 : 1
	60%	±(0.1% Span)	2.9950	3.0050	2.9968 V	1.6e-005 V		100.0 : 1
	80%	±(0.1% Span)	3.9950	4.0050	3.9989 V	2.1e-005 V		100.0 : 1

The reported uncertainty is the uncertainty of the calibration process. For measuring instruments, add 0.6 of the least significant digit to the reported uncertainty to obtain the measurement uncertainty of the unit under test at the specific test point.
Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Calibration Lab Data Report - Page 4 of 7

Field not applicable.

SUPPLEMENTAL REPORT FOR 33-8Z881-1-1

CALIBRATION LAB DATA AS FOUND / AS LEFT

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	8 Uncertainty (k=2; ±)	TUR
	100%	±(0.1% Span)	4.9950	5.0050	4.9980 V	2.6e-005 V	100.0 : 1
DC Voltage % Source - 0-5V Ch#4							
0 - 5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0002 V	5.0e-007 V	100.0 : 1
	20%	±(0.1% Span)	0.9950	1.0050	1.0000 V	5.5e-006 V	100.0 : 1
	40%	±(0.1% Span)	1.9950	2.0050	1.9981 V	1.1e-005 V	100.0 : 1
	60%	±(0.1% Span)	2.9950	3.0050	2.9985 V	1.6e-005 V	100.0 : 1
	80%	±(0.1% Span)	3.9950	4.0050	3.9967 V	2.1e-005 V	100.0 : 1
	100%	±(0.1% Span)	4.9950	5.0050	4.9975 V	2.6e-005 V	100.0 : 1
DC Voltage % Source - 0-10V Ch#1							
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.001 V	5.0e-007 V	100.0 : 1
	20%	±(0.1% Span)	1.990	2.010	2.000 V	1.1e-005 V	100.0 : 1
	40%	±(0.1% Span)	3.990	4.010	4.000 V	2.1e-005 V	100.0 : 1
	60%	±(0.1% Span)	5.990	6.010	6.000 V	3.1e-005 V	100.0 : 1
	80%	±(0.1% Span)	7.990	8.010	7.997 V	4.1e-005 V	100.0 : 1
	100%	±(0.1% Span)	9.990	10.010	9.997 V	5.2e-005 V	100.0 : 1
DC Voltage % Source - 0-10V Ch#2							
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.002 V	5.0e-007 V	100.0 : 1
	20%	±(0.1% Span)	1.990	2.010	2.001 V	1.1e-005 V	100.0 : 1
	40%	±(0.1% Span)	3.990	4.010	3.998 V	2.1e-005 V	100.0 : 1

The reported uncertainty is the uncertainty of the calibration process. For measuring instruments, add 0.6 of the least significant digit to the reported uncertainty to obtain the measurement uncertainty of the unit under test at the specific test point.

Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Calibration Lab Data Report - Page 5 of 7

Field not applicable.

SUPPLEMENTAL REPORT FOR 33-8Z881-1-1

CALIBRATION LAB DATA AS FOUND / AS LEFT

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	8	Uncertainty (k=2; ±)	TUR
	60%	±(0.1% Span)	5.990	6.010	5.998 V	3.1e-005 V		100.0 : 1
	80%	±(0.1% Span)	7.990	8.010	7.998 V	4.1e-005 V		100.0 : 1
	100%	±(0.1% Span)	9.990	10.010	9.998 V	5.2e-005 V		100.0 : 1
DC Voltage % Source - 0-10V Ch#3								
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.001 V	5.0e-007 V		100.0 : 1
	20%	±(0.1% Span)	1.990	2.010	1.999 V	1.1e-005 V		100.0 : 1
	40%	±(0.1% Span)	3.990	4.010	4.001 V	2.1e-005 V		100.0 : 1
	60%	±(0.1% Span)	5.990	6.010	6.000 V	3.1e-005 V		100.0 : 1
	80%	±(0.1% Span)	7.990	8.010	7.999 V	4.1e-005 V		100.0 : 1
	100%	±(0.1% Span)	9.990	10.010	9.998 V	5.2e-005 V		100.0 : 1
DC Voltage % Source - 0-10V Ch#4								
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.001 V	5.0e-007 V		100.0 : 1
	20%	±(0.1% Span)	1.990	2.010	1.999 V	1.1e-005 V		100.0 : 1
	40%	±(0.1% Span)	3.990	4.010	3.998 V	2.1e-005 V		100.0 : 1
	60%	±(0.1% Span)	5.990	6.010	6.000 V	3.1e-005 V		100.0 : 1
	80%	±(0.1% Span)	7.990	8.010	8.000 V	4.1e-005 V		100.0 : 1
	100%	±(0.1% Span)	9.990	10.010	9.999 V	5.2e-005 V		100.0 : 1

The reported uncertainty is the uncertainty of the calibration process. For measuring instruments, add 0.6 of the least significant digit to the reported uncertainty to obtain the measurement uncertainty of the unit under test at the specific test point.

Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Calibration Lab Data Report - Page 6 of 7

Field not applicable.

FW021R1 1/27/14 Service Order Nbr: 33-8Z881-1-1

SUPPLEMENTAL REPORT FOR 33-8Z881-1-1

CALIBRATION LAB DATA AS FOUND / AS LEFT

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	8	Uncertainty (k=2; ±)	TUR
As Found and As Left Data recorded on March 11, 2014								
Temperature: 69.8°F / 21.0°C	Relative Humidity: 48%							
Asset	Manufacturer	Model						
N0118	Agilent/HP	3458A Opt 002	Multimeter, 8.5 Digit		June 25, 2013	June 30, 2014	5 & N0118-10-6	
			Description		Cal Date	Due Date	Traceability Numbers	

The reported uncertainty is the uncertainty of the calibration process. For measuring instruments, add 0.6 of the least significant digit to the reported uncertainty to obtain the measurement uncertainty of the unit under test at the specific test point.

Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Service Order Nbr: 33-8Z881-1-1

Fm21:R1 1/27/14

Calibration Lab Data Report - Page 7 of 7

Field not applicable.



Aercoustics Engineering Ltd.
1004 Middlegate Road, Suite 1100
Mississauga, ON L4Y 0G1

Tel: 416-249-3361
Fax 416-249-3613
aercoustics.com

E-Audit Checklist



(2017 Compliance Protocol AF5): E-Audit checklist

Wind Energy Project – Screening Document – Acoustic Audit Report – Emmission IEC61400-11 Standard

Information Required in the Acoustic Audit Report – Immission

Item #	Description	Complete?	Comment
1	Characterization of the wind turbine Items 1 to 26; IEC61400-11:2013, Section 10.2	✓	
2	Physical environment Items 27 to 33; IEC61400-11:2013, Section 10.3, Physical Environment	✓	
3	Measurement instrumentation Items 34 to 39; IEC61400-11:2013, Section 10.4, Instrumentation	✓	
4	Acoustic data Items 40 to 52; IEC61400-11:2013, Section 10.5, Acoustic Data	✓	
5	Non-acoustic data Items 50 to 53, and 56; IEC61400-11:2003 Section 10.6, Non-Acoustic Data Items 59 and 60; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 8, All necessary and supporting calculations	✓	
6	Uncertainty the apparent sound power level at integer wind speeds one-third octave band spectrum of the noise at the reference position at each integer wind speed the Tonality of the sound emissions of the wind turbine measured at the reference position	✓	
7	Additional information Item 60; NPC-233, Section 10, Report Format, bullet point number 4, Conclusions and Recommendations Item 61; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 8, All necessary and supporting calculations Item 62; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 3, Details of measurement procedure	✓	All data Excel sheet provided
8	Items 68 to 72; IEC61400-11:2013, Section 10.5, Acoustic Data	∅	Items 68 to 72 acoustic data as per IEC 61400-11 standard are optional; low frequency noise, infrasound, impulsivity, amplitude modulation not reported
9	Non-acoustic data Items 73 to 74 are from IEC61400-11:2013, Section 10.6, Non-Acoustic Data	∅	Items 73 to 74 non-acoustic data as per IEC 64100-11 standard are optional; turbulence intensity during acoustic measurements not reported

End of Report
